MAR 24 1983
ENVIRONMENTAL HEALTH

Date Received 3-21-83

SEE INSTRUCTIONS ON BACK

ICAR(S) Application No. 19467

T. C. No. 205-151-07


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _____ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____Yes ____No
Residence ✓Yes ____No

4) No. of Bedrooms 3
5) Business Use — Max No Employees _____
6) Washing Machine ✓Yes ____No
7) Garbage Disposal ____Yes ✓No
8) Dishwasher ✓Yes ____No
9) Water Supply:
A) Individual Well _____
B) Governmental System ✓
C) Community System:
1. Well source _____
2. Governmental source _____
10) Sewage System:
House located within 200 feet of public sewer ____Yes ✓No
House located within 200 feet of community sewer ____Yes ✓No
11) FHA Case No. _____
12) VA Case No. _____

13) NAME OF OWNER Brooks (LAST) Leroy (FIRST) (Middle)

14) ADDRESS OF OWNER 9545 Old Statesville Rd. Charlotte NC. 28210

15) PHONE NO. Home 523-6385 Office _____

16) LOCATION OF SYSTEM 9545 Old Statesville Rd. Charlotte NC. (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK 2577 AT PAGE 291

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN 1971

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

March 17-83
DATE OF APPLICATION

Leroy Brooks
OWNER

EHD-S-76

Serial No. 6157

ICAR(S) Permit No. 19467


Date Issued 3-23-83

T. C. No. 205-151-07

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, V Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19467 dated 3-17-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before April 7th 1983 after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS ~~FHA~~

Liquid Capacity of Tank

Tank Construction Repair

Absorption and/or Nitrification Lines:

Total Line Length 150 Lin FT

Number of Lines Three

Distance from House 10FT

Distance from Property Line 10FT

Distance from Well City

NAME OF OWNER BROOKS, LEROY

LOCATION OF PROPERTY 9545 OLD NATIONS FORD RD.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly

Three Trenches to be 50FT x 3FT x 17 inches stone - grade bds- Hay or Straw - use new DIST Box.

Comments:

Division or Section Head

Environmentalist Ralph Wilkes

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 19467

Date Issued 5/17/83 **Serial** 5776 T. C. No. 205-151-07

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Brooks (LAST) LeRoy (FIRST) (MIDDLE)

Location of Property 9545 old Nations Ford Rd

Application Number 19467 Permit Number 19467

Inspection Data:

Liquid Capacity of Tank Repair Tank Material Repair

Total Length of Drain Tile 125 Number of Lines 3

Depth of Filter Material 17" stone Cover Depth 2'

Water Supply Source City Distance from Water Source /

Excavation Inspected 5/17/83 (DATE) Tank Inspected / (DATE)

Nitrification Field Inspected 5/17/83 (DATE)

Washing Machine Line Inspected, If Applicable N/A (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ____ installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments:

Randy C. Poole RS
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY