Date Received 7-26-73

APT No. 6738

T. C No.

Map Date

mail to:
Mrs Robert Moore
212 Middleton Dr.
28207

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Early, Frank N. (LAST, FIRST, MIDDLE)

2) ADDRESS OF OWNER P. O. BOX 655 ZIP

3) PHONE NO Home 372-1220 Office


4) LOCATION OF PROPERTY Crest Oaks Lane (STREET OR COUNTY ROAD)

5) SUBDIVISION Highland Forest LOT NO 23 BLOCK NO. 33

MAP BOOK NO 213 PAGE NO. 3

6) DEED REFERENCE DEED BOOK 2508 PAGE NO. 121

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Frank N. Early Not Agent
OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. August 22, 1973
2. _____
3. _____

SDR No. 6738
T.C. No. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER _____

ADDRESS OF OWNER _____ ZIP _____

LOCATION OF LOT _____

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
N/A	1.	8-22-73	17 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Thomas R. Ward
Environmentalist

(Stencil No.)
HHD 398
8/70

FORM NO.
H-19-8-14-70