Date Received 2-28-84

MECK COUNTY DEPARTMENT OF
RECEIVED
FEB 28 84
ENVIRONMENTAL HEALTH

SIR No. 20665

T. C. No. 213-021-35

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Wooten, (LAST) Mary (FIRST) Kiser Charlotte, (MIDDLE)

2) ADDRESS OF OWNER C-21 American, 6135 Park Road, Suite 101 N. C. ZIP 28210

3) PHONE NO Home _____ Office 552-0021

4) LOCATION OF PROPERTY 9109 Sardis Road (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO 213 PAGE NO. 02

6) DEED REFERENCE DEED BOOK 3753 PAGE NO 491

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Mary K. Wooten by
OWNER Agent C. Karen Herring
(See attached)

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 22665

T.C. NO. PO 213-221-35

(Ground Absorption Sewage Disposal)

OWNER: Mary Hiser Winston suite 101 PLAT NO: A
ADDRESS: C-21 American 6135 Park Rd. Charlotte, N.C. LOT SIZE: 40,000
LOCATION OF SITE: 9104

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S 8-15% PS U	S complex slopes PS U	S 2-10% PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS sandy loam U	S 2-1 clay PS U	S PS — U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S Massive PS U	S weak Blocky PS U	S PS — U	S PS U
4. SOIL DEPTH (inches)	S 12-18" PS U	S 12-30" PS U	S PS — U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S Sapolite 12" PS U	S <30" PS U	S PS — U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S >30" to ground water PS U	S Eroded areas channel runoff PS U	S Drainage way PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IIIA	IIIA	—	
9. SITE CLASSIFICATION	unsuitable	unsuitable	unsuitable	
10. SOIL SERIES	Wilkes Pike	complex slo	Drainageway	

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William R. Martin
Title: Soil Scientist

Date: 3-22-84

2H


36'
Drainage way
235'
Utility Line
110'
Complex Slopes
924'
Sandstone

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
700 E. Blythe Boulevard
Charlotte, North Carolina 28203

SIR. NO. 20605
T.C. NO. PO 213-021-38
DATE: March 23, 1984

Century 21 American Realty, Inc.
6135 Park Road, Suite 101
Charlotte, North Carolina 28210

RE: Property located at 9109 Sardis Road - Plat A

Dear Sir:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption disposal systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be reasonably expected to function satisfactorily.

Should you desire to file for permission to install an alterrate system, plans and specifications prepared by a person with a demonstrated knowledge of ground absorption sewage treatment disposal systems, soil and rock characteristics, groundwater hycrology and drainage systems should be submitted to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the execution by you of "Septic Tank Agreemnt Form" provided by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure