SEE INSTRUCTIONS ON BACK

Date Received 10-13-82

OCT 19 [illegible]

ICAR(S) Application No. 19052 ✓

T. C. No. 089-111-04

ENVIRONMENTAL HEALTH

Map Date _____


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ATT. MR. NILES

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _____ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____Yes ____No
Residence ✓Yes ____No

4) No. of Bedrooms 3
5) Business Use — Max No Employees _____
6) Washing Machine ____Yes ✓No
7) Garbage Disposal ____Yes ✓No
8) Dishwasher ____Yes ____No
9) Water Supply
A) Individual Well ✓
B) Governmental System ____
C) Community System:
1. Well source ____
2. Governmental source ____
10) Sewage System:
House located within 200 feet of public sewer ✓Yes ____No
House located within 200 feet of community sewer ____Yes ____No
11) FHA Case No. _____
12) VA Case No. _____

13) NAME OF OWNER Kolk (LAST) Edward (FIRST) B (MIDDLE)

14) ADDRESS OF OWNER 5210 Tree Rd CLT 28209

15) PHONE NO. Home 537-1152 Office 525-5100

16) LOCATION OF SYSTEM 3125 N Tryon St. Clt. (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

19) HAS A SOIL INVESTIGATION BEEN RUN? ____ YES ✓ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

10.13.82 ✓
DATE OF APPLICATION

Edward B Kolk
OWNER

EHD-5-76


Date Issued Oct 18th 1982 Serial No. 5819 ICAR(S) Permit No. 19052

T. C. No. 089-111-04

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19052, dated 10-13-82 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before Nov 2nd 1982 after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate 4

Liquid Capacity of Tank 1000 gal

Tank Construction Pre Cast Concrete

Absorption and/or Nitrification Lines

Total Line Length 300 lin FT

Number of Lines SIX

Distance from House 10 FT

Distance from Property Line 150 FT

Distance from Well City

NAME OF OWNER ROCK EDWARD

LOCATION OF PROPERTY 5125 NORTH TRYON ST

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Six Trenches - 50 FT x 3 FT x 2 FT deep - 12 inches stone - grade boards Dist Box - Shown on map - 1000 gal Tank, lines on Contour.

Division or Section Head

Ralph Miller
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY