Date Received 2-2-83

FEB 2 - 1983

ENVIRONMENTAL HEALTH

S/R No. 19266

T.C. No. 037-071-30

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER OWENS (LAST) GINA (FIRST) WIKE (MIDDLE)

2) ADDRESS OF OWNER 5101 Park Road - Apt 136 ZIP 28209

3) PHONE NO. Home 525-7686 Office 335-6176

4) LOCATION OF PROPERTY 5928 Sunset Road (STREET OR COUNTY ROAD) 15 OCK


5) SUBDIVISION Sunset Oaks LOT NO. 3, 5 & 6 BLOCK NO. 30

MAP BOOK NO 37 PAGE NO. 7

6) DEED REFERENCE. DEED BOOK 2665 PAGE NO. 188

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge

MAP ATTACHED



7) ACCURATELY DIAGRAM & DIMENSION LOT

Gina Wike Owens
OWNER

EHD-S-76

Environmental Health Department's Copy

Serial No. 4842

PTR No. 19266

Date Issued 2-7-83

T. C. No. 037-071-30

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Owens, (LAST) Gina (FIRST) Wike (MIDDLE)

ADDRESS OF OWNER 5101 Park Road, Apt. 136, Charlotte, NC ZIP 28209

LOCATION OF PROPERTY 1925 Sunset Road (STREET OR COUNTY ROAD)

SUBDIVISION Sunset Oaks LOT NO. 5 & 6 BLOCK NO. 30



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was **Provisionally Suitable**. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the sanitary system must be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction, including the drilling of a well, is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

W.B. Ramsey
EHD-5-76 Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19266

T.C. NO. 037-071-30

(Ground Absorption Sewage Disposal)

OWNER: GINA OWENS
ADDRESS: 5101 Park Rd Apt. 136 28209
LOCATION OF SITE: Sunset Rd & Sunset Circle

PLAT NO:
LOT SIZE: 1.26

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2-15	S (PS) U — 2-6	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U — Clayey	S PS (U) — clay mixed	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — Blocky	S PS (U) — weak Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U — 40-48"	S PS (U) — 20-36"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — None	S (PS) U — None	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — Adequate	S PS (U) — Slow	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IIIa	IIIb		
9. SITE CLASSIFICATION	Suitable	Unsuitable		
10. SOIL SERIES	Cecil	Helene		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Ramsey
Title: Sanitarian

Date: 3-7-83

EHD 539 (Revised: 6/82)



With The Road Drainage moved, 70' of The Front of Each Lot Might Be Useable. Pump Would Be Required. House site is Located At *.

Date Received 2-25-83

FEB 25 1983

CAR(S) Application No. 19266

T. C. No 037-071-50


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) ____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____ Yes ____ No
Residence ✓ Yes ____ No

4) No. of Bedrooms 3
5) Business Use — Max No Employees ____
6) Washing Machine ✓ Yes ____ No
7) Garbage Disposal ✓ Yes ____ No
8) Dishwasher ✓ Yes ____ No
9) Water Supply:
A) Individual Well ✓
B) Governmental System ____
C) Community System:
1. Well source ____
2. Governmental source ____
10) Sewage System:
House located within 200 feet of public sewer ____ Yes ✓ No
House located within 200 feet of community sewer ____ Yes ✓ No
11) FHA Case No. ____
12) VA Case No. ____

13) NAME OF OWNER Owens (LAST) Gina (FIRST) Vike (MIDDLE)

14) ADDRESS OF OWNER 5101 Park Road - Apt. #136

15) PHONE NO. Home 525-7686 Office 335-6176

16) LOCATION OF SYSTEM 1925 Sunset Road (STREET OR COUNTY ROAD)

17) SUBDIVISION Sunset Oaks Lot No. 5 Block No. 30

Map Book No. 37 Page No. 7

18) DEED REFERENCE — DEED BOOK 2665 AT PAGE 188

19) HAS A SOIL INVESTIGATION BEEN RUN? X YES ____ NO DATE RUN 2-12-83

20) PTR NUMBER (See Instructions) ____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

February 24, 1983
DATE OF APPLICATION

Gina Vike Owens
OWNER

EHD-5-76

Serial No. 6228

SIR No. 19266

Date Issued 2-25-83

T. C. No. 037-071-30

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Owens, (LAST) Gina (FIRST) Wike (MIDDLE)

ADDRESS OF OWNER 5101 Park Road, Apt. 136, Charlotte, NC ZIP 28209

LOCATION OF LOT 1925 Sunset Road (STREET OR COUNTY ROAD)

SUBDIVISION Sunset Oaks LOT NO. 5 BLOCK NO. 30

MAP BOOK NO. PAGE NO.

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19266. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed,altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Environmentalist

Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department's Copy