

7726 MATTHEWS-MINT HILL RD

19703703

1/4/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 4131B DATE: 11-16-99

TC: 197-037-03 ☐ L ☐ CRT

SERIAL Nº 18167

Name of Owner MINT HILL VOLUNTEER FIRE DEPT Juris.: _____

Address of Property 7926 MATTHEWS-MINT HILL ROAD

Inspection Data:

Tank Material EXISTING

Total Length of Drainfield 12' x 55'

Number of Lines 1 @ 55'

Cover Depth 18" TO 24"

Water Supply Source WELL

Distance to Water Source UNKNOWN

Excavation Inspected 11-16-99

Tank(s) Inspected _____

Wash Line Inspected —

High Water Alarm Inspected _____

SRF INSTALLATION PERMIT

PLOT

Design REPAIR - BEP INSTALLED

#124
CTR# BOBBY HOWELL

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 15A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☑ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 15A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: TYPE II

Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR APPROVAL


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 413B DATE: 11-3-99

TC: 197-037-03 X

SERIAL No 18265

Permission is hereby given to _____ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated NOV. 3, 1999. All work shall be completed on or before NOV. 3, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank EXISTING gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction —

Trench Depth 36"+

Absorption and/or Nitrification Lines:

Trench Width 12' feet

Trench Walls Scored and Porous —

Total Line Length 240' feet

Number of Lines 1

Depth of Stone 18" inches

Distance from House 5' feet

Distance from Property Line 5' feet

Distance from Well >50 feet

NOTICE: This system shall not be installed while soils are in a wet condition.

NAME OF OWNER MINT HILL VOLUNTEER FIRE DEPT

LOCATION OF PROPERTY 7726 MATTHEWS-MINT HILL ROAD.

Comments: (1) INSTALL SANITARY "T" IF ONE IS NOT PRESENT.

(2) REPAIR TO BE 12' WIDE AND 60' LONG W/ 18" STONE.

Environmental Health Specialist

WHITE - HEALTH DEPARTMENT's COPY • CANARY - E.H.S. COPY • PINK - OWNER OR AGENT's COPY

Reynolds
& SONS Construction Company
P.O. BOX 23034
CHARLOTTE, NC 28227-0272
(704) 545-4526 FAX (704) 545-4700

4/131B
use as septic

Post-it® Fax Note 7671
To Drew Walker
Co./Dept.
Phone #
Fax #
Date 11-3-99
From Bobby Reynolds
Co.
Phone #
Fax #
# of pages ▶ 1

November 3, 1999

Mr. Drew Walker
Mecklenburg County
Environmental Health Department

Ref: Septic repairs to system located at
7726 Matthews-Mint Hill Road

Property Owner:
Mint Hill Volunteer Fire Department
P.O. Box 23065
Charlotte, North Carolina 28227

Built 1950

Tax Parcel #197-037-03
Zoned BG
Building was built in 1950 and is approximately 1,500 sq.ft.
One restroom, and at most, three employees.

If you need further information, please let me know.

Thank you,

REYNOLDS & SONS CONSTRUCTION COMPANY

Bobby Reynolds
President