

9015 PLEASANT RIDGE RD

10528109

5/1/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2759-A DATE: 2-8-91

TC: 105-142-35 ☒ L ☐ CRT

SERIAL Nº 13725

Name of Owner Bob McLemore Co. Juris.:

Address of Property 9015 Pleasant Ridge Rd.

Inspection Data:

Tank Material PCC

Total Length of Drainfield 534'

Number of Lines 6 @ 89'

Cover Depth 18-21"

Water Supply Source Comm

Distance to Water Source —

Excavation Inspected 2-8-91

Tank(s) Inspected 2-8-91

Wash Line Inspected

High Water Alarm Inspected

PLOT

Design: 1991, 1500ST, con, 1602SFT, 12G, cecil CTR# 113

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: Installed as permitted.

B. R. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.