Date Received 10/15/84

SIR No. 21532

T. C. No. 139-129-46 #46

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER HANEY (LAST) SALLY (FIRST) B. (MIDDLE)

2) ADDRESS OF OWNER P. O. Box 25311 ZIP 28229

3) PHONE NO. Home _____ Office 536-2100


4) LOCATION OF PROPERTY 14708 AUGUST LN. (STREET OR COUNTY ROAD) Charlotte 28212

5) SUBDIVISION ARLINGTON FOREST LOT NO. 112 & 1/2 of 111 BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE: DEED BOOK _____ PAGE NO. _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Sally B. Haney
OWNER

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21532

T.C. NO. 139-129-45.4

(Ground Absorption Sewage Disposal)

OWNER: Sally B. Harvey
ADDRESS: PO Box 35011
Charlotte, NC 28235

PLAT NO: Lot 112 & Pt 111
LOT SIZE: 30,400

LOCATION OF SITE: 14228 August Lane

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U 2-9%	S (PS) U 2-8%	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U Clay	S (PS) U Clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U Blocky	S (PS) U Blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) U 36-40"	S (PS) U 36-40"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U >36"	S (PS) U >36"	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U >36" to ground water	S Depression PS collects (U) water	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IC'A	IC'A		
9. SITE CLASSIFICATION	Provisionally suitable	unsuitable		
10. SOIL SERIES	Cecil L. Ho	Depression		


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William R. Maclin
Title: Soil Scientist

Date: 11-19-84


150'
Depression
606'
803'
Cecil L. Hill
August Lane
150
Leyton Pl.

Serial No. 5948

SIR No. 21532

T. C. No. 139-~~219~~-45,46

Date Issued 11-19-84

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Haney, (LAST) Sally (FIRST) B. (MIDDLE)

ADDRESS OF OWNER P.O. Box 25311, Charlotte, NC ZIP 28229

LOCATION OF PROPERTY 14708 August Lane (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot PROVISIONALLY SUITABLE The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge subject to the following terms and conditions

1. A permit to install construct alter or repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of the proposed wastewater treatment system on the said lot
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health at the time of application for a permit based on the permeability rate obtained above and on the size and type of building constructed thereon
3. This approval is for the plot only of the system as installed in the immediate area shown and does not accept the lot for system installation on the above plot
4. This approval is void if any grading filling or construction including the placing of earth on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for installation construction alteration and repair of the system

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

William R. Marlin
Soil Scientist

Bill D. Hardister
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·


PROPOSED PLOT PLAN

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21532

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: Jerry W. Smith

Date: 6-5-87

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 21532
TC:
SERIAL: № 13644

RECEIVED
JUN 08 1987
ENVIRONMENTAL HEALTH

☒ L ☐ CRT

JOB LOCATION

① ADDRESS: 14703 (STREET NO) AUGUST LANE (STREET) ② FILE:

③ JURISDICTION: MECK. COUNTY ④ TAX PARCEL NO.: 137-129-45

⑤ SUBDIVISION: ARLINGTON FOREST ⑥ LOT: 111 + 112 ⑦ BLOCK: B

OWNER

⑧ NAME: JERRY (FIRST) DEAN (MIDDLE) SNIDER (LAST)

⑨ MAILING ADDRESS: 3109 ROSEHAVEN DR

⑩ CITY: CHARLOTTE ⑪ STATE: N.C. ⑫ ZIP: 28205

⑬ PHONE: (WORK) 535-1210 ⑭ (HOME) 531-3017

REQUEST

This request is for a(n):

⑮ ☒ New permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type?

㉓ Maximum occupancy? 4 ㉖ Maximum number of employees?

㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Jerry D. Snider

Date: 6-5-87

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance

Environmentalist — Date: 6-11-87

Director or Authorized Section Head — Date: 6-12-87

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21532 DATE: 12-8-87

TC: 139-129-45 L

SERIAL № 11490

Permission is hereby given to ✓ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 6-5-87. All work shall be completed on or before 12-8-88, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank ____ gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400 feet

Number of Lines 5

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well > 50 feet

NAME OF OWNER Jerry Snider

LOCATION OF PROPERTY 14708 August Ln.

Comments: 5 lines 3'X80'X12" stone

Division or Section Head

B. R. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21532 DATE: 12-18-87
TC: 139-129-45 ☐ L ☐ CRT
SERIAL № 10747

Name of Owner Jerry Snider Juris.:
Address of Property 14708 August Ln.

Inspection Data:

Tank Material PCT
Total Length of Drainfield 400'
Number of Lines 5 @ 80'
Cover Depth 15-21"
Water Supply Source well
Distance to Water Source 750'
Excavation Inspected 12-18-87
Tank(s) Inspected 12-18-87
Wash Line Inspected
High Water Alarm Inspected

PLOT

Design: 1987, 1500ST, Con, 1200SFT, 12G, cecil CTR# 113

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☑ installed or constructed ☐ altered or repaired
☑ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☑ Certificate of Completion ☐ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS:

B. A. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.