

11904 MOUNTAIN CREST CR

02316444

5/31/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

TO: ENVIRONMENTAL HEALTH DEPT.
BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

DATE 11-11-91

FROM: COUNTY ENGINEERING DEPARTMENT

53284

EHD FILE _____ JURISDICTION CODE Mech

PARCEL NUMBER 023-101-03pa

ASSIGNED ADDRESS 11904 Mountain Crest Cr

EXISTING ADDRESS _____ 480

PROJECT NAME Mountain Point Ph 2

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	DISAPPROVED
1. SUBDIVISION REGULATIONS	/ /	/ /*
2. FLOODWAY REGULATIONS	/ /	/ /*
3. EROSION CONTROL REGULATIONS	/ /	/ /*
4. PUBLIC UTILITY EASEMENT	/ /	/ /*

	PRESENT	NOT PRESENT
5. PUBLIC UTILITY EASEMENT	/ /*	/ /
6. PROPERTY FRONTS ON THOROUGHFARE	/ /*	/ /
7. DRIVEWAY PERMIT REQUIRED	/ /*	/ /

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: _____

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: _____

OPWEAR 06-88

NEW ADDRESS / /*

FORM 100

APPLICATION FOR AN IMPROVEMENT PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 5318A
TC: 02301135 PO
SERIAL: № 18530
L CRT

JOB LOCATION

① ADDRESS: 11904 Mountain Crest Circle (STREET NO. / STREET) ② FILE: 5318A
③ JURISDICTION: Mecklenburg ④ TAX PARCEL NO.: 02301135 PO
⑤ SUBDIVISION: Mountain Point ⑥ LOT: 80 ⑦ BLOCK: N/A

OWNER

⑧ NAME: Howard Eddie + Elizabeth McElveen Yountz, Jr (FIRST / MIDDLE / LAST)
⑨ MAILING ADDRESS: 201 Deer Run
⑩ CITY: Denver ⑪ STATE: NC ⑫ ZIP: 28037
⑬ PHONE: (WORK) 704-333-2131 ⑭ (HOME) 704-483 9786

REQUEST

This request is for a(n):

⑮ ☑ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3 ㉕ Type? _____
㉓ Maximum occupancy? 2 ㉖ Maximum number of employees? _____
㉔ Basement? ☑ yes ☐ no ㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☐ Individual well
B ☐ Municipal system
C ☑ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter on the property for the purpose of processing this request.

Signed: Elizabeth M Yountz
Date: 11/12/90

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 36 months from the date of issuance.

Tim Whittaker, Environmentalist — Date: 1/10/91

Director or Authorized Section Head — Date: 1-11-91

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5378 A

TC: 02301135 PO

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE TW. 1/10/91

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5378-A DATE: 4/29/91

TC: 023 011 35 ☒ L

SERIAL Nº 14783

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 11/12/91. All work shall be completed on or before 5/29/91, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1,500 gallons

Liquid Capacity of Dosing Tank 1,000 gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 400' feet

Number of Lines 4 or 5

Depth of Stone 12" inches

Distance from House 15' feet

Distance from Property Line 10' feet

Distance from Well >50' feet
C/WELL

NAME OF OWNER Howard Yountz, Jr.

LOCATION OF PROPERTY 11904 Mountain Crest Circle (Lot 80)

Comments: 3 bedrm. (4) 3'x100'x12"g or (5) 3'x80'x12"g. split / with 2-D-boxes if necessary.

Division or Section Head

Tim Whitaker, R.S.
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5378-A DATE: 5/7/91

TC: 0230135 ☒ L ☒ CRT

SERIAL № 13096

Name of Owner Howard Yountz, JR. Juris.:

Address of Property 11904 Mountain Crest Circle (Lot 80)

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400'

Number of Lines 3 @ 133'

Cover Depth 12" +

Water Supply Source C/WELL

Distance to Water Source >50'

Excavation Inspected Y

Tank(s) Inspected Y, Y

Wash Line Inspected —

High Water Alarm Inspected INSTALLED

PLOT

Design: 1500 ST, 1000 gal. PT, mod 1200 SFT, 12" g LEG CTR# 16

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 3 bedrm. (3) 3'x133'x12"g.

Tim Whittaker, R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

DATE: 11/12/90

TO: HEALTH DEPARTMENT - ENVIRONMENTAL HEALTH

FROM: COUNTY ENGINEERING

EHD FILE 5378A JURISDICTION CODE Mecklenburg

PARCEL NUMBER 02301135 70

ASSIGNED ADDRESS 11904 Mountain Crest Circle

EXISTING ADDRESS ———

PROJECT NAME _____

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	NOT APPROVED
1. SUBDIVISION REGULATIONS	☐	☐ *
2. FLOODWAY REGULATIONS	☐	☐ *
3. EROSION CONTROL REGULATIONS	☐	☐ *
4. COMMERCIAL DRAINAGE PLAN	☐	☐ *
	PRESENT	**NOT PRESENT**
5. PUBLIC UTILITY EASEMENT	☐ *	☐
	YES	**NO**
6. PROPERTY FRONTS ON THOROUGHFARE	☐ *	☐
	YES	**NO**
7. DRIVEWAY PERMIT REQUIRED	☐ *	☐

*** If checked, further investigation will be required to determine whether a building permit may be issued by Building Standards for the site.**

REMARKS: Please contact builder for problems or meetings. (Alan Lovette 598-6111)

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIERS OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: _____

OPWEAR 02/86


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5378A

TC: 02301135PO

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: E M Yount

Date: 11/12/90

6L 47 114

141 114 80

APPLICATION FOR SOIL INVESTIGATION

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5378A

TC: _____

☐ PC ☐ REPT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

JAN 11 1989

$30.

JOB LOCATION

① ADDRESS: Mountain Point Lane

② SUBDIVISION: Mountain Point Ph. 2 ③ LOT: 80 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 023 PAGE NO.: 13 PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: 436, 426 (LMI-90) PAGE NO.: 204, 354

OWNER


⑦ NAME: Crescent Land & Timber Corp. (c/o Lana Hathaway)
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: 2305 Randolph Road, Suite C

⑨ CITY: Charlotte ⑩ STATE: N.C. ⑪ ZIP: 28207

⑫ PHONE: (WORK) (704) 332-9340 (HOME) (704) 892-9811

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Miles Boyer, V.P.

Date: 1/11/89

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

May 30th, 1989

Crescent Land & Timber Corp.
2305 Randolph Road, Suite C
Charlotte, NC 28207

RE: Property located at Mountain Point Lane 80
FILE: 5378A
PARCEL: 02301135 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 12098) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Very truly yours,

Jim Ericson, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

APPLICATION FOR SOIL INVESTIGATION

30

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5378A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: Mountain Crest Circle

② SUBDIVISION: Mountain Point Ph. 2 ③ LOT: 80 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 023 PAGE NO.: 13 PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: 436 426 (LMI-90) PAGE NO.: 204 354

OWNER


⑦ NAME: Crescent Land & Timber Corp. (c/o Lana Hathaway, LandCraft Properties)
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: 2305 Randolph Road, Suite C

⑨ CITY: Charlotte, ⑩ STATE: N.C. ⑪ ZIP: 28207

⑫ PHONE: (WORK) (704) 332-9340 (HOME) (704) 892-9811

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Ethelene G Williams

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: March 23, 1989

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12098

File: 5378A Action 1

Parcel: PO 023-011-35 ☐ PC

Location: Mountain Crest Circle

Subdivision:


Lot: 80 Block: Acres: 1.07

Owner: Crescent Land & Timber Corp.
Address: 2305 Randolph Road, Suite C
Charlotte, N. C. 28207

Comments: Recommend system site be approved before lot is closed

Described by: William A. Marlin

Date: 5-30-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 6-15%	S PS (U) Depression	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U clay	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Block	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 7-36" to water	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36"+	S PS U —	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 36"+	S PS U —	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U limited	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVA cecil-like	Depression				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U