Date Received 3/23/79

APT No. 15286

Copy to: Marvin White 2129 Barrington Dr. (Apt B) Char. 28215

T. C. No. 80 106-112-14

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER WHITE (LAST) MARVIN (FIRST) A (MIDDLE)

2) ADDRESS OF OWNER 2129 Barrington Rd Apt B ZIP
(Charlotte 28215)

3) PHONE NO Home Office


4) LOCATION OF PROPERTY Off Plaza Rd Ext
STREET OR COUNTY ROAD

5) SUBDIVISION Crab Orchard LOT NO [redacted] BLOCK NO.

MAP BOOK NO PAGE NO.

6) DEED REFERENCE DEED BOOK 1967 PAGE NO. 641

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Marvin A White
OWNER

EHD-5-76

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. No. 15 286

(Ground Absorption Sewage Disposal)

OWNER: Russell Howe
ADDRESS: P.O. Box 137
COUNTY: Newell, N.C. 28126
LOCATION OF SITE: 66 Plaza Rd Ext.

DATE REQUESTED:
PLAT NO.: PO 109-112-14
LOT SIZE: Approx 20,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS 2-10% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S PS 2-1 (U) Clay	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 in.) (Clayey Soils)	S PS Massive (U)	S PS U	S PS U	S PS U
4. SOIL DEPTH (In.)	S PS 24" (U)	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (In.) (Impervious Strata, Rock)	(S) None PS U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) 76 to PS ground U water	S PS U	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation Rate)	S slow PS (U) slow	S PS U	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	unsuitable			
SOIL SERIES	Enon			

S - Suitable PS - Provisionally Suitable U - Unsuitable

* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns)


Recommendations/Comments: Proposed dwelling to connect to well at existing house on another portion of the property

Described By: William R. Tomlin

Title: Soil Scientist Date: 3-30-79

dhs form 2601 (1/79)
Sanitation

Plaza Rd Ext



Approx ½ mile
of Plaza Rd

Existing
House

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

SIR.NO. 15286
T.C.NO. _____
MAP DATE no 108-112-14
DATE March 31, 1979

NAME OF OWNER Grier, Druscillia

ADDRESS OF OWNER PO Box 137, Newell, N.C. 28126

LOCATION OF LOT off: Plaza Road Extension

At your request and pursuant to Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Health Services, Subchapter 10A, a site evaluation has been made for an on premises ground absorption sewage disposal system on the property designated above and the following conditions were found:

Soil Structure Massive

Soil Permeability Unsuitable

Sites classified as Unsuitable are not acceptable for soil absorption of sewage effluent. However, if engineering, geologic, soil, and environmental studies indicate that a suitable septic tank system or a suitable alternate system can be expected to function satisfactorily, such sites may be re-classified as Provisionally Suitable. (Section 10 of the North Carolina Administrative Code 10 A,.1910)

If you desire to file for permission to install an "alternate or modified" system, you should present this office with your proposals in the form of plans and specifications. These would be reviewed and if it is found that the system may reasonably be expected to function satisfactorily, approval may be given on the execution by you of a "Septic Tank Agreement Form" available in this office.

John R. Adkisson, Environmentalist

EHD 999 (1/79)

SEE INSTRUCTIONS ON BACK

Date Received 3/22/79

ICAR(S) Application No. 15286

T. C. No. R0 103-112-14


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) _____ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No

4) No. of Bedrooms 3

5) Business Use — Max No Employees _____

6) Washing Machine ___ Yes X No

7) Garbage Disposal ___ Yes X No

8) Dishwasher ___ Yes X No

9) Water Supply:
A) Individual Well _____
B) Governmental System _____
C) Community System:
1) Well source _____
2) Governmental source _____

10) Sewage System
House located within 200 feet of public sewer ___ Yes ___ No
House located within 200 feet of community sewer ___ Yes ___ No

11) FHA Case No _____

12) VA Case No _____

13) NAME OF OWNER White (LAST) Marvin (FIRST) A (MIDDLE)

14) ADDRESS OF OWNER 9129 Barrington Apt B 28215

15) PHONE NO. Home _____ Office _____

16) LOCATION OF SYSTEM off Plaza Rd Extn (STREET OR COUNTY ROAD)

17) SUBDIVISION Crab Orchard. Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK 1967 AT PAGE 641

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.


_____ Marvin A. White
DATE OF APPLICATION OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

15286

1



6 lines 55' long
990 sq ft bottom area
12" stone with 4"&6"
sand under stone

Joselyn White

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG

4183 0800 1524 4

The undersigned, Jocelyn White, owner of property located at off: Plaza Road Ext. (PO 108-112-14), ("the site") and described in instrument recorded in Book 1967 at Page 641, Mecklenburg Public Registry, hereby acknowledges that he applied to the Department of Environmental Health for a permit to install a septic tank sewage disposal system on the site; the Department evaluated the site for suitability for such a system in accord with the regulations promulgated by the North Carolina Commission for Health Services as 10 NCAC 10A .1900 et seq; that the Department classified the site as UNSUITABLE and an appropriate permit was issued by the Department.

The undersigned further acknowledges that the proper design, construction and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees, or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time, or that the Department, its officials, employees or agents assume any liability for damages, consequential or direct, which are caused, or which may be caused, by a malfunction of such system.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

And the undersigned further agrees for himself, his heirs and assigns, that he shall indemnify and hold harmless the Department and its successors, as well as Mecklenburg County, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure, of said septic tank system.

And the undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately, in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This 2nd day of MAY, 1979.

Jocelyn White (Seal)

(Seal)

PRESENTED FOR REGISTRATION
'79 MAY 2 PM 12
CHARLES E. ROBINSON
REGISTER OF DEEDS
MECKLENBURG CO.

STATE OF NORTH CAROLINA,
COUNTY OF MECKLENBURG

I, John R. Adkisson, a Notary Public for said County and State, do hereby certify that Jocelyn White, personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 2nd day of May, 19 79.

John R Adkisson
Notary Public

My Commission Expires: December 9, 1981

STATE OF NORTH CAROLINA,
COUNTY OF MECKLENBURG

I, _____, a Notary Public for said County and State, do hereby certify that _____ personally came before me this day and acknowledged that he is _____ of _____, and that by authority duly given and as the act and deed of said corporation, the foregoing instrument was signed in its name by its _____, sealed with its corporate seal and attested by _____ as its _____.

WITNESS my hand and notarial seal, this ____ day of _____, 19 __.

_____
Notary Public

My Commission Expires: _____

Drawn By Mail
City County County Dept.
1200 Blythe Blvd.

BOOK PAGE


4183 0808

0080 0818

State of North Carolina, County of Mecklenburg
The foregoing certificate(s) of John R. Adkisson,

a Notary(~~xxx~~) Public of said County and State
is ~~xxx~~ certified to be correct. This 2 day of May, 19 79
Charles E. Crowder, Register of Deeds, By; Mary L. Rice Deputy

1.00
3.00
4.00



Serial No. 2984

LA No. 15286

Date Issued May 2, 1979

T. C. No. po 108-112-14

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

IMPROVEMENT PERMIT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER White, Jocelyn and Marvin A.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER 7129 Barrington Drive, Apt. B, ZIP 28215

LOCATION OF LOT off: Plaza Road Extension
(STREET OR COUNTY ROAD)

SUBDIVISION Crab Orchard LOT NO. BLOCK NO.

MAP BOOK NO. PAGE NO

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 15286. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

****AGREEMENT FORMS SIGNED AND RECORDED*****

Environmentalist

John R Atkinson
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy