CERTIFICATE OF COMPLETION/OPERATION PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 7554A/7555A DATE: 6/28/04

TC: 003-081-37 ☑ L ☑ CRT

SERIAL 19228

Name of Owner DONNA WILDRICK, INC. Juris.: _____

Address of Property 19007 CALLAWAY HILLS LANE

Inspection Data:

Tank Material PCC

Total Length of Drainfield 600'

Number of Lines 6 @ VARYING LENGTHS

Cover Depth 12"

Water Supply Source well


Distance to Water Source >50'

Excavation Inspected 6/28/04

Tank(s) Inspected 6/25/04

Wash Line Inspected —

High Water Alarm Inspected —



Design 1500ST, 1800SFT, INV, E-Z FLOW, DROP BOXES CTR# CARRY TUCKER

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☒ as detailed in the plot above

and meets the provisions of I5A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☐ Certificate of Completion ☒ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of I5A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: 6 BEDROOM HOUSE

6 LINES X (60', 50', 40', 150', 150', 150') X 5'

TYPE IIIg INNOVATIVE SYSTEM

Tommy Mecklin R.S.
Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON STREET
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: 7554A & 7555A

TC: 003 081 37 & 38

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.

4 Bedroom House
w/ plumbing in basement

COMMENTS — Lots 26A & 27A to be combined as one
1500 ST, 1000 DT
pressure manifold distribution,
6 lines x 90' long x 3' wd x 12" stone
535 LF Type IIIb Repair Area
Keep the septic system > 100' (50' min) from the proposed well
Survey showing lots 26A & 27A combined as one shall be on file before final Operation Permit release
110' from the front left house corner to the front property line
20' from

362'
Flood plain
Repair Area
381'
915'
HOUSE
60'
60'
20'
110'
PROPOSED WELL
Repair Area
90'
90
90
90
90
90
Fill
180'
Calloway Hills Ln
pressure manifold

APPROVAL DATE 2/6/01

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy