

14317 EASTFIELD RD

02112218

5/30/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5135A DATE: 12/6/89

TC: 021-111-04 PO ☒ L ☐ CRT

SERIAL № 12246

Name of Owner Thomas R. Hunter Juris.:

Address of Property 14317 Eastfield Rd, Hunt NC

Inspection Data:

Tank Material PCC

Total Length of Drainfield 600

Number of Lines 6 @ 100

Cover Depth 10"

Water Supply Source well

Distance to Water Source 750

Excavation Inspected 12/6/89

Tank(s) Inspected 12/6/89

Wash Line Inspected NA

High Water Alarm Inspected NA

PLOT

Design: 1989, 1500ST, DV, MOD, 1800SFT, 12"G, packet CTR# 22

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☒ installed or constructed ☐ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System designed for 3 bedroom house

Philo S. Walker
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 5735A DATE: 11/22/89

TC: 021 111 04 PO L

SERIAL Nº 13093

Permission is hereby given to ✓ Install or Construct, _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 12/15/88. All work shall be completed on or before 12/22/89, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank - gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 600 feet

Number of Lines 6

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well >50 feet

NAME OF OWNER Thomas R. Hunter

LOCATION OF PROPERTY 14317 Eastfield Rd, Hunt NC


Comments: 6 Trenches x 100'long x 3' x 12 Gravel
Diversion valve, Dual drainfields

Division or Section Head

Philo S. Walker
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY



1500 gal tank
6 - 3 x 100' trenches
12" stone 6" sand
Diverter valve
24" 30" maximum depth

JHS
7-6-89

JANUARY 25, 1989
Thomas R. Hunter

COPY

PRESENTED FOR REGISTRATION

89 JUN 19 PM 3:06

PAMELA A. POWERS
REGISTER OF DEEDS
MECKLENBURG COUNTY, N.C.

FILE NO. 5135A

STATE OF NORTH CAROLINA

COUNTY OF MECKLENBURG

ACKNOWLEDGEMENT OF REQUEST BY OWNER FOR RECLASSIFICATION FROM "UNSUITABLE" TO "PROVISIONALLY SUITABLE" UNDER 10 NCAC 10A .1948(c)

The undersigned, THOMAS RICHARD HUNTER + ALMA W. HUNTER,

owner of property located at 14317 EASTFIELD ROAD, HUNTERSVILLE, N.C. 28078

("the site") and described in an instrument recorded in Book 5975 at Page 0277, Mecklenburg Public Registry,

hereby acknowledges that he applied to the Mecklenburg County Department of Environmental Health ("the Department") for a permit to install a septic tank sewage disposal system on the site; that the Department evaluated the site for suitability for such a system in accordance with the regulations promulgated by the North Carolina Commission for Health Services as 10 NCAC 10A .1934 et seq; that the Department originally classified the site as "unsuitable" pursuant to the standards set forth in the regulations; that the undersigned requested pursuant to 10 NCAC 10A .1948(c) that the Department reclassify the site as "provisionally suitable" in light of the particular septic tank system proposed by the undersigned; that the Department considered various studies, data and other information which indicate to the Department that the septic tank system proposed by the undersigned can reasonably be expected to function satisfactorily and thus that the findings specified in 10 NCAC 10A .1948(c)(1), (2), and (3) can be made; and that the Department therefore reclassified the site as "provisionally suitable" and issued an appropriate permit for such proposed septic tank system.

The undersigned further acknowledges that the proper design, construction, operation and maintenance of such septic tank system is his responsibility and that neither the Department nor its officials, employees or agents warrant or guarantee that the said system installed pursuant to the permit issued by the Department will function in a satisfactory manner for any given period of time or that the Department, its officials, employees or agents assume any liability for any damages of any kind which are caused, or which may be caused, by a malfunction of such system.

The undersigned further agrees for himself, his heirs and assigns that he shall indemnify and hold harmless the Department, its employees and officials, as well as Mecklenburg County and its employees and officials, for any damages or other claims of any person or persons whatsoever arising out of the installation, operation, or failure of said septic tank system.

The undersigned further agrees for his heirs and assigns that, in the event any septic tank system installed under authority of the aforesaid permit fails to perform adequately in any respect, he will take whatever measures are required to correct same; or if such is impossible he will discontinue use of said system immediately.

Use of the singular masculine pronoun forms herein shall be deemed to also include the plural and feminine forms as the context may require.

This document shall be placed on the public records of the Register of Deeds of Mecklenburg County and indexed therein under the Grantor Index in the name or names of the undersigned, and the foregoing acknowledgements shall henceforth be binding on all persons claiming any right, title, or interest in the site.

This 19th day of June, 1989.

Thomas Richard Hunter (SEAL)

Alma W. Hunter (SEAL)

STATE OF NORTH CAROLINA
COUNTY OF MECKLENBURG


I, Joyce L. Graham, a Notary Public for said County and State, do hereby certify that Thomas Richard Hunter & Alma W. Hunter personally appeared before me this date and acknowledged the due execution of the foregoing instrument.

WITNESS my hand and notarial seal, this 19th day of June, 1989.

My Commission Expires
December 30, 1989

Joyce L. Graham
Notary Public

AMENDED DRAWING
6-18-89
Thomas R. Hunter
PHONE 334.9791



FILE # 5135A
PARCEL #0211104P0

EASTFIELD ROAD

Mecklenburg County
Health Department

Basil G. Velta, M.D., M.P.H.
Health Director

April 19th, 1989

Thomas Richard Hunter
14228 Eastfield Road
Huntersville, NC 28078

RE: Property located at Eastfield Road
FILE: 5135A
PARCEL: 02111104 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 12047) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure (2)

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 12047

File: 5 135A Action 2

Parcel: PO 021-111-04 ☐ PC

Location: 14317 Eastfield Rd.

Subdivision:


Lot: Block: Acres: Approx 1.0

Owner: Thomas Hunter
Address: 14228 Eastfield Rd.
Huntersville, NC 28078

Comments: _____

Described by: William McMurtin

Date: 4-18-89



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 15-30%	S (PS) U 6-20%	S PS U —	S PS U —	S PS U	S PS U
Texture	S PS (U) 2-1 Clay	S (PS) U Clay	S PS U —	S PS U —	S PS U	S PS U
Structure	S (PS) U Blocky	S (PS) U Blocky	S PS U —	S PS U —	S PS U	S PS U
Drainage	S (PS) U 7-36" To water	S (PS) U 7-36"	S PS U —	S PS U —	S PS U	S PS U
Depth	S PS (U) 18-24"	S PS (U) 24-30"	S PS (U) 12-18"	S PS U —	S PS U	S PS U
Restrictive Horizons	S (PS) U 7-36"	S (PS) U 7-36"	S PS U	S PS U —	S PS U	S PS U
Available Space	S (PS) U	S (PS) U	S PS U	S PS U —	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IvB Mecklenburg Wilkes	IvA Pacolet Lilly	Cut Area	Filled gulley		
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 3/22/89

Name/Company Thomas Hunter

Sanitation

Vector Control

O.I.S.E.

Service: Soil Test
#5135A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

MAR 21 1989

Ck #3377
#30.00

Fee: $ 30

Completed by

APPLICATION FOR SOIL INVESTIGATION

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5125A

TC: /

☒ PC ☐ REPT

JOB LOCATION

① ADDRESS: 14317 EASTFIELD ROAD, HUNTERSVILLE, N.C. 28078

② SUBDIVISION: _____ ③ LOT: _____ ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: PO-021 PAGE NO.: 111 PARCEL NO.: 04

⑥ DEED REFERENCE: BOOK NO.: 5975 PAGE NO.: 0277

OWNER


⑦ NAME: THOMAS (FIRST) RICHARD (MIDDLE) HUNTER (LAST)

⑧ MAILING ADDRESS: 14228 EASTFIELD ROAD

⑨ CITY: HUNTERSVILLE ⑩ STATE: N.C. ⑪ ZIP: 28078

⑫ PHONE: (WORK) 334-9791 (HOME) 875-2673

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.


Signed: Thomas R. Hunter

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

Date: MARCH 21, 1989

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER'S COPY

CAM CONSTRUCTION
RT. 1, BOX 210
STANLEY, N. C. 28164
704/827-3793



Specifications

1500 gal tank
Diverter valve
4 - 3'x 75' trenches
12" stone 6" sand
Ditches to be dug according to slope and grade of plot

Approximate Distance from Eastfield Rd 600'

Trenches to be installed 24" - 30" maximum depth

Mecklenburg County
Health Department

Basil G. Deltas, M.D., M.P.H.
Health Director

January 27, 1989

Thomas Richard Hunter
14228 Eastfield Road
Huntersville, NC 28078

Dear Mr. Hunter:

RE: Property located at 14317 Eastfield Road
FILE: 5135A
PARCEL: 021-111-04 PO

Receipt of your plans for a modified waste disposal system for the property referenced above is acknowledged.

Your plans for the modified system for the above property as submitted are approved with the following comments:

- The well should be located 100 feet or no less than 50 feet away from any part of the sewage disposal system and repair area.

- Water saving plumbing devices and low flush or microflush toilets must be installed when constructing the residence.

Upon execution and recording with the Register of Deeds Office, Mecklenburg County, of the enclosed "Septic Tank Agreement Form", an Improvements Permit may be issued by this office.

Sincerely,

Jim Ericson, R.S.
On Premises Waste Disposal & Water Supply

JE/ir

Enclosures - 3 Septic Tank Agreement Forms
Copy of Plans

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 12/22/88

Name/Company Thomas R. Hunter

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: Impr - New
#5135A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID

DEC 22 1988

Fee: $ 150.00 ck#3334 $150.00

Completed by _____ Collected by _____

APPLICATION FOR AN IMPROVEMENT PERMIT

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)

FILE: 5135A

TC: _____

SERIAL: № 17376 ☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 14317 EASTFIELD ROAD, HUNTERSVILLE, N.C. (STREET NO. / STREET) ② FILE: 5135-A

③ JURISDICTION: MECKLENBURG ④ TAX PARCEL NO.: 021-111-04 PO

⑤ SUBDIVISION: _____ ⑥ LOT: _____ ⑦ BLOCK: _____

OWNER

⑧ NAME: THOMAS (FIRST) RICHARD (MIDDLE) HUNTER (LAST)

⑨ MAILING ADDRESS: 14228 EASTFIELD ROAD

⑩ CITY: HUNTERSVILLE ⑪ STATE: N.C. ⑫ ZIP: 28078

⑬ PHONE: (WORK) ~~334~~ 334-9791 ⑭ (HOME) 875-2673

REQUEST

This request is for a(n):

⑮ ☒ New permit ⑰ ☐ Authorization for mobile home exchange

⑯ ☐ Repair or alteration permit ⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3 ㉕ Type? _____

㉓ Maximum occupancy? 4 ㉖ Maximum number of employees? _____

㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Thomas R. Hunter

Date: DECEMBER 15, 1988

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void 36 months from the date of issuance.

Agreement form on file.

Environmentalist _____ Date _____

Director or Authorized Section Head [signature] Date 12-6-88

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.

TO: ENVIRONMENTAL HEALTH DEPT.
BUILDING STANDARDS DEPT.
DEPT. OF ENVIRONMENTAL PROTECTION/
SOLID AND HAZARDOUS WASTE

DATE 12/14/88

FROM: COUNTY ENGINEERING DEPARTMENT

EHD FILE _____ JURISDICTION CODE Meck

PARCEL NUMBER 021-111-04p0

ASSIGNED ADDRESS 14317 Eastfield Rd

EXISTING ADDRESS _____

PROJECT NAME N/A

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

		APPROVED	DISAPPROVED
1.	SUBDIVISION REGULATIONS	/ /	/ /*
2.	FLOODWAY REGULATIONS	/ /	/ /*
3.	EROSION CONTROL REGULATIONS	/ /	/ /*
4.	PUBLIC UTILITY EASEMENT	/ /	/ /*
		PRESENT	NOT PRESENT
5.	PUBLIC UTILITY EASEMENT	/ /*	/✓/
6.	PROPERTY FRONTS ON THOROUGHFARE	/✓/*	/ /
7.	DRIVEWAY PERMIT REQUIRED	/✓/*	/ /

*If checked, further investigation will be required to determine whether a building permit can be issued by Building Standards for the site.

REMARKS: Septic Tank

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIER'S OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: Dzi

OPWEAR 06-88

NEW ADDRESS /✓/*

FORM 100

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

November 15th, 1988

Robert Martin Wallace
14329 Eastfield Road
Huntersville, NC 28078

RE: Property located at Eastfield Road
FILE: 5135A
PARCEL: 02111104 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The results of this investigation showed the property to be classified UNSUITABLE for the installation of such a system. A copy of the Site Evaluation Report (Serial Number 15730) is enclosed.

State regulations provide that sites originally classified unsuitable may be utilized for the installation of alternate or modified sewage disposal systems provided the requirements of 10 NCAC 10A .1948 (c) are met. A reprint of this section is enclosed for your information.

Should you desire to file for permission to install an alternate or modified sewage treatment system on the property, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. They will be reviewed, and if it is determined that the proposed system may reasonably be expected to function satisfactorily, an Improvement Permit will be issued by the Department upon completion by you, of a formal request for lot reclassification.

If I may be of any assistance, please feel free to call.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure (2)

Environmental Health Division
1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 15730

File: 5135A

Parcel: 02111104 PO

Action 2

☐ PC

Location: Eastfield Road

Subdivision:


Lot: Block: Acres: 1.0

Owner: Robert Martin Wallace
Address: 14329 Eastfield Road
Huntersville, NC 28078

Comments: _____

Described by: William A. Marsh

Date: 11-15-96



East Field Rd

***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 6-15%	S PS U —	S (PS) U 15-30%	S PS U	S PS U	S PS U
Texture	S (PS) U clay	S PS U —	S PS (U) 2-1 clay	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U —	S (PS) U Blocky	S PS U	S PS U	S PS U
Drainage	S (PS) U >36" To water	S PS U —	S (PS) U 36" To water	S PS U	S PS U	S PS U
Depth	S PS (U) 24-28"	S PS U —	S PS (U) 30-36"	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >36"	S PS U —	S (PS) ~~U~~ >36"	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S (PS) U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS (U) Filled gully	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	1UA Pacolet-Lilo	Filled	1UB Mecklenburg-Lilo			
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

RECEIVED
MECKLENBURG COUNTY
HEALTH DEPT.
OCT 21 1988
ENVIRONMENTAL HEALTH
DIVISION

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 5135A

TC: 021-111-04PO

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 14329 EASTFIELD, RD. HUNTERSVILLE, N.C. 28078

② SUBDIVISION: _____ ③ LOT: _____ ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO. P03737 PAGE NO.: 0813 PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: P03737 PAGE NO.: 0813

OWNER

⑦ NAME: ROBERT (M. WALLACE) MARTIN WALLACE
(FIRST) (MIDDLE) (LAST)


⑧ MAILING ADDRESS: 14329 EASTFIELD, RD.

⑨ CITY: HUNTERSVILLE ⑩ STATE: N.C. ⑪ ZIP: 28078

⑫ PHONE: (WORK) 875-6720 (HOME) _____

⑬ Accurately diagram and dimension lot.

14329 Eastfield Rd. HUNTERSVILLE, N.C. 28078



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Robert M. Wallace

Date: Oct 21, 88

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date 10/24/88

Name/Company Robert Wallace

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: Soil Test
#5135A

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
OCT 24 1988

Fee: $30 —

Completed by

Collected by