Date Received

MECK COUNTY HEALTH DEPT.
RECEIVED
JUN 2 1972
ENVIRONMENTAL HEALTH DIVISION


ICAR(S) Application No. 6538
T. C. No. 049-063-04
Map Date 9-1-70

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ___ Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms 3
5) Business Use — Max No Employees
6) Washing Machine 1 Yes ___ No
7) Garbage Disposal ___ Yes ___ No
8) Dishwasher ___ Yes ___ No
9) Water Supply
A) Individual Well Y
B) Governmental System
C) Community System
1 Well source
2 Governmental source
10) Sewage System
House located within 200 feet of public sewer ___ Yes ___ No
House located within 200 feet of community sewer ___ Yes ___ No
11) FHA Case No
12) VA Case No.

13) NAME OF OWNER Smith (LAST) Billy (FIRST) D (MIDDLE)
14) ADDRESS OF OWNER 2226 Billy Graham Pkwy
15) PHONE NO Home 596-6672 Office 523-4046
16) LOCATION OF SYSTEM Billy Graham Pkwy (STREET OR COUNTY ROAD) Mt. Holly
17) SUBDIVISION Pendleton Est Lot No. 54 Block No.
Map Book No 7 Page No. 377-3-4
18) DEED REFERENCE — DEED BOOK 1564 AT PAGE 48
19) HAS A PERCOLATION TEST BEEN RUN? Y YES ___ NO DATE RUN 1956
20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

June 26, 1972
DATE OF APPLICATION

Billy Graham
OWNER

FORM NO. E-4 4-[illegible]

HEALTH DEPARTMENT'S COPY

Date Issued 5 July 73 Serial No. 3982 ICAR(S) Permit No. 6538

T. C. No. 049-063-04

Map Date 9-1-70


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 6538 dated 26 June 73 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 5 Aug 73, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate ✓

Liquid Capacity of Tank ✓

Tank Construction ✓

Absorption and/or Nitrification Lines.

Total Line Lenght 100 ft

Number of Lines (2) 5'X50'

Distance from House 10'+

Distance from Property Line 10'

Distance from Well 50'

NAME OF OWNER Sawyer, Kelsye B.

LOCATION OF PROPERTY 6226 King George Dr.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: Check Tank & box for breaks or leaks
Tye new line into distribution box

Division or Section Head ___

R. M. Reynolds
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO. E 5-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 10 July 73 Serial No. 3635

C of A (s) No. 6538

T. C. No. 049-063-04

Map Date 9-1-70

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Sawyer, Kelaye B. (LAST, FIRST, MIDDLE)

Location of Property 6226 King George Dr.

Application Number 6538 Permit Number 6538

Inspection Data:

Liquid Capacity of Tank — Tank Material —

Total Length of Drain Tile 100 e/ft Number of Lines (2) 5'x50'

Depth of Filter Material 17" Cover Depth 24"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 10 July 73 (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 10 July 73 (DATE)

Washing Machine Line Inspected, If Applicable 10 July 73 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments.

R. M. Reynolds
Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY