Date Received 3-20-84

RECEIVED MAR 20 1984 ENVIRONMENTAL HEALTH

ICAR (S) Application No. 20810

T. C. No. 109-121-13


Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) _ _ Install or Construct 2) X Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home _ Yes _ No
Residence X Yes _ No

4. No of Bedrooms 3
5. Business Use - Max No Employees _
6. Washing Machine X Yes _ No
7. Garbage Disposal _ Yes X No
8. Dishwasher X Yes _ No
9. Water Supply
   A. Individual Well X
   B. Governmental System _
   C. Community System
      1 Well source _
      2 Governmental source _
10. Sewage System
    House located within 200 feet of public sewer _ Yes X No
    House located within 200 feet of community sewer _ Yes X No
11. FHA Case No _
12. VA Case No. _

13) NAME OF OWNER WINCK (LAST) RONALD (FIRST) C (MIDDLE)

14) ADDRESS OF OWNER 5934 KINGHURST Dr. CHARLOTTE NC

15) PHONE NO. Home 535-2XE Office 372-5351 CHARLOTTE

16) LOCATION OF SYSTEM _ (STREET OR COUNTY ROAD)

17) SUBDIVISION KINGHURST PARK Lot No. 11 Block No. 12

Map Book No. 5 Page No. 35

18) DEED REFERENCE — DEED BOOK 4362 AT PAGE 216

19) HAS A SOIL INVESTIGATION BEEN RUN? X YES _ NO DATE RUN _

20) PTR NUMBER (See Instructions) _

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

3-19-84
DATE OF APPLICATION

Ronald C Winck
OWNER

EHD-5-76

Environmental Health Department's Copy

Date Issued 3-20-84

Serial No. 07061


ICAR(S) Permit No. 20810

T. C No. 109-121-13

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ____ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 20810, dated 3-14-84 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before APRIL 3RD 1984, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate U RB

Liquid Capacity of Tank ____

Tank Construction Repair

Absorption and/or Nitrification Lines:

Total Line Length 100 LIN FT

Number of Lines Three

Distance from House 50 FT

Distance from Property Line 10 FT

Distance from Well 60 FT

NAME OF OWNER WINCHER, RONALD

LOCATION OF PROPERTY 5934 KINGHURST DR.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Three Trenches To be 34FT X 3FT X 18 inches STONE - hay or straw COVER - use DIST BOX, IF NEEDED

Division or Section Head

Ralph Nobles
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

C of A (s) No. 20810

Date Issued 5-17-84 **Serial** 6634 T. C. No 109-121-13 L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner WINCHEK (LAST), RONALD (FIRST) _____ (MIDDLE)

Location of Property 5934 KINGHURST DR.

Application Number 20810 Permit Number 20810

Inspection Data:

Liquid Capacity of Tank Repair Tank Material Repair

Total Length of Drain Tile 100 Lin. FT Number of Lines Three

Depth of Filter Material 18 Inches Cover Depth 18 to 24 inches

Water Supply Source City Distance from Water Source City.

Excavation Inspected 5-17-84 (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 5-17-84 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, ~~altered or~~ repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments _____

Ralph Nelles
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY