CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 21812 DATE: 8-20-87

TC: 001-061-33 ☑ L ☐ CRT

SERIAL № 10481

Name of Owner CAROLINA ASSOCIATES Juris.:

Address of Property 19319 STATESMAN DR

Inspection Data:

Tank Material PCC

Total Length of Drainfield 400

Number of Lines 4 @ 100

Cover Depth 2'

Water Supply Source well

Distance to Water Source 600'

Excavation Inspected 8.19.87

Tank(s) Inspected 8.19.87

Wash Line Inspected

High Water Alarm Inspected

PLOT

Design: 1987, 600 GPD | LOADING | 2½ DEEP CTR# 87-0412

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☑ installed or constructed ☐ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☑ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 1 CAN'T SEE WATER

Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603
Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: [redacted] 2181[illegible]
TC: [redacted]
SERIAL: № 12082

RECEIVED
DEC 31 1986
ENVIRONMENTAL HEALTH
☑ PC ☐ CRT

JOB LOCATION

① ADDRESS: 19314 (STREET NO) Yachtman Dr. (STREET) ② FILE: 21812
③ JURISDICTION: ④ TAX PARCEL NO.: 001-061-33
⑤ SUBDIVISION: Yachtman Shores ⑥ LOT: 10 ⑦ BLOCK:

OWNER

⑧ NAME: Carolina Associates (FIRST) (MIDDLE) (LAST)
⑨ MAILING ADDRESS: Rt 1, Box 39
⑩ CITY: Mooresville, [illegible] ⑪ STATE: NC ⑫ ZIP: 28115
⑬ PHONE: (WORK) 892-5158, 892-7991 ⑭ (HOME)

REQUEST

This request is for a(n):

⑮ ☒ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3 ㉕ Type?
㉓ Maximum occupancy? 6 ㉖ Maximum number of employees?
㉔ Basement? ☐ yes ☒ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Edward Plank
Date: 12/26/86

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

B.A. Jayroe — Environmentalist — 1-7-87 (Date)
J.D. Daniel — Director or Authorized Section Head — 1-8-87 (Date)

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21612

T.C. NO. PO 001-001-0016 11,15

(Ground Absorption Sewage Disposal)

OWNER: Reginald Russell Ward
ADDRESS: P. O. Box 4
Davidson, N.C. 28036

PLAT NO: Lot A11
LOT SIZE: 2.6 Ac

LOCATION OF SITE: Northern side of Mantz Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) U — 2 to 12	S PS U — complex slopes	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) U — clay	S (PS) U — clay	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) U — blocky	S (PS) U — blocky	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS U — 24-30"	S PS U — 24"	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) U — 24"	S (PS) U — 24"	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) U — 24" to gravel layer	S (PS) U — Areas may collect water	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	II A	II A		
9. SITE CLASSIFICATION	Provisionally suitable	unsuitable		
10. SOIL SERIES	Cecil Clay	Tarrus and Davidson Clay		

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William H. Martin
Title: Soil Scientist

Date: 2-20-85

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA



PROPOSED PLOT PLAN

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·


1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

MECK COUNTY DEPARTMENT OF
RECEIVED
DEC 31 1986
ENVIRONMENTAL HEALTH

FILE: 21812

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: [signature] Edward Harrell

Date: 12/26/86

Serial No. 6101

SIR No. 21812

T. C. No. PO 001-061,09,10,11, 15

Date Issued 2-20-85

Map Date L


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Knox, (LAST) Russell (FIRST) B. (MIDDLE)
Knox, Bobby B.

ADDRESS OF OWNER P. O. Box 4, Davidson, NC ZIP 28036

LOCATION OF PROPERTY Nantz Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. 10 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. The permeability rate determined by the investigation was PROVISIONALLY SUITABLE. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction or building on the wastewater treatment system on the said lot.
2. The size of the septic tank, absorption system and the specific installation shall be determined by the Mecklenburg County Department of Environmental Health in accordance with the permeability rate obtained above, and on the size and type of building to be served.
3. This approval is valid only for the system, installation and location as acceptable for system installation on the above plot.
4. This approval does not apply to any proposed lot alteration, including but not limited to the removal of which, in the opinion of the Mecklenburg County Department of Environmental Health, would render the lot unacceptable as acceptable for system installation. This approval does not apply to any proposed system or component of such a system.

This approval is given pursuant to the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William P. Waller
Soil Scientist

Brice D. Vanderbilt Jr.
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

Date Received 1-15-85

SIR No. 21812

T. & M. No. 001-061-9-10-11-15

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Knox (LAST) Russell (FIRST) B (MIDDLE) Knox Bobby B

2) ADDRESS OF OWNER P.O. Box 4 Davidson NC ZIP 28036

3) PHONE NO. Home 892-0248 Office 892-0196


4) LOCATION OF PROPERTY Nantz Rd off Hwy 73 (STREET OR COUNTY ROAD)

5) SUBDIVISION Yachtmen Shores LOT NO. 10 BLOCK NO.

MAP BOOK NO. PAGE NO.

6) DEED REFERENCE: DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Bobby B Knox
OWNER

END-5-76

Environmental Health Department's Copy