Date Received 10-13-83

RECEIVED
OCT 13 1983
ENVIRONMENTAL HEALTH

SEE INSTRUCTIONS ON BACK

ICAR(S) Application No. 20118

T. C. No 011-181-03

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) _____ Install or Construct 2) X Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____Yes ____No
Residence ↘ Yes ____No
4) No of Bedrooms ↘ 3
5) Business Use — Max No Employees _____
6) Washing Machine ↘ Yes ____No
7) Garbage Disposal ↘ Yes ____No
8) Dishwasher ____Yes ____No
9) Water Supply
A) Individual Well ↘
B) Governmental System _____
C) Community System
1 Well source _____
2 Governmental source _____
10) Sewage System
House located within 200 feet of public sewer ____Yes ____No
House located within 250 feet of community sewer ____Yes ____No
11) FHA Case No _____
12) VA Case No _____

13) NAME OF OWNER OSBORNE (LAST) GEORGE & MARIE (FIRST, MIDDLE)

14) ADDRESS OF OWNER RT. 2 BOX 61, HUNTERSVILLE

15) PHONE NO. Home 875-6646 Office 394-3361 (MRS)

16) LOCATION OF SYSTEM RAMAH CHURCH ROAD (STREET OR COUNTY ROAD)

17) SUBDIVISION _____ Lot No. _____ Block No. _____

Map Book No. _____ Page No. _____ BOOK PAGE LOT

18) DEED REFERENCE — DEED BOOK 1775-195 AT PAGE 195 011 181 03

19) HAS A SOIL INVESTIGATION BEEN RUN? ↘ 1955 YES ____ NO DATE RUN 1955

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

10-11-83
DATE OF APPLICATION

George L. Osborne
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 10-19-83 Serial No. 6710 ICAR(S) Permit No 20118

T C No 011-181-03

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified hereon at the described location. This permit is granted based upon the information supplied on application 20118, dated 10-11-83, and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 12-15-83, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate: Repair

Liquid Capacity of Tank: 1500 gal

Tank Construction: p/c concrete

Absorption Area Information:

Total Line Length: 100'

Number of Lines: 1

Distance from House: 5' +

Distance from Property Line: 10' +

Distance to Well: 50' +

Ramah Church

NAME OF OWNER: George + Marie Osborne

LOCATION OF PROPERTY: Ramah Church Rd.

The system shall meet all of the construction requirements set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered inspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will function properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: Pump - break in top + backfill existing tank - set new tand approx 30' from house to allow for addition - add 1-100' x 3' x 12" stone trench or in field

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

4

C of A (s) No. 2018

Date Issued 11-10-83 **Serial** 6277 T. C. No. 011-181-03

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Osborne (LAST) George (FIRST) (MIDDLE)

Location of Property Ranch Church Rd

Application Number 2018 Permit Number 2018

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material Pre-Cast Concrete

Total Length of Drain Tile 300 Number of Lines 3

Depth of Filter Material 12" Cover Depth 20 - 30"

Water Supply Source _____ Distance from Water Source 100'

Excavation Inspected _____ (DATE) Tank Inspected 11-18-83 (DATE)

Nitrification Field Inspected 11-10-83 (DATE)

Washing Machine Line Inspected, If Applicable N A (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Complete New System



W. B. Ramsey
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY