Date Received 5-27-82

RECEIVED
MAY 27 1982
ENVIRONMENTAL HEALTH

APT No. 18751
p.o.
T. C. No. 031-201-04
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER McClure Realty Co., Inc.
(LAST) (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 10104 Highway 16 West, Charlotte,NC ZIP 28208

3) PHONE NO Home _____ Office 394-4311


4) LOCATION OF PROPERTY Hart Road (S.R. #2200)
(STREET OR COUNTY ROAD)

5) SUBDIVISION ---- LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a site investigation and on-site inspection of the proposed described for the purpose of determining if the site is suitable for the installation of a conventional subsurface sewage disposal system with a septic tank and absorption effluent disposal.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Don McClure
OWNER

ENC-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ABSORPTION,
EFFLUENT DISCHARGE

S.I.R. # 18751

T.C. # PO 031-201-04

DATE June 4, 1982

NAME OF OWNER McClure Realty Company, Inc.

ADDRESS OF OWNER 10104 Highway 16 West, Charlotte, N. C. 28208

LOCATION OF LOT Hart Road (S.R. #2200)

As determined under the Rules and Regulations promulgated by the Commission for Health Services, Division of Health Services, North Carolina Department of Human Resources, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank - soil absorption system, due to the following reason:

SOIL TEXTURE - 2 to 1 Clay

SOIL DRAINAGE/GROUNDWATER - Seasonal perched water table

SOIL PERMEABILITY - Very Slow

Michael A. Sextor, Environmentalist
On Premises Waste Disposal Section

NORTH CAROLINA
DEPARTMENT OF HUMAN
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

S.I.R. NO. 18751
T.C. NO. PD 131-20124

(Ground Absorption Sewage Disposal)

OWNER: McClure Realty Co., Inc.
ADDRESS: 10924 Hwy 16 N.
COUNTY: Gaston, N.C.
LOCATION OF SITE: West Bel

DATE REQUESTED:
PLAT NO:
LOT SIZE: 20,000

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 2-8%	(S) PS U 2-8%	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2:1 Clay)	S PS 2-1 U (Clay)	S PS 2-1 U (Clay)	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S (PS) Blocky U	S PS U	S PS U
4. SOIL DEPTH (inches)	(S) PS 48" U	(S) PS 48" U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	(S) None PS U	(S) None PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) 7-6' ft ground water PS U	S Seasonal perched water table (U)	S PS U	S PS U
7. SOIL PERMEABILITY (Percolation rate)	S Slow PS Very U (Slow)	S Very PS U (Slow)	S PS U	S PS U
8. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
9. SITE CLASSIFICATION	Unsuitable	unsuitable		
10. SOIL SERIES	Enon	Helena		


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope)

Recommendations/Comments:

Described By: William R. Marlow
Title: Soil Scientist
Date: 1-2-82

DHS Form 2601
Sanitation
EHD 539 (3/82)


80'
Helena
260'
260'
Ewen
Honi Rd.
80'