C of A (s) No. 4070

Date Issued 20 Sept 79 Serial 3061

T C No 195-053-01

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION

~~CERTIFICATE OF COMPLETION~~

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Helms (LAST) W (FIRST) H. (MIDDLE)

Location of Property 2456 Shelbourne

Application Number _____ Permit Number 4070

Inspection Date:

Liquid Capacity of Tank 1500 gal Tank Material P.C. Conc.

Total Length of Drain Tile 660' ; 167' Number of Lines (4 ; 4) ; (4)

Depth of Filter Material 12" Cover Depth 15"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected — (DATE) Tank Inspected 20 Sept (DATE)

Nitrification Field Inspected 20 Sept (DATE)

Washing Machine Line Inspected If Applicable 20 Sept (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments _____

_____

_____

_____

_____

Environmentalist

EHD-5-76

Environmental Health Department's Copy

Serial 3157

ICAR(S) Permit No. 4070


Date Issued 20 September 1979

T. C. No. 195-053-01

Map Date 5-9-78

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, _ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 4070, dated _ and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 10 Oct 1979, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate ρ. avg

Liquid Capacity of Tank 1500 gal

Tank Construction pre cast

Absorption and/or Nitrification Lines

Total Line Length 660 ℓ/165

2 beds

Number of Lines 4 ℓ 4

Distance from House 10'

Distance from Property Line 20' ±

Distance from Well 50' ±

NAME OF OWNER Helms W. H.

LOCATION OF PROPERTY Lawyers & Shebourne

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning or installing or using such system from any liability resulting from the failure of the system to operate properly.

two bed 12x83x17" stone

wash line in bed 12x42x17" stone

John R. Atkisson

Division or Section Head

Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy