

7000 OLD STATESVILLE RD

04305225

5/8/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3678-A DATE: 7-9-87

TC: 043-052-25 ☐ L ☐ CRT

SERIAL № 10372

Name of Owner William Benninger Juris.:

Address of Property 7000 Old Statesville Rd

Inspection Data:

Tank Material repair/septic

Total Length of Drainfield 200'

Number of Lines 4 @ 50'

Cover Depth 12"

Water Supply Source city

Distance to Water Source —

Excavation Inspected 7-9-87

Tank(s) Inspected

Wash Line Inspected 7-9-87

High Water Alarm Inspected

PLOT

Design: 1987 - septic repair CTR# 16

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☑ altered or repaired

☑ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☑ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS:

B. R. Ferguson
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3678-A DATE: 7-7-87

TC: 043-052-25 ☐ L

SERIAL № 11078

Permission is hereby given to ____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 6-29-87. All work shall be completed on or before 8-1-87, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank repair/septic gallons

Liquid Capacity of Dosing Tank ____ gallons

Tank Construction ____

Absorption and/or Nitrification Lines:

Trench Width 12 feet

Total Line Length 200 feet

Number of Lines 4

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10 feet

Distance from Well city feet

NAME OF OWNER William Pennington

LOCATION OF PROPERTY 7000 Old Statesville Rd

Comments: Used 12'X50'X12" stone, Connect wash pipe into septic tank

Division or Section Head

B.R. Ferguson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 3678A
TC:
SERIAL: Nº 13889

MECK COUNTY DEPARTMENT OF
RECEIVED
JUL 1 1987
ENVIRONMENTAL HEALTH

☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 7000 (STREET NO.) Old Statesville Rd. (STREET) ② FILE:

③ JURISDICTION: ④ TAX PARCEL NO.: 043-052-25

⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: [redacted] (FIRST) William (MIDDLE) Ferris (LAST) Pennington

⑨ MAILING ADDRESS: 7930 Brown Rd.

⑩ CITY: Charlotte ⑪ STATE: N.C. ⑫ ZIP: 28213

⑬ PHONE: (WORK) ⑭ (HOME) 5965806

REQUEST

This request is for a(n):

⑮ ☐ New permit

⑯ ☒ Repair or alteration permit

⑰ ☐ Authorization for mobile home exchange

⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home

㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 3

㉕ Type?

㉓ Maximum occupancy? 5

㉖ Maximum number of employees?

㉔ Basement? ☐ yes ☒ no

㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☐ Individual well

B ☒ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: W.F. Pennington

Date: 6-29-87

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

Environmentalist / Date

Director or Authorized Section Head / Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.