

300 FEATHERSTONE DR

04911115

5/24/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

Mecklenburg County
Health Department

Basil G. Belta, M.D., M.P.H.
Health Director

September 13th, 1988

Tom Hantzos
1311 Shady Bluff Drive
Charlotte, NC 28211

RE: Property located at Featherstone Drive
FILE: 4911A
PARCEL: 04911110 Po

Dear Sir:

At your request a soils investigation was conducted on the property designated above. Results of this investigation showed the site to be classified as UNSUITABLE under criteria as set forth in Section .1900 of the North Carolina Administrative Code, Title 10, Department of Human Resources, Chapter 10, Division of Health Services; Sanitary Engineering Section, Subchapter 10A, Sanitation. A copy of the Site Evaluation Report (Serial Number 11888) is enclosed.

The soil on this property is not suitable for use with any conventional, modified or alternative system of which I am aware.

If I can be of assistance, please do not hesitate to call.

Very truly yours,

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 11888

File: 4911A Action 3

Parcel: PO 049-111-10 ☐ PC

Location: Featherstone Drive

Subdivision:


Lot: Block: Acres: 1.5

Owner: Tom Hantzos
Address: 1311 Shady Bluff Drive
Charlotte, N. C. 28211

Comments: _____

Described by: William R. Medlin

Date: 6-24-96



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-10-2	S PS U —	(S) PS U 2-8%	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U —	S PS (U) 2-1 Clay	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS (U) Compacted	S (PS) U Blocky	S PS U	S PS U	S PS U
Drainage	S (PS) U 736" To water	S PS U —	S PS (U) Perched water 24"	S PS U	S PS U	S PS U
Depth	S (PS) (U) 24-30"	S PS U —	S (PS) U 36"+	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 736"	S PS U —	S (PS) U 736"	S PS U	S PS U	S PS U
Available Space	S PS (U) Restricted	S PS U	S (PS) U Limited	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IV A Pacolet-Lilo	Fill	IV B Helena-Fill			
Area Classification	S PS (U)	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
AUG 8 1988

20[illegible] BLVD
CHAR[illegible] 28213
PHONE [illegible]

OFFICE USE ONLY
491A
~~[illegible]~~
~~[illegible]~~
FILE
T[illegible] PC REPT

ADDRESS
B[illegible] ② DT ③ BLOCK
PAGE NO PARCEL NO
DEED REFERENCE BOOK PAGE NO

OWNER
NAME FIRST LAST
MAILING ADDRESS
CITY STATE ZIP
TELEPHONE NO HOME

[illegible]

I, the undersigned, [illegible] and the foregoing application [illegible] MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL [illegible] this request.

Signature

[illegible]