Date Received 8/-83

RECEIVED on BACK
AUG 1 1983
ENVIRONMENTAL HEALTH

ICAR(S) Application No. 19916

T. C. No. 211-151-04


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ____ Install or Construct 2) Repair Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____Yes ____No
Residence X Yes ____No
4) No of Bedrooms 2
5) Business Use — Max No Employees ____
6) Washing Machine ____Yes X No
7) Garbage Disposal ____Yes X No
8) Dishwasher ____Yes X No
9) Water Supply
A) Individual Well X
B) Governmental System ____
C) Community System
1. Well source ____
2 Governmental source ____
10) Sewage System
House located within 200 feet of public sewer ____Yes ____No
House located within 200 feet of community sewer ____Yes ____No
11) FHA Case No ____
12) VA Case No ____

13) NAME OF OWNER Moore (LAST) Joseph (FIRST) Erskine (MIDDLE)

14) ADDRESS OF OWNER 2915 Caribou Rd - Charlotte - 28226

15) PHONE NO. Home 542-7546 Office ____

16) LOCATION OF SYSTEM First Ave - 2913 Caribou Rd. (STREET OR COUNTY ROAD)

17) SUBDIVISION ____ Lot No. ____ Block No. ____

Map Book No. ____ Page No. ____

18) DEED REFERENCE — DEED BOOK ____ AT PAGE ____

19) HAS A SOIL INVESTIGATION BEEN RUN? Yes YES ____ NO DATE RUN 7-27-83 for Supplee

20) PTR NUMBER (See Instructions) ____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

7-28-1983
DATE OF APPLICATION

Joseph E. Moore
OWNER Joseph E. Moore

BHD-S-20

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Date Issued 8-1 1983

Serial No. 6463


ICAR (S) Permit No. 19916

T C No 211-151-04

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19916, dated 7-28-83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before Aug 15th 1983, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate PS IV4

Liquid Capacity of Tank Repair

Tank Construction Repair

Absorption Trench or Nitrification Lines:

Total Line Length 300 LIN FT

Number of Lines FOUR

Distance from House 15 FT.

Distance from Property Line 50 FT.

Distance from Well 55 FT.

NAME OF OWNER MOORE JOSEPH

LOCATION OF PROPERTY 2901 CARMEL ROAD

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

Comments: FOUR Trenches to be 75 FT x 3FT x 12 inches stone key system Cover - guards Bds - no washmachine - new DIST Box USE SCHEDULE 40 Between Tank & DIST Box Cut off old drain field

Division or Section Head

Ralph Miller
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

BHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

C of A (s) No. 1991[illegible]

T. C. No 211-151-04

Date Issued 8-22-83 Serial 6048

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner MOORE (LAST) JOSEPH (FIRST) (MIDDLE)

Location of Property 2901 CARMEL ROAD

Application Number 19916 Permit Number 19916

Inspection Data:

Liquid Capacity of Tank Repair Tank Material Repair

Total Length of Drain Tile 300 lin. FT, Number of Lines FOUR

Depth of Filter Material 12 inches Cover Depth 12 inches

Water Supply Source Well Distance from Water Source 55 FT

Excavation Inspected 8-22-83 (DATE) Tank Inspected 8-22-83 (DATE)

Nitrification Field Inspected 8-22-83 (DATE)

Washing Machine Line Inspected, If Applicable ——— (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ——— installed or constructed, X altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under Comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Ralph Miller
Environmentalist

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

EHD-S-76

C of A (s) No. 19916

Date Issued 8-22-83 Serial 6048 T C No 211-151-04

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner MOORE (LAST) , JOSEPH (FIRST) (MIDDLE)

Location of Property 2901 CARMEL ROAD

Application Number 19916 Permit Number 19916

Inspection Data:

Liquid Capacity of Tank Repair. Tank Material Repair

Total Length of Drain Tile 300 lin.FT, Number of Lines FOUR

Depth of Filter Material 12 inches Cover Depth 12 inches

Water Supply Source well Distance from Water Source 55 FT

Excavation Inspected 8-22-83 (DATE) Tank Inspected 8-22-83 (DATE)

Nitrification Field Inspected 8-22-83 (DATE)

Washing Machine Line Inspected, If Applicable ____ (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ____ installed or constructed, X altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Ralph Miller
Environmentalist

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY