[redacted]

2990A Trails End
Lot 1

CERTIFICATE OF COMPLETION/OPERATION PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2990-A DATE: 8-3-87
TC: 019-171-04 ☐ L ☑ CRT
SERIAL № 10488

Name of Owner GODWIN TERRY Juris.:
Address of Property 11501 TRAILS END LN

Inspection Data:

Tank Material PCC
Total Length of Drainfield 400
Number of Lines 4 @ 100
Cover Depth 1-2'
Water Supply Source well
Distance to Water Source 50'+
Excavation Inspected 8-3-87
Tank(s) Inspected 8-3-87
Wash Line Inspected —
High Water Alarm Inspected 8-3-87

PLOT

Design: 1987 1500 ST 1000 DT PI LIN 1200 FT 12" CTR#

The undersigned has inspected the Septic Tank System described above, and certifies it has been
☑ installed or constructed ☐ altered or repaired
☐ in accordance with the permit issued ☐ as detailed in the plot above
and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this
☐ Certificate of Completion ☑ Operation Permit
does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS:

Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

144

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2990 A DATE: 7-17-87

TC: 019-171-04 ☐ L

SERIAL Nº 11012

Permission is hereby given to ✓ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5-20-87. All work shall be completed on or before 8-17-87, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank 1000 gallons

Tank Construction PCC

Absorption and/or Nitrification Lines:

Trench Width 3' feet

Total Line Length 400' feet

Number of Lines 4

Depth of Stone 12 inches

Distance from House 5'+ feet

Distance from Property Line 10'+ feet

Distance from Well 50'+ feet

NAME OF OWNER GODWIN TERRY W

LOCATION OF PROPERTY 11501 TRAILS END LN

Comments: A line x 100' long x 3' wide x 12" rock

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 13723

File: 2990A
Parcel: 01917104 PO

Action: 4 / 1
JM
PC

Location: Trails End


Subdivision:

Lot: 1 Block: Acres: 1+

Owner: Edison B. Davis
Address: 6132 Lakeforest, East
Charlotte, NC 28212

Comments: Elevation problem

Described by: W. B. Ramsey
Date: 3-6-87



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-8	S (PS) U 2-6	S PS (U) Ditched	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS (U) Mixed Clay	S PS (U)	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS (U)	S PS (U)	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS (U)	S PS (U)	S PS U	S PS U	S PS U
Depth	S (PS) U 36-37"	S PS (U) 30-36	S PS (U) 10-30	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S (PS) U	S (PS) U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS (U)	S (PS) U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IIe Cecil	IIe a+b Cecil Helena Mix ed	IIe+b Cecil Helena			
Area Classification	S (PS) U	S PS (U)	S PS (U)	S PS U	S PS U	S PS U

PROPOSED PLOT PLAN

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·


1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 21 1987
ENVIRONMENTAL HEALTH

FILE: 2990A

TC: _____

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



SCALE 1" = 40'

Signed: Wayne Hodnett

Date: _____

MECKLENBURG COUNTY

Department of Environmental Health

May 20, 1987

Terry Wayne Godwin
4323 Hubbard Road
Charlotte, NC 28213

Dear Mr. Godwin:

Subject: Property located at 11501 Trails End Lane
File: 2990A

Receipt of the plans and specifications for a conventional system of sewage disposal proposed for installation at the above referenced property is hereby acknowledged. Upon receipt of the plan, a review was made of the material on file and a site evaluation was conducted. The plan was then reviewed in conjunction with provisions of 10 NCAC 10A .1900, "Laws and Rules for Sanitary Sewage Collection, Treatment and Disposal". Our comments are listed below:

1. The site appears insufficient in size to accommodate the proposed house plan, well, sewage disposal system, and a 100% repair area.

For these reasons, the plan as submitted is disapproved.

You may resubmit a plot plan if you desire. A minimum of 1200 square feet will be required for the sewage system installation and an additional 1200 square feet must be set aside for future repair area. The linear feet requirement would be 400 feet for the original system. It may be necessary to reduce or change the house plans to accommodate the sewage disposal needs.

If you have any questions regarding these matters, please do not hesitate to contact me.

Very truly yours,

B. R. Ferguson
Registered Sanitarian
On Premises Waste Disposal Section

BRF/ir

PROPOSED PLOT PLAN


MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 2990A

TC: 019-171-04

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



Signed: Wayne Hodum

Date: 5-20-87

dis-approved based
on topo. Not enough
again area

B. J.

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 2990A
TC:
SERIAL: № 11333

MECK COUNTY DEPARTMENT OF
RECEIVED
MAY 18 1987
ENVIRONMENTAL HEALTH

☐ L ☑ CRT

JOB LOCATION

① ADDRESS: 11501 (STREET NO) Trails End Lane (STREET) ② FILE:
③ JURISDICTION: ④ TAX PARCEL NO.: 019-171-04
⑤ SUBDIVISION: ⑥ LOT: ⑦ BLOCK:

OWNER

⑧ NAME: Terry (FIRST) Wayne (MIDDLE) Godwin (LAST)
⑨ MAILING ADDRESS: 4323 Hubbard Road
⑩ CITY: Charlotte N.C ⑪ STATE: N.C ⑫ ZIP: 28213
⑬ PHONE: (WORK) 596-4735 ⑭ (HOME) 597-9794

REQUEST

This request is for a(n):

⑮ ☑ New permit
⑯ ☐ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☐ Other (specify)

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home ㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3 ㉕ Type?
㉓ Maximum occupancy? 4 ㉖ Maximum number of employees?
㉔ Basement? ☐ yes ☑ no ㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☑ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Wayne Godwin
Date: 5-20-87

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

W. B. Ramsey — 5-27-87
Environmentalist — Date

S. E. Arnold — 5-28-87
Director or Authorized Section Head — Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid

MECKLENBURG COUNTY
Department of Environmental Health

March 11th, 1987

Edison B. Davis
6132 Lakeforest, East
Charlotte, NC 28212

RE: Property located at Trails End 1
FILE: 2990A
PARCEL: 01917104 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 13723) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

Enclosure

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 2990A

TC: 019-171-04PO

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 11501 Trails End

② SUBDIVISION: N/A ③ LOT: 04 ④ BLOCK: N/A

⑤ PARCEL REFERENCE: BOOK NO.: PO 019 PAGE NO.: 171 PARCEL NO.:

⑥ DEED REFERENCE: BOOK NO.: 2153181 PAGE NO.:

OWNER


⑦ NAME: Edison (FIRST) B (MIDDLE) Davis (LAST)

⑧ MAILING ADDRESS: 6132 Lakeforest East

⑨ CITY: Charlotte ⑩ STATE: NC ⑪ ZIP: 28212

⑫ PHONE: (WORK) (HOME) 537-4379

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: E B Davis

Date: 2-23-87

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY