Date Received 11-29-73

RECEIVED
NOV 30 1973
MECK. COUNTY ENVIRONMENTAL HEALTH DIVISION

Application No 7276

T C No 055-331-11


Map Date 9-1-70

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) ___ Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedrooms 3

5) Business Use Max No Employees ___

6) Washing Machine ✓ Yes ___ No

7) Garbage Disposal ___ Yes ✓ No

8) Dishwasher ___ Yes ✓ No

9) Water Supply
- A) Individual Well ✓
- B) Governmental System ___
- C) Community System ___
  - 1 Well source ___
  - 2 Governmental Source ___

10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No

11) FHA Case No ___

12) VA Case No ___

13) NAME OF OWNER BYRUM (LAST) LESTER (FIRST) WILSON (MIDDLE)

14) ADDRESS OF OWNER 2627 PARK LANE, CHARLOTTE, N.C 28214

15) PHONE NO. Home 399-3363 Office 399-3539

16) LOCATION OF SYSTEM 2627 PARK LANE (STREET OR COUNTY ROAD) ___

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No. ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 2732 AT PAGE 423

19) HAS A PERCOLATION TEST BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

11-29-73
DATE OF APPLICATION

Lester Wilson Byrum
OWNER

FORM NO E-4-8-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 4706

ICAR(S) Permit No. 7276

Date Issued 6/7/73

T. C. No. _____

Map Date _____


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to __ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 12 [illegible] dated [illegible] 3 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 11/26/73, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate 3 Eg 111

Liquid Capacity of Tank 1,1

Tank Construction 11

Absorption and/or Nitrification Lines.

Total Line Lenght 150'

Number of Lines 3 @ 50' x 17"

Distance from House 15' E

Distance from Property Line 10' min.

Distance from Well 50' min.

NAME OF OWNER [illegible] BYRUM

LOCATION OF PROPERTY 2227 JACK LANE

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: [illegible] 10' x 38[illegible]' x 17"

[illegible] 3' x 17"

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO. E-5-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 12/13/73 Serial 4294

C of A (s) No. 7276

T. C. No. 055-331-11

Map Date 9/1/70

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner BYRUM (LAST) LESTER (FIRST) W. (MIDDLE)

Location of Property 2627 PARK LANE

Application Number RE PA Permit Number 2627

Inspection Data:

Liquid Capacity of Tank —

Tank Material —

Total Length of Drain Tile 136 sq *

Number of Lines 5 (@ 11'x 30'x 17")

Depth of Filter Material 17"

Cover Depth 20"

Water Supply Source IND WELL

Distance from Water Source 60'+

Excavation Inspected 12/13/73 (DATE)

Tank Inspected — (DATE)

Nitrification Field Inspected 12/13/73 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been _____ installed or constructed, X altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: * LAYOUT & PERMIT SPECIFIED 150 linear ft drain. OR 375 sq ft x 17" deep; Installation consisted of 136 linear ft. OR 330 sq ft x 17" deep

Jeffler-

L R Buckman

Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY