

1600 THOMPSON AV

03702420

1/3/2008

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

N. C. Department of Environment, Health, and Natural Resources/Division of Environmental Health

ON-SITE WASTEWATER VIOLATION NOTICE

OWNER Robert Coleman

MAILING ADDRESS 1600 Thompson Ave. Charlotte, NC 28216

OCCUPANT same

LOCATION 1600 Thompson Ave.

[X] RESIDENCE [ ] BUSINESS [ ] OTHER Tax Parcel: 037-024-20

You are hereby notified that you are violating the Rules adopted by the North Carolina Commission for Health Services or Article 11 of Chapter 130A of the General Statutes of North Carolina by owning or controlling a residence, place of business, or place of public assembly which is not provided with an approved wastewater system. Your wastewater system is not in compliance; the following corrections must be made. Consult your Local Health Department for advice and required permits by calling telephone number 336-5569/336-5102.

[X] Install/Repair wastewater system. You must obtain an Improvement Permit from the local health department prior to repairing your system.

[ ] Eliminate wastewater discharge and connect to an approved wastewater system.

[ ] Pit Privy must be repaired/constructed.

[X] Other Repairs (*specify*) ~~Connect to C.M.U.D. sewer~~ line. Submit copy of tap-on fee receipt to ~~local Health Dept.~~

[X] Perform Maintenance (*specify*) Pump tank as necessary.

If the wastewater violation is not brought into compliance by July 17, 1995, appropriate legal action will be taken.

Notice Issued June 15, 1995 (Date) Signed Susan Bateman, R.S. (Agent) Division of Environmental Health

Compliance (Date) Signed (Agent) Division of Environmental Health

DEHNR 1108 (Revised 9/92)
On-Site Wastewater Section (Review 10/94)

7-7-95 Mr Coleman + Father called/visited Mother's office between lunch & 1-2 pm. Explained situation. Will make appt in next 1-2 weeks to get it done. Check on.

7/3

8-8-95 site visit malfunction problem appears to be corrected from maintenance work done by homeowner.

7-24-95 Inspection has not appeared to be malfunctioning.

4400

3614B

INDIVIDUAL WATER AND WASTEWATER SYSTEMS PROGRAM
APPLICATION FOR SERVICES

"Repair" II

☐ CRT

Mecklenburg County Health Dept.
Environmental Health Division
c/o Hal Marshall Ctr., Suite 211
700 N. Tryon St.
Charlotte, NC 28202

(704)336-5102

PERSON FILING APPLICATION:
X NAME: Coleman (last) Jackie (first) N. (mi)
ADDRESS: 1600 Thompson Ave PHONE: (704) 399-3526
CITY: Charlotte STATE: NC ZIPCODE: 28216

Date:

PROPERTY INFORMATION (FROM ENGINEERING FORM):
TAX/PARCEL NUMBER: 037-024-20
STREET ADDRESS: 1600 Thompson Ave
ZONING:

X PROPERTY OWNER:
NAME: Coleman (last) Robert (first) S. (mi)
ADDRESS: 1600 Thompson Ave PHONE: (704) 399-3526
CITY: Charlotte STATE: NC ZIPCODE: 28216

SUBDIVISION OR MOBILE HOME PARK NAME:

Township (check one):
☐ 0 Mecklenburg County ☐ 2 Davidson ☐ 4 Pineville ☐ 6 Huntersville
☐ 1 Charlotte ☐ 3 Cornelius ☐ 5 Matthews ☐ 7 Mint Hill

TYPE APPLICATION (check one):

LOT NUMBER: LOT SIZE (in acres):

☐ SOIL TEST - INDIVIDUAL LOT (D)
☐ NEW CONSTRUCTION ON VACANT LOT - 4 BEDROOMS OR LESS (N)
☐ EXCHANGE MOBILE HOME - SAME # BEDROOMS (Y)
☐ ADDITION - INCREASE ROOMS/OCCUPANCY/MOBILE HOME SIZE (A or M)
☐ COMMERCIAL OR INDUSTRIAL (N)
☐ SOIL TEST DEVELOPMENT (P)
☐ ADDITION - GARAGE OR RENOVATION/NO MAJOR CHANGES (X)
☐ MODIFIED /ALTERNATIVE/ OR RESIDENCE > 4 BEDROOMS (Z)
X REPAIR TO SYSTEM (R)

RESIDENTIAL PROPERTY (Type Building, check one):
☐ SINGLE MOBILE HOME (S) X HOUSE (H) ☐ MULTIPLE FAMILY (U)
☐ DOUBLE WIDE (D) ☐ MODULAR HOME (M) ☐ OTHER _____ (O)

NUMBER BEDROOMS: 3 NUMBER OCCUPANTS: 4

SYSTEM CLASSIFICATION:

COMMERCIAL/INDUSTRIAL PROPERTY:
Type Business _____ # Employees ___ Per Shift ___ ___ ___
Industrial Wastes (Y/N) ___
Underground Storage Tanks On Property (Y/N) ___ Type _____

WATER SUPPLY (check one):
X ☐ Community (C) ☐ Shared Well (S)
☐ Municipal (M) ☐ Other 'spring' (O)
☐ Private Well (P)

FUTURE ADDITIONS - ALL PLANNED ADDITIONS MUST BE ENTERED (check all that apply):
☐ Swimming Pool ☐ Jacuzzi ☐ Stable/Barn ☐ Workshop ☐ None
☐ Garage ☐ Storage Building ☐ Deck/Patio ☐ Bedrooms ☐ Other

The undersigned, owner, or legal agent for the owner, of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: X Robert S. Coleman Date: 6-9-95

NOTICE:

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

...No work shall be conducted on the septic tank system until an installation, Construction, Alteration and/or Repair approval is granted by this Department.

...This permit is not transferable.

...6-14-95 site visit - malfunctioning. Sent NOV. May have collapsed pipe between tank + d-box. Advised that may want to see about maintenance for that. SB

☐ IMPROVEMENT PERMIT - VALID 60 MONTHS FROM ISSUANCE
☐ MOBILE HOME EXCHANGE APPROVAL - VALID 6 MONTHS FROM ISSUANCE
☐ ADDITION/RENOVATION APPROVAL - VALID 1 YEAR FROM ISSUANCE

Environmentalist Date

Director or Authorized Section Head Date

NO Record found

8-8-95 site visit. malfunction appears corrected by maintenance work done by homeowner. SBateman

WATER : 122791