Date Received 4-5-84

RECEIVED
APR 5 1984
ENVIRONMENTAL HEALTH

SIR No. 20863

T. P. No. 025-131-08

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER [illegible] (LAST) [illegible] (FIRST) L (MIDDLE)

2) ADDRESS OF OWNER [illegible] ZIP 28216

3) PHONE NO. Home 392 5484 Office [illegible]


4) LOCATION OF PROPERTY 4939 [illegible] Road (STREET OR COUNTY ROAD)

5) SUBDIVISION [illegible] LOT NO 9-10 BLOCK NO 1

MAP BOOK NO 12 PAGE NO. 36

6) DEED REFERENCE DEED BOOK [illegible] PAGE NO [illegible]

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Lakewood Road

OWNER [signature]

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 20863

T.C. NO. PO 025-131-08

(Ground Absorption Sewage Disposal)

OWNER: Roger L. Campbell
ADDRESS: 2915 Battles Ford Road Charlotte, N.C. 28214
PLAT NO: Lots 9&10
LOT SIZE: 17,666
LOCATION OF SITE: 4939 Lakeview Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 3-10% U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 36 48 U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) 36" U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S (PS) To ground water U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS 20,000 sq ft U	S PS U	S PS U	S PS U
8. SOIL GROUP	II-A			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cecil Lloyd			


S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: _____

Described by: William F. Mayfield
Title: Soil Scientist
Date: 4-26-84

14


50'
Contr
Line
90'
90'
50'
Lakeview

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE, NORTH CAROLINA 28203

SIR. NO. 20863
T.C. NO. PO 025-131-08
DATE: 4-27-84

Roger L. Campbell
2818 Beatties Ford Road
Charlotte, NC 28216

RE: Property located at 4939 Lakeview Road

At your request, a field investigation was conducted on the property designated above. The soils on the property were found to contain a limited area of provisionally suitable soil for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit plot plans for the proposed construction, well, and ground absorption sewage disposal system to this office. They will be reviewed and if it is found that there is an adequate area of provisionally suitable soil to accommodate the proposed installation, an Improvements Permit will be issued by this office.

If I may be of assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

BDH/kbg

Enclosure