

2421 MARY ANN DR

05911309

1/11/2008

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

Bldg OS

7678 County Permit Review Worksheet

Reviewer ICR

Rule or Law		1	2	3	4	5	6	7	8	9	10
	Permit Application										
.1937(d)	Is the Application complete	✓									
.1937(d)	Is there a Site plan/Plat with application	✓									
.1937(d)	Is the Facilityshown?	✓									
.1937(d)	Are appurtenances shown	✓									
	Site Evaluation Information										
.1939 (a)(1)	Topography and Landscape Position Recorded?										
.1940 (a-q)	Slope % Recorded?										
.1939 (a)(2)	Texture Class Recorded?										
.1939 (a)(2)	Structure type Recorded?										
.1939 (a)(2)	Consistence Recorded?										
.1939 (a)(2)	Mineralogy Recorded?										
.1939 (a)(3)	Soil Wetness Condition Recorded?										
.1939 (a)(4)	Soil Depth to Rock or Parent Material Recorded When Encountered?										
.1939 (a)(5)	Depth to Restrictive Horizons Recorded When Encountered?										
.1939 (a)(6)	Sufficient Available Space Recorded?										
.1937(m)	Are the Profile Locations Shown?										
.1939(a) & .1945(b)	Are the S/PS Profiles in system & in repair area?										
	Number of auger borings made:										
.1939(d), .1955, .1956, .1957	Were sufficient auger borings made?										
	LTAR										
	IP/CA										
G.S. 130A-336(a) & .1937(g)	Proposed System Type stated-Initial										
.1945(b)	Proposed System Type stated-Repair										
G.S. 130A-336(a)(3)	System location identifiable by setbacks - Initial										
.1937(g) & .1945(b)	System components shown - Initial										
.1945(b)	Repair area shown										
.1937 (f)(g)	Does System design match facility, flow & WW characteristics?										
.1937 (f)(g)	*Is System design consistent with soil/site conditions?*										
.1937 (f)(g)	Is the System located in the approved area?										
G.S. 130A-336(a)	Is the Design flow (gpd) indicated?										
G.S. 130A-336(a)	Number of Bedrooms, employees, seats, etc. indicated?										
.1937(g)	Trench depth indicated?										
.1937(g)	Trench width indicated?										
.1937(g)	Trench length indicated?										
G.S. 130A-336(a)(1)	Proposed/existing well shown?										
G.S. 130A-336(a)(1)	Property line lengths shown?										
G.S. 130A-336(a)	Facility/appurtenance setbacks shown from fixed points?										
	OP										
.1937(i)	System type as described in table V(a) of rule .1961										
.1937(i)	Conditions for system performance, operation, maintenance, monitoring and reporting										

If system design is incorrect or inconsistent with site conditions, indicate why for each below

NOT ACCEPTABLE

Mecklenburg County Groundwater & Wastewater Services
700 N. Tryon St., Suite 211 Charlotte, NC 28202
Phone: (704) 336-5103 Fax: (704) 336-6894

NC DENR
Division of Environmental Health
On-Site Wastewater Section

INSTALLATION APPROVAL for an
ON-SITE WASTEWATER TREATMENT & DISPOSAL SYSTEM

File #: 7067B Permit #: _____ Tax Parcel #: 05911309

Property Owner: Paul Martin / H Lee Freeman

Job Location Address: 2421 Mary Ann Dr.

City: Charlotte State: NC Zip Code: 28214

Installation Approval Issuance Date: 04-11-2007

Permission is hereby given to ☐ install ☐ alter ☒ repair an on-site wastewater treatment & and disposal system, with subsurface soil absorption and effluent discharge, as specified herein at the described location. This approval is granted based upon the application information submitted to our office. All work shall be completed on or before 05-11-2007, after which date this approval shall be null and void. The system shall meet all of the construction requirements of 15A NCAC 18A. 1900 which are in effect on the date of granting this approval. An **Operation Permit** must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now of hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

***NOTICE: This system shall not be installed while soils are in a wet condition.**

Permitted Design Flow: 360 GPD

Site LTAR: .3 GPD/ft² (For new installations only.)

Liquid Capacity of Septic Tank: Existing gallons

Liquid Capacity of Dosing Tank: N/A gallons

Drainfield Design ☒ N/A

Trench Depth: _____ inches

Trench Width: _____ feet

Line Spacing: _____ feet (O.C.)

Total line length: _____ feet

# of Lines: _____ @ _____ feet

Depth of Media: _____ inches (Type) _____

Distribution Device: _____

Bed Design *(For Repair Installations ONLY.)* ☐ N/A

Bed Depth: 30 inches

Bed Width: 9 feet

Total line length: 67 feet

# of Lines: 1 @ 67 feet

Depth of Media: 12 inches (Type) Stone or other Approved

Distribution Device: D-Box

Water Supply Source

☒ Municipal ☐ Private Well ☐ Community Well

☐ Other _____


Minimum System Setbacks

Distance from Building Foundation: 5 feet

Distance from Property Line: 10 feet

Distance from Water Supply Source: 10 feet

SKETCH OF SYSTEM LAYOUT
(Proposed Layout)



Comments: System Classification & Type: IIc

DENR Authorized Agent: Jeremy Michael Signature: Jeremy Michael

GWS – RES. APP 07/05

SEPTIC FEE: _____
DATE: 4/11/07
CRT [ ]

PERMIT APPLICATION FOR A RESIDENTIAL SITE IMPROVEMENT PERMIT / CONSTRUCTION AUTHORIZATION FOR ON-SITE WASTEWATER SYSTEM NEW WELL INSTALLATION OR REPAIR OF EXISTING WELL MECKLENBURG COUNTY GROUNDWATER & WASTEWATER SERVICES

App ID 2157

WELL FEE: _____
DATE: _____
CRT [ ]

FILE # 70628

SEPTIC / TYPE APPLICATION: ☐ NONE ☐ NEW SYSTEM ☐ ALTERATION ☑ REPAIR ☐ MODIFY PLOT PLAN

WELL / TYPE APPLICATION: ☐ NONE ☐ NEW WELL ☐ MAJOR REPAIR ☐ ABANDONMENT

JOB LOCATION INFORMATION:

TAX/PARCEL #: 059-113-09
STREET ADDRESS: 2421 MARY ANN DR
CITY: CHARLOTTE
STATE: NC ZIP: 28214
SUBDIVISION OR MOBILE HOME PARK NAME:
LOT #:
1962
TOWNSHIP:

☑ 0-MECKLENBURG ☐ 4-PINEVILLE
☐ 1-CHARLOTTE ☐ 5-MATTHEWS
☐ 2-DAVIDSON ☐ 6-HUNTERSVILLE
☐ 3-CORNELIUS ☐ 7-MINT HILL

BUILDING INFORMATION:

TYPE OF BUILDING:

☐ SINGLE MOBILE HOME (S) ☐ MODULAR HOME (M)
☐ DOUBLE WIDE (D) ☐ MULTIPLE FAMILY (U)
☑ HOUSE (H) ☐ OTHER

HEATED SQUARE FOOTAGE: 1728
NUMBER OF BEDROOMS: 3
NUMBER OF OCCUPANTS: 2

FOUNDATION FOR RESIDENCE:

☐ CONCRETE SLAB ☐ BASEMENT WITH PLUMBING
☑ CRAWLSPACE ☐ BASEMENT WITH NO PLUMBING

IF PLANNING TO EXPAND/ALTER THE EXISTING SYSTEM INDICATE THE FOLLOWING CHANGES:

NUMBER OF BEDROOMS TO BE ADDED: 0 NUMBER OF ADDITIONAL OCCUPANTS IN THE RESIDENCE: N/A

WILL THERE BE A HOME BUSINESS IN THE RESIDENCE? ☐ YES ☑ NO TYPE:

WATER SUPPLY:

☑ MUNICIPAL (M) ☐ PUBLIC (C) ☐ PRIVATE WELL (P) ☐ SHARED WELL (S) ☐ OTHER 'SPRINGS' (O)

PROPOSED USE OF WELL: ☐ N/A ☐ IRRIGATION ☐ POTABLE ☐ GEOTHERMAL ☐ OTHER

ARE ANY OF THE FOLLOWING LOCATED ON THE PROPERTY? IF SO, PLEASE SHOW LOCATION ON SITE PLAN/PLAT.

BURIED CABLES, LANDFILLS, STUMPHOLES	☐ YES	☑ NO	WELLS, SPRINGS, OR WATER LINES	☐ YES	☑ NO
EXISTING WASTEWATER SYSTEMS	☑ YES	☐ NO	DESIGNATED WETLANDS	☐ YES	☑ NO
EASEMENTS OR RIGHT-OF-WAYS'	☐ YES	☑ NO	GRADING/SOIL REMOVAL PERFORMED	☐ YES	☑ NO

PROPERTY OWNER:

NAME: LEE FREEMAN
ADDRESS: 2421 MARY ANN DR
CITY: CHARLOTTE
STATE: NC ZIP: 28214
HOME PHONE: 704 392-0994 WORK PHONE:
MOBILE PHONE: 704 968-3700 FAX:

LEGAL AGENT FOR PROPERTY OWNER, IF APPLICABLE:

NAME: PAUL MARTIN
ADDRESS: 7421 MARY ANN DR
CITY: CHARLOTTE
STATE: NC ZIP: 28214
HOME PHONE: 704 392-0994 WORK PHONE:
MOBILE PHONE: FAX:

WHAT DATE WAS THE PROPERTY ORIGINALLY DEEDED AND RECORDED?

WHAT IS THE ANTICIPATED CLOSING DATE FOR THIS PROPERTY?

*An Improvement Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

Owner's/Agent's Signature Date

NORTH CAROLINA DEPARTMENT OF
ENVIRONMENT & NATURAL RESOURCES DIVISION
OF ENVIRONMENTAL HEALTH ON-SITE
WASTEWATER SECTION

*A Well Permit is subject to suspension or revocation if site plans or the intended use change or if information submitted in this application is falsified or changed. The undersigned, owner, or legal agent for the owner, of the property described above as the "Job Location" has read the foregoing application, acknowledges that the contents of same are true, and authorizes the Mecklenburg County Health Department to enter onto the property for the purpose of processing this request.

Owner's/Agent's Signature 4/11/07 Date

MECKLENBURG COUNTY HEALTH DEPARTMENT
GROUNDWATER & WASTEWATER SERVICES
700 N. TRYON ST., SUITE 211
CHARLOTTE, NC 28202 704-336-5103 / FAX: 704-336-6894