SEE INSTRUCTIONS ON BACK

Date Received 1-9-94

ICAR (S) Application No 7404

T C No CMS-7404-C7


Map Date Sept 1, 1970

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) Number of Bedrooms —
5) Existing Water Supply —
Emergency —
6) Within City Limits — No
7) Garbage Disposal — No
8) Driveway — No
9) Water Supply —
A Public Water Supply —
B Community System —
C Individual Supply —
1 Well —
2 Spring —
Sewage Type —
Other Dwellings Same —
Property Lines —
Other Buildings Same Lot —
Community Water — Yes No
11) FHA Case No —
12) VA Case No —

13) NAME OF OWNER Austin (LAST) Zeke (FIRST) Tomlinson (MIDDLE)

14) ADDRESS OF OWNER 117 13. Ref 139

15) PHONE NO Home 596-2836 Office

16) LOCATION OF SYSTEM Darwin Drive & Oak Drive (STREET OR COUNTY ROAD)

17) SUBDIVISION — Lot No — Block No —

Map Book No — Page No. —

18) DEED REFERENCE — DEED BOOK — AT PAGE —

19) HAS A PERCOLATION TEST BEEN RUN? — YES ✓ NO DATE RUN 1958

20) PTR NUMBER (See Instructions) —

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION 1/12/94

OWNER Zeke T. Austin

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued 8 Jan 74

Serial No. 4749

ICAR(S) Permit No. 7404

T. C. No. 045-444-07

Map Date 1 Apr 70


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to Install or Construct, ✓Alter or Repair the individual septic tank waste water treatment system with subsurface soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7404, dated 5 Jan 74 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 5 Feb 74, after which date this permit shall be null and void.



PLOT OF SYSTEM

Percolation Rate —

Liquid Capacity of Tank —

Tank Construction —

Absorption and/or Nitrification Lines:

Total Line Lenght 200'

Number of Lines 4 (4 x 50' x 12")

Distance from House 20'

Distance from Property Line 20'

Distance from Well 100'

NAME OF OWNER Linton, Ted Jonhson

LOCATION OF PROPERTY Elk Ave (Center Park)

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: Same Letter (Cert)

Division or Section Head

W. D. Lisby
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO. E 5-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 10 Jan 74

Serial 4308

C of A (s) No. 7404

T C. No 045-444-07

Map Date Sep 70

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Porter, Freda Freeman
(LAST, FIRST, MIDDLE)

Location of Property Oak Lane

Application Number 7404 Permit Number 7404

Inspection Data:

Liquid Capacity of Tank — Tank Material Asphalt

Total Length of Drain Tile 200' Number of Lines 4(10'X50'X17")

Depth of Filter Material 12" Cover Depth 18"

Water Supply Source Individual Well & Community Distance from Water Source 100'

Excavation Inspected 8 Jan 74 (DATE) Tank Inspected — (DATE)

Nitrification Field Inspected 8 Jan 74 (DATE)

Washing Machine Line Inspected, If Applicable N/A (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit (s) in addition to those listed below under comments This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: James Stewart (Contr.)

M L Lisby
Environmentalist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY