Date Received 2-23-73

APT No. 5631

T. C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Huntley (LAST) Baxter (FIRST) D. (MIDDLE)

2) ADDRESS OF OWNER Roberts Ave. York, S.C. ZIP 29745

3) PHONE NO Home Office 503-0910


4) LOCATION OF PROPERTY Helena Circle (STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO. 11 BLOCK NO.

MAP BOOK NO. 12 PAGE NO. 171

6) DEED REFERENCE DEED BOOK 2350 PAGE NO 275

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

Serial No. 7

PTR No. 5631

Date Issued March 6, 1973

T C No 195-093-03

Map Date 9-29-71

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Huntley (LAST) Baxter (FIRST) D. (MIDDLE)

ADDRESS OF OWNER Roberts Ave., York, S.C. ZIP

LOCATION OF PROPERTY Helena Circle (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 11 BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling or construction including the drilling of wells is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John R. Atkinson

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 3:14:73

ICAR(S) Application No 5631

T C No 195-093-03

Map Date 9 29 71


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1 ___ Install or Construct 2 ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3 PLOT PLAN (ACCURATELY DIMENSIONED)

3 Bedrooms

4 Family Size (No. of Persons) Employed

5 Water Supply: Yes [X] No

6 Garbage Disposal: Yes [X] No

7 Dishwasher: [X] Yes No

8 Water Supply:
A Individual Well [X]
B Governmental System
C Community System
1 Well Owned by Applicant
2 Well Owned by Community

9 Sewage System
House outside within 200 feet of public sewer: Yes [X] No
House located within 200 feet of sewer: Yes [X] No

10 Connected to sewer: Yes [X] No

11 FHA Case No: None

12 VA Case No: None

13) NAME OF OWNER Huntley (LAST) Baxter (FIRST) D. (MIDDLE)

14) ADDRESS OF OWNER Roberts Ave; York S.C.

15) PHONE NO Home ___ Office 523-0912

16) LOCATION OF SYSTEM Helena Circle (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. 11 Block No. ___

Map Book No 12 Page No. 171

18) DEED REFERENCE — DEED BOOK 2359 AT PAGE 235

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN 3-23 PR 60

20) PTR NUMBER (See Instructions) 5631

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

March 12, 1973
DATE OF APPLICATION

Baxter D Huntley
OWNER

FORM NO. E 4-4-[illegible]

HEALTH DEPARTMENT'S COPY

Date Issued March 14, 1973 Serial No. 2611

LA No. 5631

T. C No 195-093-03

Map Date 9-29-71

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Huntley (LAST) Baxter (FIRST) D. (MIDDLE)

ADDRESS OF OWNER Roberts Avenue, York, South Carolina ZIP

LOCATION OF LOT Helena Circle (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO 11 BLOCK NO

MAP BOOK NO PAGE NO

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/in an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation Construction, Alteration, and/or Repair Permit", number 5631. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Thomas R. Ward
Environmentalist

John R. Robinson
Director, Environmental Health Division or Authorized Section Head

FORM NO E-3-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 22 May 1973 Serial No. 3728 ICAR(S) Permit No 5631

T C No 195-093-03

Map Date 9-29-71


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby granted to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment and disposal subsurface soil absorption, effluent discharge as specified herein at the described location. This system is granted based upon the information supplied in application 5631, dated 3-12-73 and this permit shall be void and of no effect if the information provided in the application is incorrect or misrepresented. All work shall be completed on or before 20 June 1973 after which date the permit shall be void.



LAY OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1500 gal

Tank Construction precast

Absorption and/or Nitrification Lines:

Total Line Length 600 lf 4ft

Number of Lines 6 (15-2100

Distance from House 10' +

Distance from Property Line 10' +

Distance from Well 50' +

NAME OF OWNER Huntley, Baxter D.

LOCATION OF PROPERTY Helena Circle 11

The system shall meet all the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments wash line in bed 5 x 12 x 4'

John R Atkinson

Signature of Sanitarian

Signature of Section Head

Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO. E-514-73

OFFICE COPY

Date Issued 6-5-73

Serial No. 3476

C of A (s) No. 5631

T C No. 195-063-03

Map Date 6-26-71

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Huntley, Royster D
LAST FIRST MIDDLE

Location of Property Helena Circle

Application Number 5631 Permit Number 5631

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material Pre cast Conc.

Total Length of Drain Tile 600' Number of Lines 6

Depth of Filter Material 12" Cover Depth 18"

Water Supply Source Well Distance from Water Source 100'

Excavation Inspected 6-5-73 DATE Tank Inspected 6-5-73 DATE

Nitrification Field Inspected 6-5-73 DATE

Washing Machine Line Inspected, If Applicable 6-5-73 DATE

The undersigned has inspected the Individual Septic Tank System with subsurface soil absorption, effluent discharge as described above and it has been ~~installed~~ or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Installed by Howard Hayes

Thomas R. Ward
Environmentalist

FORM NO E-6-4-1-71

HEALTH DEPARTMENT'S COPY