Date Received 5-8-73

APT No 6188

T. C. No.

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Southminster Company Inc.
(LAST) (FIRST) (MIDDLE)

2) ADDRESS OF OWNER P. O. Box 23057 ZIP 28212

3) PHONE NO Home 545-5107 Office 372-3885


4) LOCATION OF PROPERTY London Circle
(STREET OR COUNTY ROAD)

5) SUBDIVISION LOT NO. 8 BLOCK NO. 102

MAP BOOK NO 213 PAGE NO. 10

6) DEED REFERENCE: DEED BOOK PAGE NO.

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

John C Poore
OWNER
Southminster Co.

FORM NO E-1-B-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. May [illegible] 73
2. _____
3. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. [illegible]133
T.C. No. _____

NAME OF OWNER [illegible], Inc.

ADDRESS OF OWNER [illegible] ZIP _____

LOCATION OF LOT [illegible]

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	[illegible]	[illegible] min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

_____

_____

_____

_____
Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70