Date Received 7/12/77

APT No. 12834

T. C No. 031-164-11

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER [illegible] (LAST) (FIRST) (MIDDLE)

2) ADDRESS OF OWNER [illegible] ZIP [illegible]

3) PHONE NO Home [illegible] Office [illegible]


4) LOCATION OF PROPERTY [illegible] (STREET OR COUNTY ROAD)

5) SUBDIVISION [illegible] LOT NO 12 BLOCK NO [illegible]

MAP BOOK NO 3 PAGE NO 6

6) DEED REFERENCE DEED BOOK [illegible] PAGE NO 107

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



7) SKETCH DIAGRAM OF PROPERTY OR LOT

[illegible]
OWNER

Environmental Health Department's Copy

NORTH CAROLINA
DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES
RALEIGH, NORTH CAROLINA

APPENDIX H
SITE EVALUATION

(Ground Absorption Sewage Disposal)

APT 13934
T T 031-104-19
Lot # 19

OWNER: Delton N. Oliver
ADDRESS: R.F.D. One 44: 25
COUNTY: Randolph
LOCATION OF SITE: Jack Linn

DATE REQUESTED: 7/18/77
PLAT NO.:
LOT SIZE: Several

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) 2-8% / PS / U	S / PS / U	S / PS / U	S / PS / U +
2. SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, Note 2:1, Clay)	S Some / (PS) 2:1 Clay / U	S / PS / U	S / PS / U	S / PS / U
3. SOIL STRUCTURE (12.36 in.) (Clayey Soils)	S Moist / (PS) / U	S / PS / U	S / PS / U	S / PS / U
4. SOIL DEPTH (In.)	(S) 49" / PS / U	S / PS / U	S / PS / U	S / PS / U
5. RESTRICTIVE HORIZONS (In.) (Imprevious Strata, Rock)	S / PS — / U	S / PS / U	S / PS / U	S / PS / U
6. SOIL DRAINAGE/GROUNDWATER (External & Internal)	(S) 24" to / PS water / U Table	S / PS / U	S / PS / U	S / PS / U
7. SOIL PERMEABILITY (Percolation Rate)	S Moderate / (PS) 30 min/in / U	S / PS / U	S / PS / U	S / PS / U
8. OTHER (Specify) *	S Lot Size / PS Less than 2 ac / U Soil	S Less / PS / U	S / PS / U	S / PS / U
9. SITE CLASSIFICATION	unsuitable due to lot size			
SOIL SERIES	Cat. I Enon Loam			

S - Suitable PS - Provisionally Suitable U - Unsuitable


* See Diagram on Back (Include: Soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slope patterns, etc)

Recommendations/Comments: Based on this investigation on undisturbed soil areas of provisionally suitable soil for the installation of a septic tank system was found on the lot.

Described By: William M. Marlow

Title: Soil Scientist Date: July 26, 1977

DHS Form 2601 (2/77)
Sanitation


30'
149.3 Cont.
156'±
10-12 ft Ridge
on Lot line
50'

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
1200 BLYTHE BOULEVARD
CHARLOTTE NORTH CAROLINA 28203

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

SIR. NO. 12834
T.C. NO. 031-164-19
MAP DATE
DATE 7-28-77

NAME OF OWNER Oliver, Delton Norvell

ADDRESS OF OWNER Route 6, Box 747-I5, Charlotte, NC 28208

LOCATION OF LOT Lake Drive, Lot 19

As determined under the Rules and Regulations of the North Carolina Department of Human Resources, Division of Health Services, Raleigh, North Carolina, the soils on the lot described above were found to be unsuitable for the installation of an individual septic tank-soil absorption system. This site cannot be approved for a septic tank system due to the following reason:

Insufficient space available for installation of ground absorption sewage disposal system in accordance with North Carolina Department of Human Resources specifications.

John R. Adkisson

John R. Adkisson, Environmentalist
On Premises Waste Disposal Section

JRA:glr

EHD 398
7/77

R