RECEIVED

Date Received 3-[illegible]-1983

ENVIRONMENTAL HEALTH

SIR No. 19425

T. C. No. 135-203-02

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER SCHLABACH (LAST), ROBERT (FIRST) H. (MIDDLE)

2) ADDRESS OF OWNER 3432 JOSEPH DR., MATTHEWS, N.C. ZIP 28105

3) PHONE NO. Home 545-4684 Office 332-2615

4) LOCATION OF PROPERTY L101 M7 849 JONES BERRY RD.
STREET OR COUNTY ROAD


5) SUBDIVISION ELLBURTA DOWNS LOT NO. 101 BLOCK NO.

MAP BOOK NO. PAGE NO.

6) DEED REFERENCE DEED BOOK PAGE NO.

INFORMATION AS SHOWN ON TAX APPRAISAL NOTICE:
DEED REF.-4164559, L101 M7 849 JONES BERRY RD., PARCEL NO.- BOOK 135 PAGE 203 LOT 02

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER Robert H. Schlabach
Margaret R. Schlabach

EHD-5-76

Environmental Health Department's Copy

Serial No. 4908

PTR No. 19425

T. C. No. 135-203-02

Date Issued 3-18-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Schlabach, (LAST) Robert (FIRST) H. (MIDDLE)

ADDRESS OF OWNER 3432 Joseph Dr., Matthews, NC ZIP 28105

LOCATION OF PROPERTY 849 Jones-Berry Road (STREET OR COUNTY ROAD)

SUBDIVISION Ellburta Downs LOT NO. 101 BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot **Provisionally Suitable**

The permeability rate determined by the investigation was The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions

1. A permit to install, construct, alter, or repair the septic system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the improved area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction, including the drilling of a well is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

William A. Marlin
Soil Scientist

Mike Sexton
Environmental Health Director or Authorized Section Head

EHO-S-76

Environmental Health Department's Copy

DEPARTMENT OF ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY, NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19425

T.C. NO. 135-20302

(Ground Absorption Sewage Disposal)

OWNER: Robert H. Schlabach
ADDRESS: 3432 Jones Dr. Matthews N.C.
PLAT NO: Lot 101
LOT SIZE: 22,737
LOCATION OF SITE: Jones Berry Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 8-15%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 36-48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) Saprolite 36"+ U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S ground (PS) water U >48"	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U
8. SOIL GROUP	IV A			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cecil-Like			

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: William B. Martin
Title: Soil Scientist

Date: 3-15-83

EHD 539 (Revised: 6/82)


Well
109'
168
150'
Cecil-Like
Cut Area Adjacent To Road
Jones
Berry
64'
92