Date Received 2-23-73

APT No. 564

T. C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER _____ (LAST) _____ (FIRST) _____ (MIDDLE)

2) ADDRESS OF OWNER _____ ZIP _____

3) PHONE NO. Home _____ Office _____


4) LOCATION OF PROPERTY _____ (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO _____ BLOCK NO. _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

_____
OWNER

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

Serial No. 2

PTR No 5641

Date Issued March 1, 1973

T C No 023-093-13

Map Date 1-22-73

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Davis (LAST) Candace (FIRST) A. (MIDDLE)

ADDRESS OF OWNER Route 7, Box 834 ZIP 28213

LOCATION OF PROPERTY Pennewick Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 50 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with sub-surface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John R. Atkinson

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-4-1-71

HEALTH DEPARTMENT'S COPY

Date Received 2 23 23

ICAR(S) Application No. 5641

T C No.

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

✓ (1) Install or Construct (2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



(3) PLOT PLAN (ACCURATELY DIMENSIONED)

(4) NAME OF OWNER _____ (LAST) _____ (FIRST) _____ (MIDDLE)

(5) ADDRESS OF OWNER _____

(6) PHONE NO. Home _____ Office _____

(7) LOCATION OF SYSTEM _____ (STREET OR COUNTY ROAD) _____

(8) SUBDIVISION _____ Lot No. _____ Block No _____

Map Book No _____ Page No. _____

(9) DEED REFERENCE — DEED BOOK _____ AT PAGE _____

(10) HAS A PERCOLATION TEST BEEN RUN? ___ YES _____ NO DATE RUN _____

(20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

_____ _____
DATE OF APPLICATION OWNER

FORM NO. E-4-4[illegible]

HEALTH DEPARTMENT'S COPY

Date Issued March 1, 1973

Serial No. 2584

LA No. 5641

T. C. No 023-093-13

Map Date 1-22-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Davis (LAST) Candace (FIRST) A. (MIDDLE)

ADDRESS OF OWNER Route 7, Box 634 ZIP 28213

LOCATION OF LOT Kennewick Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface soil absorption effluent discharge based on the percolation test results which yielded a percolation rate of 50 min/in on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" number 5641. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

M. L. Kirby
Environmentalist

John R. Robinson
Director, Environmental Health Division or Authorized Section Head

FORM NO. E-3-4-1-71

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received 9/28/77

ICAR (S) Application No 5641

T C No 023-093-13


Map Date 9-9-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to ADD: den, bedroom, bath, utility + carport

1 ( ) Install or Construct 2) (✓) Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



3 PLOT PLAN (ACCURATELY DIMENSIONED)

4 Mobile Home ___ Yes (✓) No
___ (✓) Yes ___ No

4 No. of bedrooms 2 ___

5 Business Use Max No. Employees ___

6 Washing Machine (✓) Yes ___ No

7 Garbage Disposal ___ Yes (✓) No

8 Dishwasher ___ Yes (✓) No

9 Water Supply
A Individual Well (✓)
B Governmental System ___
C Community System
1 Well source ___
2 Governmental source ___

10 Sewage System
House supplied within 200 feet of public sewer ___ Yes (✓) No
House located within 200 feet of community sewer ___ Yes (✓) No

11 FHA Case No ___

12 VA Case No ___

13) NAME OF OWNER Causey (LAST) Mr. & Mrs. Thomas (FIRST) Edward (MIDDLE)

14) ADDRESS OF OWNER Route 4 Box 195 J Charlotte NC 28205

15) PHONE NO Home 394-9655 Office 542-4186

16) LOCATION OF SYSTEM Mt Holly-Huntersville Rd. (STREET OR COUNTY ROAD)

17) SUBDIVISION ___ Lot No. ___ Block No. ___

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK 3735 AT PAGE 745

19) HAS A SOIL INVESTIGATION BEEN RUN? YES (✓) NO DATE RUN ___

20) PTR NUMBER (See Instructions)

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

9-26-77
DATE OF APPLICATION

Thomas E Causey
OWNER

EHD-5-76

Environmental Health Department's Copy

Date Issued September 28, 1977

Serial No. 1218

LA No. 5641

T. C. No. 023-093-13

Map Date 8-9-77

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Causey (LAST) Thomas (FIRST) Edward (MIDDLE)

ADDRESS OF OWNER ROute 9, Box 195-A, Charlotte, NC ZIP 28208

LOCATION OF LOT Mount Holly-Huntersville Road (STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO._____ BLOCK NO._____

MAP BOOK NO._____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 5641. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

*** Will Use Existing System.**

Environmentalist

Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy