EDWARD'S PLACE

60' PUBLIC R/W

SURVEY

OF

Note: Topo taken from aerial maps furnished by Mecklenburg County Engineering Dept.

LOT 40, BAINBRIDGE II, PH 1, MAP 3

SCALE 1" = 50' TOWN OF MINT HILL, MECKLENBURG CNTY, NORTH CAROLINA

THE PROPERTY OF: David Hargett

MAP RECORDED IN BOOK 24 AT PAGE 13 DEED RECORDED IN BOOK ___ PAGE ___

Mecklenburg County
Health Department

Betty S. Snow, R.N., M.A.
Health Director

TELECOPIER TRANSMITTAL COVER SHEET

NOTICE

THE INFORMATION CONTAINED IN THIS TELECOPY MAY BE PRIVILEGED AND/OR CONFIDENTIAL AND IS INTENDED ONLY FOR THE USE OF THE PERSON TO WHOM IT IS ADDRESSED. IF THE READER OF THIS MESSAGE IS NOT THE INTENDED RECIPIENT (OR SUCH RECIPIENT'S EMPLOYEE OR AGENT), YOU ARE HEREBY NOTIFIED NOT TO READ, DISTRIBUTE OR COPY THE MATERIALS ATTACHED HERETO WITHOUT THE PRIOR WRITTEN CONSENT OF THE SENDER. IF YOU HAVE RECEIVED THIS TELECOPY IN ERROR, PLEASE NOTIFY THE SENDER BY TELEPHONE CALL AND RETURN THE ORIGINAL TELECOPY TO US BY MAIL AND WE WILL REIMBURSE YOU FOR THE REQUIRED POSTAGE. THANK YOU.

TO: Britt Setzer TELECOPIER # 663-6040

FROM: Sue Bateman 336-5569 DATE 12-14-93

NUMBER OF PAGES TRANSMITTED: 2 (including cover sheet)

COMMENTS:
Copy of a proposed building lot attached. The well area is for a public well. Supposedly there is an easement for the 100' area. Can you please comment/memo to me on this situation? as far as the public well is concerned? (The septic system design is one which is a proposed design, not yet reviewed) Thanks!

~~*~~ our FAX # 336-6894

If you do not receive all pages, please call us as soon as possible at the following number: (704)336-5102.

[X] Original will not follow [ ] Original will follow via:

[ ] U.S. Mail [ ] Hand Delivery [ ] ____

Fred Hamilton had checked out this situation, and he said That 100' minimum separation distance must be maintained between well and septic tank system and its repair area.

3-9-94 Britt Setzer, DEM in office in A.M. and said he did not feel it necessary to provide me/our office with a memo in reference to this situation. He said that as long as the septic tank system and its repair area is a minimum 100' from the well that that is all we can enforce.