W

Date Received 6 13 73

(200)

APT No. 6478

T. C. No. 211-022-33

Map Date Sept 1, 19 7x

# MECKLENBURG COUNTY HEALTH DEPARTMENT

## ENVIRONMENTAL HEALTH DIVISION

### APPLICATION FOR PERCOLATION TEST

YOUNG REALTY CO: INC. By,

1) NAME OF OWNER _____ PRES.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER P.O. BOX 1417 CHARLOTTE, N.C. ZIP 28201

3) PHONE NO. Home _____ Office 372-2750


4) LOCATION OF PROPERTY _____
(STREET OR COUNTY ROAD)

5) SUBDIVISION PROVIDENCE ACRES LOT NO 4 BLOCK NO. Page 643 & 657 MAP BOOK 6

MAP BOOK NO 6 PAGE NO 643 & 657

6) DEED REFERENCE. DEED BOOK 2458 PAGE NO 173

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.




7) ACCURATELY DIAGRAM & DIMENSION LOT

YOUNG REALTY CO: INC. Young Realty Co Inc

OWNER By C S Young

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

# MECKLENBURG COUNTY
## Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. July 16, 1973
2. _____
3. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE,
SOIL ABSORPTION, EFFLUENT DISCHARGE

SDR No. 6478
T.C. No. 211-032-33
9-1-70

NAME OF OWNER Young, C. D.

ADDRESS OF OWNER Post Office Box 1417 ZIP 28201

LOCATION OF LOT Olde Providence Road, Lot 4

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

| | Test No. | Date of Test | Percolation Rate |
|---|---|---|---|
| X | 1. | 7-13-73 | 200 min/in |
| ____ | 2. | _____ | _____ min/in |
| ____ | 3. | _____ | _____ min/in |

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Thomas R Ward
Environmentalist

(Stencil No.)
EHD 398
-/70

FORM NO.
R-19-8-14-70

2

SEE INSTRUCTIONS ON BACK

Date Received 6-13-73

MECK COUNTY HEALTH DEPT.
RECEIVED
1973

CAR (S) Application No 6478

T C No

Map Date

# MECKLENBURG COUNTY HEALTH DEPARTMENT

## ENVIRONMENTAL HEALTH DIVISION


Application for an

**Installation, Construction, Alteration, and/or Repair Permit**

**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1) X Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) No of Bedroom 7

5) Business Use Max No Employees

6) Washing Machine Yes No

7) Garbage Disposal Yes No

8) Dishwasher Yes No

9) Water Supply

A) Individual Well

B) Government System

C) Community System

1 Well Source

2 Government

10) Sewage System

House located within 200 feet of public sewer Yes No

House located within 200 feet of community sewer Yes No

11) FHA Case No

12) VA Case No

13) NAME OF OWNER YOUNG REALTY CO; INC.
(LAST, FIRST, MIDDLE)

14) ADDRESS OF OWNER P.O. BOX 1417 CHARLOTTE, N.C. 28201

15) PHONE NO Home ___ Office 372-2750

16) LOCATION OF SYSTEM Old Providence Rd.
(STREET OR COUNTY ROAD)

17) SUBDIVISION PROVIDENCE ACRES Lot No 4 Block No.

Map Book No 6 Page No. 643 & 657

18) DEED REFERENCE — DEED BOOK 2458 AT PAGE 173

19) HAS A PERCOLATION TEST BEEN RUN? ___ YES ___ NO DATE RUN

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true

DATE OF APPLICATION

YOUNG REALTY CO; INC. C.D. Young, Pres
OWNER

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Received 4/10/75

RECEIVED
APR 10 1975
ENVIRONMENTAL HEALTH DIVISION

APT No. 9135 6478

T. C. No.

Map Date

# MECKLENBURG COUNTY HEALTH DEPARTMENT

## ENVIRONMENTAL HEALTH DIVISION

### APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Young (LAST) Charles (FIRST) Cyrus Ray Jr. (MIDDLE)

2) ADDRESS OF OWNER 6955 Old Providence Road ZIP 28211

3) PHONE NO. Home 366-4227 Office 375-7726

4) LOCATION OF PROPERTY corner of Old Providence Road & Providence Rd W. (STREET OR COUNTY ROAD)


5) SUBDIVISION _____ LOT NO. #33 BLOCK NO. _____

MAP BOOK NO 211 PAGE NO. 032

6) DEED REFERENCE. DEED BOOK 211 PAGE NO. 032 - Lot # 33

2853-542 Deed Reference

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.




7) ACCURATELY DIAGRAM & DIMENSION LOT

Note: Please call Referenced test - Mark yellow -

OWNER Charles Young

FORM NO. E-1-9-1-72

HEALTH DEPARTMENT'S COPY

# MECKLENBURG COUNTY HEALTH DEPARTMENT

**INTER-OFFICE COMMUNICATION**

DATE: April 17, 1975

TO: John R. Adkisson

FROM: W. Everette Lynn, Jr. WEL
Soil Scientist

SUBJECT: APT ~~9130~~ 6478 (Charles Young)
Old Providence Road
TCN: 211-032-33
Date: 4/15/75

The lot consists of soils of the Wilkes and Iredell series. These soils have plastic and sticky clay subsoils which contain expanding minerals. The Iredell soils may also have a perched high water table during periods of high rainfall. In addition, the Wilkes soils are shallow to weathered rock material which results in potential for contamination of the water table. These soil characteristics result in inadequately slow permeability and percolation rate (mean perc. rate in excess of 200 min./in.).

Based on this investigation, the lot is not recommended for installation of a septic tank system.

WEL:jjk

WEL

SOIL INVESTIGATION REPORT

Date of Investigation 4-15-75 APT NO. 6478 9130

Owner Charles Young

Location of Property Old Providence Rd. TCM: 211-032-33

| Soil Properties | Soil Suitability Ratings | | | |
|---|---|---|---|---|
| | Soil 1 | Soil 2 | Soil 3 | Soil 4 |
| 1. Soil Series | Tredell | Wilkes | | |
| 2. Soil Slope | Suitable 2% | Suitable 6-8% | | |
| 3. Soil Depth | Suitable >48" | Unsuitable <30" | | |
| 4. Soil Texture | Unsuitable Silclay | Unsuitable Silclay | | |
| 5. Soil Structure | Unsuitable Massive | Unsuitable Massive | | |
| 6. Restrictive Horizons | — | — | | |
| 7. Soil Drainage | Unsuitable Perched W.T. <36" | Suitable W.T. >48" | | |
| 8. Soil Permeability (Percolation Rate) | Unsuitable >120 min/in | Unsuitable >120 min/in | | |
| 9. Other | — | — | | |
| 10. Overall Rating | Unsuitable | Unsuitable | | |


Recommendations Lot not recommended for installation of a septic tank system.

See diagram on back

W. Cynthia Cymmyfo
Soil Scientist

3/18/75
EHD 539

DIAGRAM OF PROPERTY




3/18/75

KMD 539

# MECKLENBURG COUNTY
## Department of Public Health
### 1200 Blythe Boulevard
### Charlotte, North Carolina 28203

DATE ISSUED
1. 4-17-75
2. _____
3. _____

SITE INVESTIGATION REPORT
INDIVIDUAL SEPTIC TANK SYSTEM
WITH SUBSURFACE,
SOIL ADSORPTION,
EFFLUENT DISCHARGE

SIP NO. 4478
T.C. NO. 211-032-33
MAP DATE 6-10-74

NAME OF OWNER Young, Charles

ADDRESS OF OWNER 6955 Old Providence Road, Charlotte, N. C. 28211

LOCATION OF LOT Corner: Old Providence Rd. & Providence Lane

The lot described above is not recommended for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

Unsuitable Soil

Percolation rate in excess of 200 min./in.

John R. Adkisson, Environmentalist
On Premises Waste Disposal Branch
Environmental Health Division

JRA:jjk

(Stencil No.)
EHD 389
8/74

FORM NO.
E-19-8-21-74