Date Received 1-23-23

APT No. 5459

T. C No _____

Map Date _____

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Johnson (LAST) Tommy (FIRST) Keith (MIDDLE)

2) ADDRESS OF OWNER 2532 Ashley Rd, Charlotte ZIP 28205

3) PHONE NO. Home 392-6910 Office 374-2732


4) LOCATION OF PROPERTY Back Creek Church Rd (287) (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 16 BLOCK NO _____

MAP BOOK NO 51 PAGE NO 19

6) DEED REFERENCE DEED BOOK 3135 PAGE NO 469

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Tom K. Johnson
OWNER

FORM NO. E-1-11-1-78

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Telephone 374-2113

Date Issued
1. January 26, 1973
2. _____
3. _____

SDR No. 5459
T.C. No. _____

SITE DISAPPROVAL REPORT
INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Johnson, Tommy Keith

ADDRESS OF OWNER 2032 [illegible] Road ZIP 28208

LOCATION OF LOT Back Creek Church Road, Lot 16

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	1-[illegible]-73	38 min/in
____	2.	_____	_____ min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

_____

_____

_____

H. S. J.
Environmentalist

(Stencil No.)
MMD 398
8/70

FORM NO.
R-19-8-14-70