Date Received 9/14/77

APT No. 12662

T. C. No. PO 215-191-01

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Ralph Squires Construction Company, Inc.
(LAST / FIRST / MIDDLE)

2) ADDRESS OF OWNER P. O. Box 25178 Charlotte, N. C. ZIP 28212

3) PHONE NO Home _____ Office 537-9553


4) LOCATION OF PROPERTY 13910 Creekside Drive
(STREET OR COUNTY ROAD)

5) SUBDIVISION Windrow Estates LOT NO 35 BLOCK NO. F

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK _____ PAGE NO _____

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Jerri Bryan
OWNER

EHD-5-76

Environmental Health Department's Copy

Apl. 12662

DEPT. OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES


APPENDIX H
SITE EVALUATION
(Ground Absorption Sewage Disposal)

: Ralph Squires Construction Co. DATE REQUESTED: June 14, 1977
: P.O. Box 25178 Charlotte PLAT NO.: ——
: Mecklenburg LOT SIZE: 27,000 sq. ft.
LOCATION OF SITE: 3910 Creekside Drive Lot No. 35 Block F
Taxlot No. 120-215-131-62

FACTORS	AREA 1	AREA 2	AREA 3	AREA
(")	(S) PS U 3-8"	S PS U ——	S PS U	S PS U
SOIL TEXTURE (12-36 in.) (Sandy, loamy, clayey, sandy clay)	S (PS) U Clay	S PS U ——	S PS U	S PS U
SOIL STRUCTURE (12-36 in.) (Clayey soils)	S (PS) U Blocky	S PS U ——	S PS U	S PS U
SOIL DEPTH (In.)	(S) PS U >48"	S PS U ——	S PS U	S PS U
RESTRICTIVE HORIZONS (In., Impervious Strata, rock)	S PS U ——	S PS U ——	S PS U	S PS U
SEASONAL HIGH GROUNDWATER (Perched & Internal)	(S) PS U water table >6'	S PS (U) poorly drained	S PS U	S PS U
PERMEABILITY (Percolation Rate)	S (PS) U moderate 60 min/in	S seasonal PS high water U table <18"	S PS U	S PS
(Specify)	S PS U ——	S transitional PS (U) floods	S PS	
	provisionally suitable	unsuitable		
	Cecil	Chewacla		

Based on this investigation, the lot was found to have an adequate area of provisionally suitable soils for installation of a septic tank system. System design should be based on a percolation rate of 60 min/in.

: W. Edward Pennant
: Soil Scientist July 5, 1977


180'
Deerhaven Court
140'
235'
120'
preferred septic system location
Creekside Drive

Serial No. 1059

PTR No. 12662

T C. No. P.0.215-131-01

Date Issued July 5, 1977

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Ralph Squires Construction Company, Inc.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER P.O. Box 25178, Charlotte, NC ZIP 28212

LOCATION OF PROPERTY 13910 Creekside Drive
(STREET OR COUNTY ROAD)

SUBDIVISION Windrow Estates LOT NO 35 BLOCK NO F



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot **Provisionally Suitable**

The permeability rate determined by the investigation was **60 min/in.** The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions

1. A permit for the proper alteration, or the construction system, must be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank and wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health according to the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval applies only to the system as located on the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is granted pending the satisfactory completion of the following: A well is to be performed on the lot which in the opinion of the Mecklenburg County Department of Environmental Health renders the area indicated as acceptable for system installation unsuitable for the proposed system. The owner or his agent is to notify the Director in writing of the results of the well and a report of such shall be submitted to the Department of Environmental Health before a permit for the system will be issued.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

W. Edward Eisenhut
Soil Scientist

John R. Atkinson
Environmental Health Director or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy

MECK COUNTY DEPARTMENT OF
Date Received 10/12/78

SEE INSTRUCTIONS ON BACK

ICAR (S) Application No. 12662

T C No. 215-431-01


Map Date ___

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) X Install or Construct 2) ___ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4) Mobile Home ___ Yes X No
Fence X Yes ___ No
4) No of Bedrooms 4
5) Business Use - Max No Employees N/A
6) Washing Machine X Yes ___ No
7) Garbage Disposal ___ Yes X No
8) Dishwasher ___ Yes X No
9) Water Supply
A. Individual Well YES
B. Governmental System ___
C. Community System:
1. Well source ___
2. Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes X No
House located within 200 feet of community sewer ___ Yes X No
11) FHA Case No N/A
12) VA Case No N/A

13) NAME OF OWNER RALPH (LAST) SQUIRES (FIRST) CONSTRUCTION Co (MIDDLE)

14) ADDRESS OF OWNER P.O. Box 25178, CHARLOTTE, N.C. 28212

15) PHONE NO Home ___ Office 537-9553

16) LOCATION OF SYSTEM 13400 CREEKSIDE DRIVE (STREET OR COUNTY ROAD)

17) SUBDIVISION LONDEDD ESTATES Lot No 35 Block No. F

Map Book No ___ Page No. ___

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? X YES ___ NO DATE RUN 7/5/77

20) PTR NUMBER (See Instructions) 12662

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

10-11-78
DATE OF APPLICATION

Mary Jo Ellis
OWNER

EHD-5-76

Department's Copy

Serial No. 2338

LA No. 12662

Date Issued October 13, 1978

T. C. No. 215-131-01

Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

TO THE BUILDING INSPECTION DEPARTMENT

IMPROVEMENT PERMIT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Ralph Squires Construction Company _____
LAST FIRST MIDDLE

ADDRESS OF OWNER P.O. Box 25178, Charlotte, NC ZIP 28212

LOCATION OF LOT 13910 Creekside Drive _____
STREET OR COUNTY ROAD

SUBDIVISION Windrow Estates LOT NO 35 BLOCK NO. F

MAP BOOK NO. _____ PAGE NO. _____

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 12662. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run

2 That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and, or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

Steve Wood
Environmentalist

John R Adkisson
Environmental Health Director, or Authorized Section Head

EHD-5-76

Environmental Health Department's Copy


Date Issued 22 Mar 79 Serial No. 2500 ICAR(S) Permit No. 12662

T & C No 215-131-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, Alter or Repair the individual septic tank waste water treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 12662, dated 10/13/78 and this permit shall be void and of no effect if the information provided in the application is found to be erroneous. All work shall be completed on or before 22 Sept, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permitted Rate P.S.

Liquid Capacity of Tank 1500 gal

Tank Construction P.C. Con

Absorption and/or Nitrification Lines

Total Line Length 440' ; 167'

Number of Lines 5 ; 4

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Ralph Squires Const. Co.

LOCATION OF PROPERTY 13916 Creekside Dr.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Ordinance which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered inoperative or can be used. **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

CORRECTIONS: (12'x42'x17" Stone)

(15'x88'x17" Stone)

Division or Section Head

Environmentalist Steve Wood

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

Date Issued 2 April 79 Serial No. 2455 C of A (s) No. 12663

T C No 80-215-131-01

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF COMPLETION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Ralph Squires Const. Co. Inc.
(LAST FIRST MIDDLE)

Location of Property 13910 Creekside Dr

Application Number 12663 Permit Number 12663

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material P.C. Conc.

Total Length of Drain Tile 440' & 167' Number of Lines 5 & 4

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected — Tank Inspected 30 Mar by JRA
(DATE)

Nitrification Field Inspected 30 Mar by JRA
(DATE)

Washing Machine Line Inspected, If Applicable 28 Mar SW
(DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, ——— altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly, or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments W/M o'kd by SW. St. by JRA - As permitted

Environmentalist

EHD-5-76

Environmental Health Department's Copy

Date Issued 4 June 79

Serial No. 2808


ICAR (S) Permit No. 12662

T. C. No. 215-13T-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct ✓ Alter or Repair the individual septic tank waste-water treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application _____, dated 4/ and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before _____, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate Repair

Liquid Capacity of Tank

Type Construction

Absorption and or Nitrification Line:

Total Line Length 150' & 100'

Number of Lines 2 & 2

Distance from House 20'

Distance from Property Line 10'

Distance from Well 1000'

NAME OF OWNER Soderquist

LOCATION OF PROPERTY 13910 Bactmore at Creekside

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments

THE ISSUANCE OF THIS PERMIT DOES NOT IN ANY WAY GUARANTEE THAT THE SYSTEM ANTICIPATED TO BE CONSTRUCTED WILL OPERATE PROPERLY OR RELIEVE ANY PERSON IN ANY WAY OR DEPARTMENT OWNING, CONTROLLING OR USING SUCH SYSTEM FROM ANY LIABILITY RESULTING FROM THE FAILURE OF THE SYSTEM TO OPERATE PROPERLY.

Steve Wood

Environmentalist

Division or Section Head

* If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

Date Issued 7 June 79 Serial No. 2710 C of A (s) No. 12662

T C No 215.13101

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Soderquist (LAST) (FIRST) (MIDDLE)

Location of Property 1390 Creekside DR.

Application Number _____ Permit Number _____

Inspection Data:

Liquid Capacity of Tank Repair Tank Material _____

Total Length of Drain Tile 150' & 100' Number of Lines 2 & 2

Depth of Filter Material 60" & 34" Cover Depth 18"

Water Supply Source well Distance from Water Source 100'

Excavation Inspected 7 June (DATE) Tank Inspected _____ (DATE)

Nitrification Field Inspected 7 June (DATE)

Washing Machine Line Inspected, If Applicable 7 June (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Note yard graded down severely after original system installed - partial wash for problem

Environmentalist

EHD-5-76

Environmental Health Department's Copy


Date Issued 6 Sept 77 Serial 3155 ICAR(S) Permit No. 12662

T. C. No. 215-131-01

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 12662, dated _____ and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before _____, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate Kyan

Liquid Capacity of Tank

Tank Construction

Absorption and/or Nitrification Lines

Total Line Length aerate system

Number of Lines

Distance from House

Distance from Property Line

Distance from Well

NAME OF OWNER Seagroves

LOCATION OF PROPERTY 3?? Lincoln Dr.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

3'x3'x? aeration pit 1 yard of line - backfill over system - to depth of 18" where graded shallow

Division or Section Head

Environmentalist


* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's **Copy**

THIS IS TO CERTIFY THAT ON THE 30th DAY OF OCT. 19 79 I, PLATTED THE PROPERTY SHOWN ON THIS PLAT AND THAT THE TITLE LINES AND THE WALLS OF THE BUILDINGS IF ANY ARE SHOWN HEREON

SIGNED D. RICE [redacted]



SKETCH PLAN SURVEY OF

SEEPAGE PIT

SCALE 1" = 2'

THE PROPERTY OF

MAP RECORDED IN BOOK AT PAGE DEED RECORDED IN BOOK PAGE

RALPH
SQUIRES
HOMES

November 1, 1979

Mr. Thomas W. Bivens, Director
Environmental Health
Mecklenburg County Health Department
1200 Blythe Blvd.
Charlotte, N. C. 28204

Re: Mr. and Mrs. Soderquist
13910 Creekside Drive
Matthews, N. C. 28105

Dear Mr. Bivens:

We propose to install a 12'x20'x12' seepage pit on the right hand side of the property half way of the original system where two pine trees presently stand. The two pine trees will have to be removed.

Attached is a diagram of the seepage pit. If there are no questions and this is satisfactory we will begin work.

Yours truly,

Larry Schuster

Larry Schuster
Construction Manager

LS:as

Attachment

P.O. BOX 25178 / CHARLOTTE, NORTH CAROLINA 28212 / TELEPHONE 704-537-9553

Serial 3406

Date Issued 12/6 79


ICAR(S) Permit No. 12662

T C No.

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 12662 * dated 12/6 79 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 15 Dec 79, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate

Liquid Capacity of Tank

Tank Construction

Absorption and/or Nitrification Lines

Total Line Length *

Number of Lines 4

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER Sedgwick

LOCATION OF PROPERTY 1320 Eastside Dr

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

* As per proposed plans filed Septic tank on file

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

Date Issued 15 Nov 79 Serial 3238 C of A (s) No. 12662

T C. No

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Sooeraquist (LAST) (FIRST) (MIDDLE)

Location of Property 13910 Creekside Dr

Application Number Permit Number 12662

Inspection Data:

Liquid Capacity of Tank — Tank Material Repair

Total Length of Drain Tile — Number of Lines 4

Depth of Filter Material 9' Cover Depth 3½'

Water Supply Source well Distance from Water Source 100'

Excavation Inspected — (DATE) Tank Inspected (DATE)

Nitrification Field Inspected 15 Nov (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been installed or constructed, ✓ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Design by Squires Company — repair tied into original bed — installed under direction of Squires Company in 10'x35'x12' bed.

Steve Wood
Environmentalist

EHD-5-76

Environmental Health Department's Copy