

C.D. MITCHELL LOT 4A

5/24/2007

duponbj

Groundwater and Wastewater Services File Imaging Project

May 2007

Barcode Font = IDAutomationHC39M

Mecklenburg County
Health Department

Basil G. Delta, M.D., M.P.H.
Health Director

August 25th, 1988

Moses Lee Heath, Jr.
200 South Tryon Street
Charlotte, NC 28202

RE: Property located at Blakeney Heath Road 4-A
FILE: 4832A
PARCEL: 22922212 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 11873) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Very truly yours,

Sylvia D. Daniel

Sylvia D. Daniel, R.S., Supervisor
On Premises Waste Disposal & Water Supply

Enclosure

8/3/88 Pd 30 - Ck# 2-169016 SK

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 4832A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: Access over Lt 1 of Part 1 of C.D. Mitchell property (just before 9001 Blakeney Heath Rd) Part 2

② SUBDIVISION: C.D. Mitchell Property ③ LOT: 4A ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: unrecorded plat but on tax parcel # 229-222-12 PAGE NO.: _____ PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: ~~4289~~ 4400 PAGE NO.: ~~930~~ 411

OWNER


⑦ NAME: Moses Lee Heath, Jr.
(FIRST) (MIDDLE) (LAST)

⑧ MAILING ADDRESS: c/o BB&T Trust Department, 200 South Tryon Street

⑨ CITY: Charlotte ⑩ STATE: NC ⑪ ZIP: 28202

⑫ PHONE: (WORK) 704/372-3180 (wife's #) (HOME) 704/552-1850 (answering machine)

⑬ Accurately diagram and dimension lot.



Lot has been staked (see tax map attached for specific location)

⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: M. Lee Heath, Jr.

Date: 25 Jul 88

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 11873

File: 4832 A Action 4

Parcel: PO 229-222-12 ☐ PC

Location: Blakeney Heath Road

Subdivision:


Lot: 4-A Block: Acres: 1.07

Owner: Moses Lee Heath, Jr.
Address: 200 South Tryon Street
Charlotte, N. C. 28202

Comments: _____

Described by: William A. Martin

Date: 8-24-88



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = *Provisionally Suitable*
The "Area Classification" below indicates the suitability of *areas in the diagram.*

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 6-15%	S PS (U) Terrace	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U 736" to water	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36"	S PS U —	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U 36"	S PS U —	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U —	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVA Cecil-Hillo	Terrace				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U