SEE INSTRUCTIONS ON BACK

Date Received 3/8/79

ICAR (S) Application No. 15194

T C. No. 053-164-10


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

1) Install or Construct 2) ✓ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge. Repair Washing Machine Field



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ___ Yes ___ No
Residence ✓ Yes ___ No
4) No. of Bedrooms 4
5) Business Use – Max No. Employees ___
6) Washing Machine ✓ Yes ___ No
7) Garbage Disposal ___ Yes ✓ No
8) Dishwasher ✓ Yes ___ No
9) Water Supply
A) Individual Well ✓
B) Governmental System ___
C) Community System
1 Well source ___
2 Governmental source ___
10) Sewage System
House located within 200 feet of public sewer ___ Yes ✓ No
House located within 200 feet of community sewer ___ Yes ✓ No
11) FHA Case No. ___
12) VA Case No. ___

13) NAME OF OWNER Burgin (LAST) Robert (FIRST) Charles (MIDDLE)

14) ADDRESS OF OWNER 1912 Leolillie Ln.

15) PHONE NO Home 392-5743 Office 373-3333

16) LOCATION OF SYSTEM 1912 Leolillie Ln. (STREET OR COUNTY ROAD)

17) SUBDIVISION Cuna-Roman Lot No. #16 Block No. ___

Map Book No. 12 Page No. 543

18) DEED REFERENCE — DEED BOOK ___ AT PAGE ___

19) HAS A SOIL INVESTIGATION BEEN RUN? ___ YES ___ NO DATE RUN ___

20) PTR NUMBER (See Instructions) ___

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

March 8, 1979
DATE OF APPLICATION

Robert Charles Burgin
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

7

Date Issued 3-8-79

Serial No. 2447


ICAR(S) Permit No. 15194

T C R33-104-10

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 15197, dated 2-8-79 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 4-8-79, after which date this permit shall be null and void.



Permeability Rate P/S

Liquid Capacity of Tank 1500 Existing

Tank Construction P/C

Absorption and or Nitrification Line:

Total Line Length 100'

Number of Lines 4

Distance from House 10'+

Distance from Property Line 10'+

Distance from Well 50'+

NAME OF OWNER Robert Charles Burgin

LOCATION OF PROPERTY 1912 Leolillia Ln.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

Comments

Division or Section Head

Environmentalist Marshall Edwards

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-5-76

Environmental Health Department's Copy

15194

Serial No. 2366

C of A (s) No. 25807

Date Issued 3-16-79

T C 033-104-10

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Burgin (LAST) Robt. (FIRST) Charles (MIDDLE)

Location of Property 1912 Leo Lillie Ln.

Application Number 15197 Permit Number 15197

Inspection Date:

Liquid Capacity of Tank 1500 - Existing Tank Material F/C

Total Length of Drain Tile 100' Number of Lines 4

Depth of Filter Material N. A. Cover Depth N/A

Water Supply Source Well Distance from Water Source 50'+

Excavation Inspected 3-16-79 (DATE) Tank Inspected N/A. (DATE)

Nitrification Field Inspected N/A (DATE)

Washing Machine Line Inspected, If Applicable N. A (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been ✓ installed or constructed, altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Did Not have to add ANY Field - FAULTY Distribution Box - Broken & Blocked Passage to Field — New Box installed - AND System O.K.

Marshall Edwards
Environmentalist

EHD-5-76

Environmental Health Department's Copy