Date Received 5/3/77 RECEIVED MAY 3 1977 MECKLENBURG COUNTY ENVIRONMENTAL HEALTH

ICAR (S) Application No 12387

T C No. 197-033-23


Map Date —

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH

**Application for an**
**Installation, Construction, Alteration, and/or Repair Permit**
**Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge**

The owner of the property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to

Install or Construct ____ X Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption effluent discharge



Water Supply: Yes ____ No ____

Public: Yes ____ No ____

4 Number of Bedrooms 4

5 Business Use Max. No. Employees NINE

6 Washing Machine ✓ Yes ____ No

7 Garbage Disposal ____ Yes ✓ No

8 Dishwasher ✓ Yes ____ No

9 Water Supply:

A Individual Supply ✓

B Community System ____

C Municipal System

Water Source ____

D Governmental Source ____

Sewage System

Is any water supply within 200 feet: Public ____ Yes ✓ No

House basement within 200 feet of community sewer: ____ Yes ✓ No

11 FHA Case No. ____

12 VA Case No. ____

3 PLOT PLAN (ACCURATELY DIMENSIONED)

13 NAME OF OWNER ALLEN (LAST) LAIRN (FIRST) ELBERT (MIDDLE)

14 ADDRESS OF OWNER 1224 ELLEN WOOD RD CHARLOTTE NC 28212

15 PHONE NO Home 545-4130 Office 566-7401

16 LOCATION OF SYSTEM 12219 BRIAR SCHOOL RD (STREET OR COUNTY ROAD)

17 SUBDIVISION ____ Lot No ____ Block No. ____

Map Book No ____ Page No. ____

18 DEED REFERENCE — DEED BOOK 3280 AT PAGE 119

19 HAS A SOIL INVESTIGATION BEEN RUN? YES ✓ NO DATE RUN ____

20 PTR NUMBER (See Instructions) ____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

DATE OF APPLICATION ____ OWNER Lairn E. Allen

EHD-5-76

**Environmental Health Department's Copy**

12389


Date Issued 5/12/77 Serial No. 0742 ICAR(S) Permit No. [redacted]

T. C. No. 197-033-23

Map Date

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
### (Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ___ Install or Construct, X Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application # 387 dated 5/12/77, and this permit shall be void and of no effect if the information provided in the application is not true or correct as used. All work shall be completed on or before 6/1/77 after which date this permit shall be null and void.




PLOT OF SYSTEM

Permeability Rate REPAIR

Liquid Capacity of Tank "

Tank Construction "

Absorption Field or Nitrification Line:

Trench Width 24" 18"

Trench Length 100' 70'

Number of Lines 2 2

Distance from House 10' min

Distance from Property Line 10' min

Distance from Well 60' ±

NAME OF OWNER WILLIAM GUILLEN

LOCATION OF PROPERTY Erin School Rd.

The installation is to be in accordance with the requirements as set forth in the Regulations of the Mecklenburg County Board of Commissioners governing sewage disposal and in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Department before any system can be covered up or otherwise rendered inaccessible for inspection or can be used. **The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.**

Reynolds

Division Section Head

L. P. Brieger
Environmentalist

If this permit is for the installation or construction of a new system, it must be signed by the division or section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

Environmental Health Department's Copy

Serial No. 0698

C of A (s) No. 12389

Date Issued 5/23/77

T C. No 197-033-23

# MECKLENBURG COUNTY
# DEPARTMENT OF ENVIRONMENTAL HEALTH
## ENVIRONMENTAL HEALTH DIVISION

### CERTIFICATE OF APPROVAL
**(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)**

Name of Owner QUILLEN (LAST) LAURIN (FIRST) ___ (MIDDLE)

Location of Property ELLIN School Rd

Application Number 12389 Permit Number 12389

**Inspection Date:**

Liquid Capacity of Tank RE Tank Material RE

Total Length of Drain Tile 100' 70' Number of Lines 2 2

Depth of Filter Material 12" Cover Depth 2'

Water Supply Source Drd WELL Distance from Water Source 60'+

Excavation Inspected 5/13/77 (DATE) Tank Inspected NEW LIDS (DATE)

Nitrification Field Inspected 5/23/77 (DATE)

Washing Machine Line Inspected If Applicable 5/23/77 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption effluent discharge as described above and it has been installed or constructed X altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permits in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

cont'd. N. Reynolds

Environmentalist

EHD-5-76

Environmental Health Department's Copy