C of A (s) No. 8481

Serial 3344

Date Issued 12-17-75

T C No 105-165-01

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Crosby James B.
(LAST, FIRST, MIDDLE)

Location of Property Goodrum and Oak Lane

Application Number 8481 Permit Number 8481

Inspection Data:

Liquid Capacity of Tank 1500 gal Tank Material P.C.

Total Length of Drain Tile 445'+125' Number of Lines 5'+4

Depth of Filter Material 12" Cover Depth 15"

Water Supply Source well Distance from Water Source 50'

Excavation Inspected 12-17-75 (DATE) Tank Inspected 12-17-75 (DATE)

Nitrification Field Inspected 12-17-75 (DATE)

Washing Machine Line Inspected If Applicable 12-17-75 (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption of effluent discharge as described above and it has been ~~installed~~ constructed altered or repaired in substance with the permit issued and the regulations of the Mecklenburg County Health Commission in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments

Bob Austin
Environmentalist

EHD-5-74

Environmental Health Department's Copy