Date Received 5-10-83

RECEIVED
MAY 10 1983
ENVIRONMENTAL HEALTH

SIR No. 19648
T. C. No 113-163-22
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Porter (LAST) Carrie (FIRST) Hyleen (MIDDLE)

2) ADDRESS OF OWNER 9527 Wallace Ferry Road (STREET OR COUNTY ROAD) Charlotte, N.C. ZIP 28208

3) PHONE NO. Home 399-2677 Office 394-6310


4) LOCATION OF PROPERTY 9527 Wallace Ferry Road, Charlotte, N.C.

5) SUBDIVISION English Estates LOT NO. 3 BLOCK NO. 1

MAP BOOK NO. _____ PAGE NO. _____

6) DEED REFERENCE. DEED BOOK 3819 PAGE NO. 939

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and on on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT

Hilda Spencer/ C. H. Porter
OWNER

EHD-5-76

Environmental Health Department's Copy

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19648

T.C. NO. 113-163-27

(Ground Absorption Sewage Disposal)

OWNER: Daniel H. Porter
ADDRESS: 9520 Walkers Ferry Rd
Charlotte, N.C. 28278

PLAT NO: Lot 3 B1
LOT SIZE: 15,000

LOCATION OF SITE: 9527 Walkers Ferry Road

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	(S) PS U 3-6%	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S (PS) Clay U	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S (PS) Blocky U	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S (PS) 36-48" U	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S (PS) saprolite 36"+ U	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	(S) >48" to ground water PS U	S PS U	S PS U	S PS U
7. OTHER (Specify)	S SEE PS NOTE! U	S PS U	S PS U	S PS U
8. SOIL GROUP	1UA			
9. SITE CLASSIFICATION	Provisionally Suitable			
10. SOIL SERIES	Cecil			

S - Suitable PS - Provisionally Suitable U - Unsuitable


**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments: Lot has an existing well and has only 15,000 sq. ft. of area

Described by: William A. Mullis
Title: Soil Scientist

Date: 5 20 83

EHD 539 (Revised: 6/82)



check well location on adjoining property prior to septic tank permit

J. H. Robinson

Date Received 5-10-83

MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
MAY 10 1983
ENVIRONMENTAL HEALTH

Application No. 19648

T. C. No. 113-163-22


Map Date _____

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

Application for an
Installation, Construction, Alteration, and/or Repair Permit
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

The owner of that property described hereinafter hereby applies to the Mecklenburg County Department of Environmental Health for a permit to:

1) ✓ Install or Construct 2) _____ Alter or Repair an individual septic tank wastewater treatment system with a subsurface, soil absorption, effluent discharge.



3) PLOT PLAN (ACCURATELY DIMENSIONED)

Mobile Home ____Yes ____No
Residence ✓ Yes ____No

4) No. of Bedrooms 3

5) Business Use — Max No Employees _____

6) Washing Machine ✓ Yes ____No

7) Garbage Disposal ✓ Yes ____No

8) Dishwasher ✓ Yes ____No

9) Water Supply
A) Individual Well ✓
B) Governmental System _____
C) Community System:
1 Well source _____
2 Governmental source _____

10) Sewage System
House located within 200 feet of public sewer ____Yes ✓ No
House located within 200 feet of community sewer ____Yes ✓ No

11) FHA Case No. _____

12) VA Case No. _____

13) NAME OF OWNER Potter (LAST) Carrie (FIRST) Hyatt (MIDDLE)

14) ADDRESS OF OWNER 9526 Caldwell Ferry Road

15) PHONE NO. Home 399-1677 Office 394-6310

16) LOCATION OF SYSTEM 9527 Caldwell Ferry Road. (STREET OR COUNTY ROAD)

17) SUBDIVISION Briarhill Acres Lot No. 3 Block No. 1

Map Book No. _____ Page No. _____

18) DEED REFERENCE — DEED BOOK 3819 AT PAGE 934

19) HAS A SOIL INVESTIGATION BEEN RUN? _____ YES _____ NO DATE RUN _____

20) PTR NUMBER (See Instructions) _____

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true.

5-11-83
DATE OF APPLICATION

Helen Spencer / O.H Potter
OWNER

EHD-5-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY

Serial No. 5028

SIR No. 19648

T. C. No. 113-163-22

Date Issued 5-23-83

Map Date


MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
SOIL INVESTIGATION REPORT

NAME OF OWNER Porter, (LAST) Daniel (FIRST) H. (MIDDLE)

ADDRESS OF OWNER 9520 Walkers Ferry Rd., Charlotte, NC ZIP 28208

LOCATION OF PROPERTY 9527 Walkers Ferry Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO. BLOCK NO.



PLOT PLAN

This is to certify that a soil investigation and on-site investigation was made by the Mecklenburg County Department of Environmental Health on the lot described above. The said investigation was conducted on that portion of the lot as indicated on the above plot. **Provisionally Suitable**
The permeability rate determined by the investigation was ___. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions.

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Department of Environmental Health prior to the beginning of any construction of buildings or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Mecklenburg County Department of Environmental Health prior to installation based on the permeability rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area indicated as acceptable for system installation on the above plot.
4. This approval is void if any grading, filling, or construction including the drilling of a well is performed on the lot which, in the opinion of the Mecklenburg County Department of Environmental Health, renders the area indicated as acceptable for system installation unsuitable for installation, construction, alteration, and or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina Department of Human Resources, Division of Health Services and the Mecklenburg County Health Commission which were in effect on the date of issuance and is void if at any time in the future, prior to completion of the system, these laws, rules and regulations are changed such that this approval would not have been granted had the new or revised laws, rules and regulations been in effect on the issue date.

William A. Martin
EHD-5-76 Soil Scientist

John D. Akerson
Environmental Health Director or Authorized Section Head

Environmental Health Department's Copy

BT-5-26-83

SIR No. 19648

Serial No. 6465

Date Issued 5-25-83

T. C. No. 113-163-22

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
IMPROVEMENT PERMIT
TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Porter, (LAST) Daniel (FIRST) H. (MIDDLE)

ADDRESS OF OWNER 9520 Walkers Ferry Rd., Charlotte, NC ZIP 28214

LOCATION OF LOT 9527 Walkers Ferry Road (STREET OR COUNTY ROAD)

SUBDIVISION Berryhill Park LOT NO 3 BLOCK NO. 1

MAP BOOK NO. PAGE NO.

The above specified lot is approved by the Mecklenburg County Department of Environmental Health for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge based on the soil investigation, on an on-site inspection of the said lot; and upon the information supplied in the "Application for an Installation, Construction, Alteration, and/or Repair Permit", number 19648. This approval is subject to the following terms and conditions:

1. That the nitrification field be installed, constructed, altered and/or repaired in the same area where the soil investigation was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and/or repaired and that the system be installed in accordance with same.

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit.

Randy C Poole RS
Environmentalist

John R Adkisson
Environmental Health Director, or Authorized Section Head

EHD-S-76

Environmental Health Department's Copy

Date Issued 9/21/83

Serial No. 6637


ICAR(S) Permit No. 19649 /

T. C. No. 113-163-22

Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT
(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct, ___ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 19649, dated 9/21/83 and this permit shall be void and of no effect if the information provided in the application is not true or is erroneous. All work shall be completed on or before 12/21/83, after which date this permit shall be null and void.



PLOT OF SYSTEM

Permeability Rate P5

Liquid Capacity of Tank 1500 gal

Tank Construction Pr concrete

Absorption and/or Nitrification Lines

Total Line Length 300'

Number of Lines 6 @ 50' ea

Distance from House 20'

Distance from Property Line 210'

Distance from Well 75'

NAME OF OWNER Peter Daniel Hipshock

LOCATION OF PROPERTY 3321 Wilkinson Blvd.

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Health Commission which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Environmental Health Director before any system can be covered up or otherwise rendered uninspectable or can be used. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.

(6) lines @ 50' long Stone 12" deep 24" wide

Comments: Pressure

Division or Section Head

Environmentalist Randy C Beck RS

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

EHD-S-76

ENVIRONMENTAL HEALTH DEPARTMENT'S COPY