MECKLENBURG COUNTY
Department of Environmental Health

FILE NO. 21691

DATE 4-30-85

David Reid
223 Comodore Drive
Savannah, GA 31410

Re: Property located at McKee Road, TC# 231-062-04

Dear Sir:

At your request a soils investigation was conducted on the property designated above. Results of this investigation, showed the site to be classified **unsuitable** for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

North Carolina General Statute 130A-335 and 10 NCAC 10A .1948 (c) provides that:

> Sites originally classified as **UNSUITABLE** may be used for soil absorption disposal systems, provided engineering, hydrogeologic, and soil studies indicate to the local health department that a suitable septic tank system or a suitable alternate system can reasonably be expected to function satisfactorily. Such sites may be reclassified as **PROVISIONALLY SUITABLE** upon submission to the local health department and when requested by the local health department to the state agency of the following:
>
> (1) Adequate substantiating data to indicate that a ground absorption system can be installed so that the effluent will receive adequate treatment;
>
> (2) Adequate substantiating data to indicate that the effluent will not contaminate any drinking water supply, ground water used for drinking water, or any surface water;
>
> (3) Adequate substantiating data to indicate that the effluent will not be exposed on the ground surface or be discharged to surface waters where it could come in contact with people, animals, or vectors.

Upon receipt of a request for reclassification as provided for above, the submission of plans and specifications for an applicable sewerage treatment system, and the approval of such system as submitted, the department will issue the appropriate permits.

If I may be of any assistance, please feel free to call.

Sincerely,

Bill D. Hardister, Jr.
Environmental Health Supervisor

Enclosure

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 21611

T.C. NO. 231-[illegible]

(Ground Absorption Sewage Disposal)

OWNER: [illegible]
ADDRESS: [illegible]
[illegible], Va. 31416
LOCATION OF SITE: [illegible]

PLAT NO: [illegible]
LOT SIZE: [illegible]

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S / PS 2-5% / U	S / PS 2-8% / U [illegible]	S / PS [illegible] / U slopes	S / PS / U —
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S / PS clay / U	S / PS 2-1 clay / U	S / PS — / U	S / PS — / U
3. SOIL STRUCTURE (12-36 inches)	S / PS Blocky / U	S / PS Blocky / U	S / PS / U	S / PS — / U
4. SOIL DEPTH (inches)	S / PS 24-36" / U	S / PS [illegible] / U	S / PS / U	S / PS — / U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S [illegible] to saprolite / PS / U	S [illegible] to saprolite / PS / U	S / PS / U	S / PS — / U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S [illegible] to ground water / PS / U	S [illegible] to ground water / PS / U	S / PS / U	S / PS Drainageway Depression / U
7. OTHER (Specify)	S / PS / U	S / PS / U	S / PS / U	S / PS / U
8. SOIL GROUP	[illegible]	[illegible]		—
9. SITE CLASSIFICATION	[illegible]	[illegible]	[illegible]	[illegible]
10. SOIL SERIES	[illegible]	[illegible]	[illegible]	[illegible]

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: [illegible]
Title: [illegible]

Date: [illegible]

2d

DEPARTMENT OF
ENVIRONMENTAL



THE BOUND PRESS, INC.—CHARLOTTE, N. C.

Bill - HELP! TC#

December 5, 1984

Date Received 12-7-84

MECK COUNTY DEPARTMENT OF
RECEIVED
DEC 7 1984
ENVIRONMENTAL HEALTH

144

PT No. 21691

T C. No. 231-062-04

Map Date L

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER REID (LAST) DAVID (FIRST) (MIDDLE)

2) ADDRESS OF OWNER 223 Comodore Drive, Savannah, Georgia ZIP 31410

3) PHONE NO. Home 912-897-5552 Office 912-234-1671

4) LOCATION OF PROPERTY McKee Road (STREET OR COUNTY ROAD)

5) SUBDIVISION East Providence Estates LOT NO 4 (FOUR) BLOCK NO. 1 (ONE)

MAP BOOK NO 9 (NINE) PAGE NO. 357

6) DEED REFERENCE: DEED BOOK _____ PAGE NO _____

NOTEPLEASE SEND A COPY OF THIS REPORT TO: ASSELL, HATTRIC, & ROSE REAL ESTATE, INC. 11500 E. Independence Boulevard, Matthews, North Carolina 28105

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge.



7) ACCURATELY DIAGRAM & DIMENSION LOT