

731 ELIZABETH LN

22743287

5/8/07

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3626-A DATE: 7-1-88

TC: 227-041-05 ☐ L ☐ CRT

SERIAL № 11295

Name of Owner Julius Watthall Juris.:

Address of Property 731 Elizabeth Ln

Inspection Data:

Tank Material PCC

Total Length of Drainfield 535

Number of Lines 6 @ 90'

Cover Depth 12"

Water Supply Source well


Distance to Water Source >50'

Excavation Inspected 7-1-88

Tank(s) Inspected 7-1-88

Wash Line Inspected —

High Water Alarm Inspected 7-1-88



Design: 1988, Repair CTR# 113

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☐ altered or repaired

☐ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☐ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of 10 NCAC 10A .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: System relocated at owners Request

Jim Emm
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 3626-A DATE: 6-14-88

TC: 227-041-05 ☐ L

SERIAL № 11979

Permission is hereby given to ____ Install or Construct, ____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 5-25-88. All work shall be completed on or before 7-14-88, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Department of Environmental Health before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank 1500 gallons

Liquid Capacity of Dosing Tank — gallons

Tank Construction: pcc

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 535 feet

Number of Lines Six

Depth of Stone 12 inches

Distance from House 5 feet

Distance from Property Line 10' feet

Distance from Well 250' feet

NAME OF OWNER Julius Walthall

LOCATION OF PROPERTY 731 Elizabeth In.

Comments: Six Trenches 90' X 3' X 12" Stone
Abandon old system, pump old tank, Fill with dirt

Division or Section Head

Jim Ericson
Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Department of Environmental Health in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER OR AGENTS COPY

MECKLENBURG COUNTY

Department of Environmental Health

June 1st, 1988

Julius Byron Walthall
731 Elizabeth Lane
Matthews, NC 28105

RE: Property located at Elizabeth Lane
FILE: 3626A
PARCEL: 22704105

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. The property was found to contain a limited area of soils which were classified as provisionally suitable for such an installation. A copy of the Site Evaluation Report (Serial Number 11745) is enclosed for your information.

Should you desire to file for permission to install a ground absorption sewage disposal system, please submit an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems to this office. The plan will be reviewed and if it is found that the area of provisionally suitable soils is adequate for the proposed construction, an Improvement Permit will be issued by this Department.

If I may be of assistance, please do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

Enclosure

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 11745

File: 3626A Action: /

Parcel: PO 227-041-05 ☐ PC

Location: 731 Elizabeth Lane

Subdivision:


Lot: Block: Acres: Approx .18 ac

Owner: Julius Byron Walthall
Address: 731 Elizabeth Lane
Matthews, N. C. 28105

Comments: Some areas may need surface diversion

Described by: William R. Maulsby

Date: 6-1-06



***** EVALUATION KEY *****

S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 6-15%	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U >36" to water	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 36" +	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVA Ext. 1-1;40					
Area Classification	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U

5/26/88 Paid $30.00 cash tw

APPLICATION FOR SOIL INVESTIGATION

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 3626A

TC: _____

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: 731 ELIZABETH LANE, MATTHEWS

② SUBDIVISION: NA ③ LOT: NA ④ BLOCK: NA

⑤ PARCEL REFERENCE: BOOK NO.: P0227 PAGE NO.: 041 PARCEL NO.: 05

⑥ DEED REFERENCE: BOOK NO.: 2724 PAGE NO.: 236

OWNER

AND WIFE DANNY S. WALTHALL

⑦ NAME: JULIUS (FIRST) BYRON (MIDDLE) WALTHALL (LAST)

⑧ MAILING ADDRESS: 731 ELIZABETH LANE

⑨ CITY: MATTHEWS ⑩ STATE: NC ⑪ ZIP: 28105

⑫ PHONE: (WORK) 704 847-6301 (HOME) 704 847-6301

⑬ Accurately diagram and dimension lot.

SEE ATTACHED

⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Julius B. Walthall
Danny S. Walthall

Date: May 26, 1988

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

Tested $50.00 Pd 6/6/88 $50.00 ck#592 EW

APPLICATION FOR AN IMPROVEMENT PERMIT

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)

FILE: 3626A

TC: _____

SERIAL: № 14484 ☐ L ☐ CRT

JOB LOCATION

① ADDRESS: 731 ELIZABETH LANE, MATTHEWS (STREET NO. / STREET) ② FILE: 3626A

③ JURISDICTION: MATT ④ TAX PARCEL NO.: PO 227-041-05

⑤ SUBDIVISION: NA ⑥ LOT: NA ⑦ BLOCK: NA

OWNER

⑧ NAME: JULIUS BYRON WALTHALL AND WIFE, DANNY S. (FIRST / MIDDLE / LAST)

⑨ MAILING ADDRESS: 731 ELIZABETH LANE

⑩ CITY: MATTHEWS ⑪ STATE: NC ⑫ ZIP: 28105

⑬ PHONE: (WORK) 704 847-6301 ⑭ (HOME) 704 847-6301

REQUEST

This request is for a(n):

⑮ ☐ New permit

⑯ ☒ Repair or alteration permit

⑰ ☐ Authorization for mobile home exchange

⑱ ☐ Other (specify) _____

DESIGN CRITERIA

System will serve:

⑲ ☒ Residence ⑳ ☐ Mobile home

㉑ ☐ Business or place of public assembly

㉒ Number of bedrooms? 4

㉓ Maximum occupancy? 8

㉔ Basement? ☐ yes ☒ no

㉕ Type? _____

㉖ Maximum number of employees? _____

㉗ Maximum number of seats? _____

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☒ Individual well

B ☐ Municipal system

C ☐ Community well

D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Danny S. Walthall / Julius B. Walthall

Date: 5-25-88

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

. . . No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

. . . This permit is not transferable, and shall become null and void 36 months from the date of issuance.

_____ / _____

Environmentalist Date

_____ / _____

Director or Authorized Section Head Date

*This permit must be signed by the Director of Environmental Health or an authorized section head in order to be valid.

SCALE: 1" = 20'

5-24-88

731 ELIZABETH LANE
MATTHEWS, NC

DATE: 5-25-88

TO: ENVIRONMENTAL HEALTH

FROM: COUNTY ENGINEERING

EHD FILE _____ JURISDICTION CODE MATT

PARCEL NUMBER 227-033-92

ASSIGNED ADDRESS 731 Elizabeth Ln

EXISTING ADDRESS _____

PROJECT NAME N/A

THE ABOVE DESCRIBED LOCATION HAS BEEN CHECKED CONCERNING:

	APPROVED	NOT APPROVED
1. SUBDIVISION REGULATIONS	☐	☐ *
2. FLOODWAY REGULATIONS	☐	☐ *
3. EROSION CONTROL REGULATIONS	☐	☐ *
4. COMMERCIAL DRAINAGE PLAN	☐	☐ *

	PRESENT	NOT PRESENT
5. PUBLIC UTILITY EASEMENT	☐ *	☐
6. PROPERTY FRONTS ON THOROUGHFARE	YES ☐ *	NO ☐
7. DRIVEWAY PERMIT REQUIRED	YES ☐ *	NO ☐

* If checked, further investigation will be required to determine whether a building permit may be issued by Building Standards for the site.

REMARKS: Septic tank

NOTE: THIS FORM MUST BE TURNED IN AT THE CASHIERS OFFICE AT BUILDING STANDARDS WHEN PAYING PERMIT FEES.
A CERTIFICATE OF OCCUPANCY WILL NOT BE GRANTED UNTIL THE TRANSPORTATION DIVISION GRANTS FINAL APPROVAL ON DRIVEWAY(S).

SIGNED: Rwl

OPWEAR 02/86

Form 100

MECKLENBURG COUNTY
Department of Environmental Health

July 15th, 1987

Julius Byron Walthall
731 Elizabeth Lane
Matthews, NC 28105

RE: Property located at Elizabeth Lane
FILE: 3626A
PARCEL: 22704105

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 14334) deliniating the soil types and there respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

1200 Blythe Boulevard • Charlotte, North Carolina 28203 • (704) 376-4603

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 14334

File: 3626A

Action 4

Parcel: 22704105

☐ PC

Location: Elizabeth Lane

Subdivision:


Lot: Block: Acres: .98

Owner: Julius Byron Walthall
Address: 731 Elizabeth Lane
Matthews, NC 28105

Comments: _____

Described by: W. B. Ramsey

Date: 7-14-87



***** EVALUATION KEY *****

S = *Suitable* U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of *areas in the diagram.*

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	S (PS) U 2-6	S PS U	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U 45-48	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IIa Cecil					
Area Classification	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U

APPLICATION FOR SOIL INVESTIGATION

MECKLENBURG COUNTY · ENVIRONMENTAL HEALTH ·

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 3626A

TC: 227-041-05

☐ PC ☐ REPT

JOB LOCATION

① ADDRESS: ELIZABETH LANE, MATTHEWS (BETWEEN #629 AND #731)

② SUBDIVISION: NA ③ LOT: NA ④ BLOCK: NA 227-041-05

⑤ PARCEL REFERENCE: BOOK NO.: PO 227 PAGE NO.: 041 PARCEL NO.: 05

⑥ DEED REFERENCE: BOOK NO.: 2724 ~~236~~ PAGE NO.: 236

OWNER


⑦ NAME: JULIUS BYRON WALTHALL (FIRST) AND WIFE, DANNY S. (MIDDLE) (LAST)

⑧ MAILING ADDRESS: 731 ELIZABETH LANE

⑨ CITY: MATTHEWS ⑩ STATE: NC ⑪ ZIP: 28105

⑫ PHONE: (WORK) 704 847-6301 (HOME) 704 847-6301

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Julius B. Walthall, Danny S. Walthall

Date: June 28, 1987

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY