

3501 JOSEPH DR

13520412

5/10/2007

duponbj

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

APPLICATION FOR SOIL INVESTIGATION

MECK COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH
RECEIVED
1987

1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

(OFFICE USE ONLY)

FILE: 3787A

TC: 135-204-12

☐ PC ☐ REPT

MECK COUNTY DEPARTMENT OF
RECEIVED
JUN 22 1987
ENVIRONMENTAL HEALTH

3501

JOB LOCATION

① ADDRESS: ~~Now~~ 2 Lot from ~~3517~~ Joseph Dr ~~Map book 7~~

② SUBDIVISION: Elberta Downs ③ LOT: 5 ④ BLOCK: _____

⑤ PARCEL REFERENCE: BOOK NO.: 135-204-12 PAGE NO.: 849 PARCEL NO.: _____

⑥ DEED REFERENCE: BOOK NO.: _____ PAGE NO.: _____

OWNER


⑦ NAME: Jim Burch (FIRST) none (MIDDLE) BURCH (LAST)

⑧ MAILING ADDRESS: 3517 Joseph Dr

⑨ CITY: Matthews ⑩ STATE: NC ⑪ ZIP: 28105

⑫ PHONE: (WORK) ~~5~~ 568 5134 (HOME) 545 6271

⑬ Accurately diagram and dimension lot.



⑭ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY DEPARTMENT OF ENVIRONMENTAL HEALTH to enter onto the property for the purpose of processing this request.

Signed: Jim Burch

Date: 6-18-87

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

WHITE - ENVIRONMENTAL HEALTH DEPARTMENT'S COPY ● CANARY - ENVIRONMENTALIST'S COPY ● PINK - OWNER'S COPY

MECKLENBURG COUNTY ENVIRONMENTAL HEALTH
SITE EVALUATION REPORT
SERIAL NUMBER 14498

File: 3787A
Parcel: 13520412 PO
Action 4
☐ PC


Location: Joseph Drive
Subdivision:

Lot: Block: Acres: .55

Owner:
Address: Jim Burch
3517 Joseph Drive
Matthews, NC 28105

Comments: _____

Described by: William A. Mashi
Date: 8-17-17



***** EVALUATION KEY *****
S = Suitable U = Unsuitable
PS = Provisionally Suitable
The "Area Classification" below indicates the suitability of areas in the diagram.

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4	AREA 5	AREA 6
Topography	(S) PS U 2-4%	S PS (U) slight Depression	S PS U	S PS U	S PS U	S PS U
Texture	S (PS) U Clay	S PS U —	S PS U	S PS U	S PS U	S PS U
Structure	S (PS) U Blocky	S PS U —	S PS U	S PS U	S PS U	S PS U
Drainage	S (PS) U >36" To Water	S PS U —	S PS U	S PS U	S PS U	S PS U
Depth	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U	S PS U
Restrictive Horizons	S (PS) U >36"	S PS U	S PS U	S PS U	S PS U	S PS U
Available Space	S (PS) U	S PS U	S PS U	S PS U	S PS U	S PS U
Other (specify)	S PS U	S PS U	S PS U	S PS U	S PS U	S PS U
Soil Group/Series	IVA Cec:H,Hu	Slight Depression				
Area Classification	S (PS) U	S PS (U)	S PS U	S PS U	S PS U	S PS U

MECKLENBURG COUNTY

Department of Environmental Health

August 17th, 1987

Jim Burch
3517 Joseph Drive
Matthews, NC 28105

RE: Property located at Joseph Drive
FILE: 3787A
PARCEL: 13520412 PO

Dear Sir:

At your request, a field investigation was conducted on the property designated above for the purpose of determining site suitability for the installation of a ground absorption sewage disposal system. Results of the investigation revealed that the lot contains soils which have been classified as PROVISIONALLY SUITABLE in accordance with the provisions of 10 NCAC 10A .1900. A copy of the Site Evaluation Report (Serial Number 14498) deliniating the soil types and their respective classifications is enclosed.

While this classification indicates the site is acceptable for the installation of a septic tank system, no specific system or plans have been approved. The area available for such an installation may impose limitations on the size and/or type construction permitted on the lot. Specific plan approval will be provided upon submission of an Application For An Improvement Permit with an ACCURATELY dimensioned plot plan detailing the location of current and/or proposed buildings, wells and sewage disposal systems and determination that the area is adequate to accomodate the proposed construction.

Please note that this classification may be revoked if any filling, grading or construction (including the drilling of a well) is performed on the lot which in the opinion of this Department renders any area previously designated suitable for system installation, unsuitable. Futhermore, this approval may be revoked should any changes occur in the regulations under which it was granted, if such changes would have prevented its approval had they been in effect on the date of issuance.

If there are any questions concerning this matter, do not hesitate to contact me.

Sincerely,

Sylvia D. Daniel, R.S.
Environmental Health Supervisor
Environmental Resources Division

enclosure