Date Received 1-19-23

APT No 5445

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Clockford (LAST) Richard (FIRST) H-JR (MIDDLE)

2) ADDRESS OF OWNER 9020 Mottoway Dr Charlotte ZIP 28213

3) PHONE NO Home 5969337 Office 3322286


4) LOCATION OF PROPERTY Knollwood C.T.E (STREET OR COUNTY ROAD)

5) SUBDIVISION Shady Hills LOT NO 18 BLOCK NO 31

MAP BOOK NO 47 PAGE NO 803

6) DEED REFERENCE DEED BOOK 2134 PAGE NO 27

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

Richard H. Clockford
OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

MECKLENBURG COUNTY
Department of Public Health
1200 Blythe Boulevard
Charlotte, North Carolina 28203 Telephone 374-2113

Date Issued
1. February 22, 1973 SITE DISAPPROVAL REPORT SDR No. 5445
2. _____ INDIVIDUAL SEPTIC TANK SYSTEM WITH SUBSURFACE, T.C. No. _____
3. _____ SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Crockford, Richard H., Jr.

ADDRESS OF OWNER 9020 Nottoway Drive ZIP 28213

LOCATION OF LOT Knollwood Court, Lot 18-1

The lot described above has been disapproved for the installation of an individual septic tank system with subsurface, soil absorption, effluent discharge due to the following:

FAILURE TO PASS PERCOLATION TEST (60 minutes per inch or less)

	Test No.	Date of Test	Percolation Rate
X	1.	2-22-73	115 min/in
X	2.	2-23-73	95 min/in
____	3.	_____	_____ min/in

____ ON SITE INSPECTION REVEALED LOT TO BE UNSUITABLE FOR THE FOLLOWING REASON(S) _____

Environmentalist

(Stencil No.)
EHD 398
8/70

FORM NO.
E-19-8-14-70