Date Received 2-21-72

APT No. 5636

T C No.

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Judy (LAST) Joe (FIRST) Clarence (MIDDLE)

2) ADDRESS OF OWNER 431 Hunts Moor Dr. ZIP 28210

3) PHONE NO. Home 525-6985 Office


4) LOCATION OF PROPERTY Amen Lane (STREET OR COUNTY ROAD)

5) SUBDIVISION Ravenwood LOT NO 5 BLOCK NO 1

MAP BOOK NO 12 PAGE NO 29

6) DEED REFERENCE DEED BOOK 3357 PAGE NO 27

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

OWNER Joe Clarence Judy

FORM NO. E-1-11-1-70

HEALTH DEPARTMENT'S COPY

Serial No. [illegible]3

PTR No. 5636

T C No. [illegible] 203-052-29

Date Issued April 20, 1973

Map Date 2/14/73

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Judy (LAST) Joe (FIRST) Clarence (MIDDLE)

ADDRESS OF OWNER 421 Huntsmoor Drive ZIP 28210

LOCATION OF PROPERTY Amon Lane (STREET OR COUNTY ROAD)

SUBDIVISION Ravenwood LOT NO 5 BLOCK NO 1



PLOT PLAN

This is to certify that a percolation test has been run and an on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 60 min/in. The said lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter, or repair the specific system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings, or of the wastewater treatment system on the said lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which, in the opinion of the Health Department, renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future, prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John T. Robinson

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-4-1-71

HEALTH DEPARTMENT'S COPY

SEE INSTRUCTIONS ON BACK

Date Received [illegible]

ICAR'S Application No 5636

T C No 205-052-411

Map Date 2/14/73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an
Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner or their duly authorized hereinafter hereby applies to the Mecklenburg County Health Department for a permit to:

1 ✓ Install or Construct 2 Alter or Repair an individual septic tank wastewater treatment system with subsurface soil absorption, effluent discharge



3 PLOT PLAN ACCURATELY DIMENSIONED

4 No. of Baths 3

5 Bedrooms No. Employees

6 Washing Machine ✓ No

7 Garbage Disposal ✓ No

8 Dishwasher ✓ No

9 Water Supply

A Public or Community

B Government

C Swimming Pool

Well

D Spring

E Cistern

F Other

10 Public Sewer ✓ No

11 Water Softener ✓ No

12 EHA Loan No.

A Contractor GRICA HOMES, INC

13) NAME OF OWNER Jerry Joel Chandler Jr & Stricklind Ruth J
LAST FIRST MIDDLE

14) ADDRESS OF OWNER 1121 Hollowtree Dr Charlotte N.C.

15) PHONE NO Home 525-6985 Office

16) LOCATION OF SYSTEM Hicks Lane
STREET OR COUNTY ROAD

17) SUBDIVISION Hollywood Lot No 5 Block No 1

Map Book No 12 Page No. 29

18) DEED REFERENCE — DEED BOOK 3936 AT PAGE 447

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES ___ NO DATE RUN 4/8/73 #R3360

20) PTR NUMBER See Instructions: [redacted] 5636

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for hereon shall be void and of no effect if any of the above facts are not true.

4/25/73
DATE OF APPLICATION

OWNER Jerry C. Chandler

FORM NO E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued May 1, 1973

Serial No. 2926

LA No. 5636

T C No 205-052-24

Map Date 2-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Judy (LAST) Joe (FIRST) C. (MIDDLE)

ADDRESS OF OWNER 421 Huntsmoor Drive ZIP

LOCATION OF LOT Amon Lane (STREET OR COUNTY ROAD)

SUBDIVISION Ravenwood LOT NO 5 BLOCK NO 1

MAP BOOK NO 12 PAGE NO 29

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface soil absorption, effluent discharge based on the percolation test results which yielded a percolation rate of 60 min/in on an on-site inspection of the said lot, and upon the information supplied in the "Application for an Installation Construction Alteration, and/or Repair Permit" number 5636. This approval is subject to the following terms and conditions

1. That the nitrification field be installed constructed altered, and or repaired in the same area where the percolation test was run
2. That an "Installation, Construction Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altered, and or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit(s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic-tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction Alteration, and/or Repair Permit

Environmentalist

Director Environmental Health Division or Authorized Section Head

FORM NO E-3-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 7/1/73

Serial No. 4043

ICAR(S) Permit No. SE-36

T C No

Map Date


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTRUCTION, ALTERATION, AND OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to X Install or Construct ___ Alter or Repair the individual septic tank waste-water treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application SE-36 dated 7/2/73 and this permit shall be void or of no effect if the information provided in the application is found to be erroneous. All work shall be completed on or before 5/15/73 after which date this permit shall be null and void



PLOT OF SYSTEM

Percolation Rate 60

Liquid Capacity of Tank 1000

Tank Construction PC

Absorption Area or Nitrification Lines

Total Line Length 300

Number of Lines 5

Distance from House 10'

Distance from Property Line 10'

Distance from Well 100'

NAME OF OWNER [illegible] STUDY

LOCATION OF PROPERTY ARGYLE LN

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments: D. W. Hill-Webb

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Environmental Health Division in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

FORM NO E 5-4-1-71

HEALTH DEPARTMENT'S COPY

Date Issued 8/22/73 Serial 3775

C of A (s) No. 5636

T C No ____

Map Date ____

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner JUDY (LAST) JOE (FIRST) C. (MIDDLE)

Location of Property AMON LN. 2nd ON S. SIDE

Application Number 5636 Permit Number 5636

Inspection Data:

Liquid Capacity of Tank 1000 Tank Material PC

Total Length of Drain Tile 300 Number of Lines 5

Depth of Filter Material 17" Cover Depth 24"

Water Supply Source CITY Distance from Water Source —

Excavation Inspected 8/22/73 (DATE) Tank Inspected 8/22/73 (DATE)

Nitrification Field Inspected 8/22/73 (DATE)

Washing Machine Line Inspected, If Applicable — (DATE)

The undersigned has inspected the Individual Septic Tank System with subsurface, soil absorption, effluent discharge as described above and it has been X installed or constructed, ____ altered or repaired in accordance with the permit issued and the regulations of the Mecklenburg County Board of Health in effect on the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This Certificate of Approval is issued subject to those restrictions and conditions shown on the permit(s) in addition to those listed below under comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments: Certificate held up because plumbing was too low.

Environmental Specialist

FORM NO. E-6-4-1-71

HEALTH DEPARTMENT'S COPY