Date Received 4-29-83

RECEIVED
APR 29 1983
ENVIRONMENTAL HEALTH

APT No. 19623
T. & No. 013-062-05
Map Date

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

APPLICATION FOR SOIL INVESTIGATION

1) NAME OF OWNER Lawing (LAST) Louise (FIRST) (MIDDLE)

2) ADDRESS OF OWNER Rt 9 Box 15-E ZIP 28208

3) PHONE NO. Home 399-6511 Office 377-2000


4) LOCATION OF PROPERTY Jim Kidd Road (STREET OR COUNTY ROAD)

5) SUBDIVISION _____ LOT NO 3 BLOCK NO. _____

MAP BOOK NO _____ PAGE NO _____

6) DEED REFERENCE DEED BOOK 013 PAGE NO 062

Application is hereby made to the Mecklenburg County Department of Environmental Health for the conduct of a soil investigation and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



I ACCURATELY DIAGRAM & DIMENSION LOT

Louise Lawing
OWNER

END-5-76

Environmental Health Department's Copy

MECKLENBURG COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH

SIF. NO. 19623
T. C. NO. PO 013-062-05
DATE: 5-12-83

Mrs. Louise Lawing
Route 9, Box 158
Charlotte, NC 28208

Re: Property located at Jim Kidd Road, Lot 3

Dear Mrs. Lawing:

At your request, a field investigation was conducted on the property designated above and was classified unsuitable for the installation of a ground absorption sewage disposal system. A copy of the site evaluation report is enclosed for your information.

Sites classified as unsuitable may be utilized for soil absorption sewage systems provided engineering, hydrogeologic, soil and environmental studies indicate that a suitable septic tank system or a suitable alternate system can reasonably expected to function satisfactorily.

If you elect to file for permission to install an alternate system, please submit your proposals, in the form of plans and specifications, to this office. They will be reviewed and if it is found that the system may be reasonably expected to function satisfactorily, approval will be given upon the completion by you of a "Septic Tank Agreement Form" provided by this office.

If I may be of assistance, please feel free to call at any time.

Sincerely,

Mike Sexton

Michael A. Sexton
Environmentalist
On Premises Waste Disposal Section

Enclosure

EHD #37 (11-82)

DEPARTMENT OF
ENVIRONMENTAL HEALTH
MECKLENBURG COUNTY,
NORTH CAROLINA

SITE EVALUATION

S.I.R. NO. 19623

T.C. NO. P.O. 013-062-05

(Ground Absorption Sewage Disposal)

OWNER: Louise Lowing
ADDRESS: R-9 Box 165 1

PLAT NO:
LOT SIZE: 30,000+* .69

LOCATION OF SITE: Jim Kidd Rd

* Back Line not Designated

FACTORS	AREA 1	AREA 2	AREA 3	AREA 4
1. SLOPE (%)	S (PS) 2-4 U	S PS U	S PS U	S PS U
2. SOIL TEXTURE (12-36 inches) Sandy, Loamy, Clayey (Note 2-1 Clay)	S PS (U) 2-1 clay mixed	S PS U	S PS U	S PS U
3. SOIL STRUCTURE (12-36 inches)	S PS (U) weak Blocky	S PS U	S PS U	S PS U
4. SOIL DEPTH (inches)	S PS (U) 15-20"	S PS U	S PS U	S PS U
5. RESTRICTIVE HORIZONS (Inches) (Impervious strata, Rock)	S PS (U) clay saprolite	S PS U	S PS U	S PS U
6. SOIL DRAINAGE/GROUNDWATER (external and internal)	S PS (U) very slow	S PS U	S PS U	S PS U
7. OTHER (Specify)	S PS U	S PS U	S PS U	S PS U

8. SOIL GROUP — IIb

9. SITE CLASSIFICATION — Unsuitable

10. SOIL SERIES — ENON

S - Suitable PS - Provisionally Suitable U - Unsuitable

**See Diagram on Back (includes: soil areas, property lines, roads, streams, gullies, wet areas, fill areas, wells, water bodies, slopes)

Recommendations/Comments:

Described by: W. B. Kennedy
Title: Sanitarian

Date: 5-10-83

EHD 539 (Revised: 6/82)

2

360
ENON
2-4
115'