Date Received 26 Apr '74

Application No. 7484

T. C. No. 195-050-09

Map Date _____

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR WELL WATER SUPPLY PERMIT

NAME OF OWNER Huntley Bros., Inc.
(LAST, FIRST, MIDDLE)

ADDRESS OF OWNER Rt 1, Box 930 - D, Charlotte, NC ZIP 28212

PHONE NO. Home 545-5109 Office _____

LOCATION OF PROPERTY 16350 Thompson Road
(STREET OR COUNTY ROAD)


SUBDIVISION _____ LOT NO. _____ BLOCK NO. _____

MAP BOOK NO. _____ PAGE NO. _____

DEED REFERENCE: DEED BOOK _____ PAGE NO. _____

WELL CONTRACTOR Mills LICENSE NO. 346

Application is hereby made to the Mecklenburg County Health Department for a permit to drill a water well on the hereinabove described lot to be used as a source of ✓ individual, _____ semi public, or _____ public water supply.



ACCURATELY DIAGRAM & DIMENSION LOT

4-26-74
DATE OF APPLICATION

OWNER Huntley Bros Inc. by Charles C. Huntley

Application approved and permit hereby granted

Permit No: 7484

ENVIRONMENTALIST Jerry Burleson

FORM NO. E-20-8-1-72

HEALTH DEPARTMENT'S COPY

Date Received 2-13-74

APT No 7484

T C No

Map Date

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

APPLICATION FOR PERCOLATION TEST

1) NAME OF OWNER Huntley (LAST) Carter (FIRST) L (MIDDLE)

2) ADDRESS OF OWNER McConnells, York, S. C. ZIP 29745

3) PHONE NO Home ____ Office 628-6112


4) LOCATION OF PROPERTY Thompson Road (STREET OR COUNTY ROAD)

5) SUBDIVISION ____ LOT NO ____ BLOCK NO ____

MAP BOOK NO ____ PAGE NO ____ Map recorded Book

6) DEED REFERENCE DEED BOOK 1951 PAGE NO 31 page 34

Application is hereby made to the Mecklenburg County Health Department for the conduct of a percolation test and an on site inspection of the lot hereinabove described for the purpose of determining if the lot is suitable for the installation of an individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge



7) ACCURATELY DIAGRAM & DIMENSION LOT

---------- Proposed Lot Line

Huntley L Carter
OWNER

FORM NO E-1-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No. 4033

PTR No 7484

T C No 195-151-09

Date Issued February 18, 1974

Map Date 12-14-73

Do Not Issue A Building Permit Based On This Form

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION


PERCOLATION TEST REPORT

NAME OF OWNER Huntley (LAST) Baxter (FIRST) D. (MIDDLE)

ADDRESS OF OWNER P.O. Box 419, York, S. C. ZIP 29745

LOCATION OF PROPERTY Thompson Road (STREET OR COUNTY ROAD)

SUBDIVISION LOT NO BLOCK NO



PLOT PLAN

This is to certify that a percolation test has been run and on-site inspection made by the Mecklenburg County Health Department on the lot described above. The said test was conducted on that portion of the lot as indicated on above plot.

The percolation rate determined by the test was 50 min/in. The subject lot is approved for the installation of an individual septic tank wastewater treatment system with subsurface, total absorption effluent discharge subject to the following terms and conditions:

1. A permit to install, construct, alter or repair the specified system shall be obtained from the Mecklenburg County Health Department prior to the beginning of any construction of buildings on the lot or of the wastewater treatment system on the lot.
2. The size of the septic tank wastewater treatment system which must be installed will be determined by the Health Department prior to installation based on the percolation rate obtained above, and on the size and type of building constructed thereon.
3. This approval is valid only if the system is installed in the immediate area where the percolation test was run.
4. This approval is void if any grading, filling, or construction (including the drilling of a well) is performed on the lot which in the opinion of the Health Department renders the area where the percolation test was run unsuitable for the installation, construction, alteration, and/or repair of such a system.

This approval is granted based on the laws of the State of North Carolina and the rules and regulations of the North Carolina State Board of Health and the Mecklenburg County Board of Health which were in effect on the date of issuance and is void if at any time in the future prior to the completion of the system, these laws, rules, and regulations are changed such that this approval would not have been granted had the new or revised laws, rules, and regulations been in effect on the issue date.

John P. Atkisson

Director, Environmental Health Division or Authorized Section Head

FORM NO. E-2-S-1-72

HEALTH DEPARTMENT'S COPY

R

SEE INSTRUCTIONS ON BACK

MECK COUNTY HEALTH DEPT. RECEIVED 1974 ENVIRONMENTAL HEALTH DIVISION

Date Received 4-3-74 ICARUS Application No 7484

T C No 195-151-09

Map Date 12-11-73


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

Application for an Installation, Construction, Alteration, and/or Repair Permit
Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge

The owner of that property described hereinafter hereby applies to the Mecklenburg County Health Department for a permit to

1 [x] Install or Construct 2 [ ] Alter or Repair an individual septic tank wastewater treatment system with a subsurface soil absorption, effluent discharge



3) PLOT PLAN (ACCURATELY DIMENSIONED)

4 No of bdrms 3

5 Public or Community Water Supply Available

Employer

6 Working Water [x] Yes [ ] No

7 Garbage Disposal [ ] Yes [x] No

8 Dishwasher [x] Yes [ ] No

9 Water Softener

A Automatic Type [x]

B Garbage Disposal

C Separate Laundry Waste

D Sump Pump

E Footing Drain

F Roof Drain

G Basement

H Other Water Using Fixture

I Swimming Pool [ ] Yes [x] No

J Water Under Pressure

K Commercial Use Yes [x] No

11 EHA Case No

12 VA Case No

13) NAME OF OWNER Huntley Bros., Inc. (LAST, FIRST, MIDDLE)

14) ADDRESS OF OWNER Rt. 1 Box 430-D Charlotte, N. C. 28212

15) PHONE NO Home Office 545-5109

16) LOCATION OF SYSTEM Thompson Road (STREET OR COUNTY ROAD)

17) SUBDIVISION Lot No Block No

Map Book No Page No

18) DEED REFERENCE — DEED BOOK 3661 AT PAGE 0428 PR 50

19) HAS A PERCOLATION TEST BEEN RUN? ✓ YES NO DATE RUN 2-15-74

20) PTR NUMBER (See Instructions) 7484

The undersigned person hereby agrees that he has read the foregoing application and that the contents of same are true. It is understood that any permit applied for herein shall be void and of no effect if any of the above facts are not true

April 1, 1974
DATE OF APPLICATION

OWNER Huntley Bros. Inc. By Clarice C. Huntley Sec. Pres

REV 7-1 E-4-9-1-72

HEALTH DEPARTMENT'S COPY

Date Issued April 3, 1974

Serial No. 3954

LA No 7484

T C No 195-151-09

IMPROVEMENTS PERMIT

Map Date 12-14-73

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

TO THE BUILDING INSPECTION DEPARTMENT

APPROVAL OF LOT FOR INSTALLATION OF AN INDIVIDUAL SEPTIC TANK WITH SUBSURFACE, SOIL ABSORPTION, EFFLUENT DISCHARGE

NAME OF OWNER Huntley Bros., Inc.
(LAST / FIRST / MIDDLE)

ADDRESS OF OWNER Route 1, Box 430-D ZIP 28212

LOCATION OF LOT Thompson Road
(STREET OR COUNTY ROAD)

SUBDIVISION _____ LOT NO _____ BLOCK NO _____

MAP BOOK NO _____ PAGE NO _____

The above specified lot is approved by the Mecklenburg County Health Department for the installation of an individual septic tank system with subsurface, soil absorption effluent discharge based on the percolation test results which yielded a percolation rate of 50 min/in on an on site inspection of the said lot, and upon the information supplied in the "Application for an Installation Construction, Alteration, and/or Repair Permit", number 7484. This approval is subject to the following terms and conditions

1. That the nitrification field be installed, constructed, altered, and/or repaired in the same area where the percolation test was run.
2. That an "Installation, Construction, Alteration, and/or Repair Permit" be issued and in full force and effect when the system is installed, constructed, altred, and/or repaired and that the system be installed in accordance with same

This approval may be revoked and the building inspection department requested to revoke any building permit (s) which have been issued to authorize construction on the said lot if at any time it is determined that any information contained in the "Application for an Installation, Construction, Alteration, and/or Repair Permit" is not correct or is untrue or that the septic tank system is not being installed, constructed, altered and/or repaired in accordance with a valid Installation, Construction, Alteration, and/or Repair Permit

R. M Reynolds
Environmentalist

John R Robinson
Director Environmental Health Division or Authorized Section Head

FORM NO E-3-9-1-72

HEALTH DEPARTMENT'S COPY

Serial No.

Date Issued 4 Jan 74

ICAR(S) Permit No 7484

T C No 195-151-09

Map Date 4 May 74


MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

INSTALLATION, CONSTUCTION, ALTERATION, AND/OR REPAIR PERMIT

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Permission is hereby given to ✓ Install or Construct Alter or Repair the individual septic tank wastewater treatment system with subsurface soil absorption effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in application 7484 dated and the permit shall be void and of no effect if the actual conditions do not conform to the application. All work shall be completed on or before 4 Jul 74 after which date this permit shall be null and void.



FRONT OF LOT

FRONT OF SYSTEM

Percolation Rate 50

Legal Capacity of Tank 1500

Tank Construction PC

Absorption and/or Notification Lines

Total Line Length 600' + 135' + 135' + 135'

Trench Dimensions 5 (125' x 120' x 11")

Distance from Street 10'

Distance from Property Line 15'

Distance from Well 100'

NAME OF OWNER Whitley Brothers

LOCATION OF PROPERTY 1635 Thompson Road

The system shall meet all of the construction requirements as set forth in the Regulations of the Mecklenburg County Board of Health which are in effect on the date of the granting of this permit. A certificate of approval must be issued by the Health Director before any system can be covered up or otherwise rendered uninspectable or can be used.

Comments Lloyd Honeycutt (Contr.)

Director of Environmental Health

M. L. Kirby
Environmentalist

In the case of the installation or construction of a new system it must be signed by the division or a district environmental Health Director in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

E-5-9-1-72

Serial No. 1

C of A (s) No 7484

Date Issued 5 Jun 74

P/O T C No 195-151-09

Map Date 4 May 74

CERTIFICATE OF COMPLETION

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

CERTIFICATE OF APPROVAL

(Individual Septic Tank System with Subsurface, Soil Absorption, Effluent Discharge)

Name of Owner Huntley Brothers Const. Co. (LAST, FIRST, MIDDLE)

Location of Property 16350 Thompson Road

Application Number 7454 Permit Number 7454

Inspection Data:

Liquid Capacity of Tank 1500 Tank Material PC

Total Length of Drain Tile 600' + 150' WM Number of Lines 3 (7½' x 50' x 17") 5 (12½' x 120' x 12")

Depth of Filter Material 17" Cover Depth 18"

Water Supply Source Ind Well Distance from Water Source 100'

Excavation Inspected 5 Jun 74 (DATE) Tank Inspected 5 Jun 74 (DATE)

Nitrification Field Inspected 5 Jun 74 (DATE)

Washing Machine Line Inspected If Applicable 5 Jun 74 (DATE)

The above described property for the Individual Septic Tank System with subsurface soil absorption effluent disposal field has been ✓ inspected / interpreted and it has been determined that the system is in accordance with the permit issued and the requirements of the Mecklenburg County Board of Health regulations governing the date of issuance of the permit. The issuance of this Certificate of Approval does not in any way guarantee that the system will operate properly or relieve any person or property owner from any liability arising from the failure of the system to operate properly. This Certificate of Approval is issued subject to these restrictions and conditions with respect to the permit in addition to those listed below under Comments. This Certificate of Approval shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Comments Floyd Honeycutt (Contr.)

M. L. Kirby
Environmentalist

FORM NO E-6-9-1-72

T. C. No. 195-151-13

MECKLENBURG COUNTY HEALTH DEPARTMENT

ENVIRONMENTAL HEALTH DIVISION

WELL RECORD

Drilling Contractor D. L. Mullis Reg No 346 Well Permit No 74485

1. Town Mint Hill County Meck
2. Location 16400 Thompson Rd Quadrangle No.
   Show a sketch of location on back of form
3. Owner Huntley Bros Inc.
   Address Rt 1, Box 430-D
4. Topography: draw, slope, hilltop, valley, flat
5. Use of Well Indiv Date Completed 5-1-74
6. Rig type or method CORE Total Depth 75
7. Casing: Depth Diam. Type
   From 0 to 50 ft. 2 in. H 120
8. Grout: Depth Material Method
   From 0 to 20 ft. 2 in. Cement
9. Screen: Depth Diam. Type and Opening
   From to ft. in.
10. Water Zones (depth) 60-75
11. Static Water Level: 20 ft. above (below) top of casing
    which is 1 ft. above land surface. Elev.
    Date 5-1-74
12. Yield (gpm) 5 Method of testing Jet Pump
13. Pumping Water Level: 20 ft. after 5 hrs.
    at 5 gpm.
14. Water Quality Good Temperature (°F)
15. Well sterilization method H.T.H.
16. Permanent Pump: ✓ Type Myers Make 40-52
    Installed — Date 5-2-74 By D. L. Mullis
    Capacity 8 (gpm) Hp 1/2
    Intake depth 42 Airline depth 42'
17. Remarks:

I do hereby certify that this well record is true and exact.

D. L. Mullis
SIGNATURE OF CONTRACTOR OR AGENT

5-2-74

DRILLING LOG

From	To	Formation
0	50	Light Clay
50	60	Light Rock
60	75	Blue Granite

FORM NO. E-22-9-1-72

97816

Joel Campion 135-190-00-02

Joel C. Agner

6753 Lebanon

Joel C. Agner 135-191-00-01

6763 Lebanon Rd

97815

Reece Barker

James C. Brady — Permit #

6800 Lebanon Rd 099463

135-220-00-01

George A Patton

137 013-06