

8508 FATIMA PL

13927118

7/18/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

DX00

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
700 NORTH TRYON ST., SUITE 211
CHARLOTTE, NC 28202
PHONE (704) 336-5102

FILE: ~~36445~~ 45041 DATE: 5/9/96

TC: 139 271 18 ☐ L ☐ CRT

SERIAL Nº 16573

Name of Owner Benjamin + Donna Martin Juris.: _____

Address of Property 8508 Fatima Pl

Inspection Data:

Tank Material +

Total Length of Drainfield 80'

Number of Lines 2 @ 40'

Cover Depth 12"

Water Supply Source well

Distance to Water Source > 50'

Excavation Inspected 5/9/96

Tank(s) Inspected —

Wash Line Inspected 5/9/96

High Water Alarm Inspected NA

PLOT

Design 1996 Repair 24" stone installed CTR# RCS

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☒ altered or repaired

☒ in accordance with the permit issued ☐ as detailed in the plot above

and meets the provisions of I5A NCAC 18A. 1900, "Laws And Rules For Sewage Treatment and Disposal Systems" in effect on the date of issuance of the permit. This issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of I5A NCAC 18A. 1990 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

Notice: Disturbance of the designated repair area may result in the suspension/revocation of this permit.

COMMENTS: Repair for washer line. Existing washer line cut off 24" stone installed

Philo S. Walker R.S.

Environmental Health Specialist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.