

3805 MARWICK RD

11318309

7/2/08

marliwr

Groundwater and Wastewater Services File Imaging Project
May 2007
Barcode Font = IDAutomationHC39M

CERTIFICATE OF COMPLETION/OPERATION PERMIT

DKW

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 12819 DATE: 4/26/94

TC: 13-183-09 ☐ L ☒ CRT

SERIAL № 13770

Name of Owner Thurston Brown Juris.:

Address of Property 3805 Morwick Rd

Inspection Data:

Tank Material

Total Length of Drainfield 130'

Number of Lines 1 (2) 3' x 102' 3' x 28'

Cover Depth 24"

Water Supply Source well


Distance to Water Source 100'

Excavation Inspected 4/26/94

Tank(s) Inspected 4/26/94

Wash Line Inspected

High Water Alarm Inspected



Design: 1994 Alteration 392 Sq Ft, 12" 6 Rock CTR# Gary Bradley 192

The undersigned has inspected the Septic Tank System described above, and certifies it has been

☐ installed or constructed ☒ altered or repaired

☐ in accordance with the permit issued ☒ as detailed in the plot above

and meets the provisions of 10 NCAC 10A .1900, "Laws And Rules For Sanitary Sewage Collection, Treatment, And Disposal" in effect on the date of issuance of the permit. The issuance of this

☒ Certificate of Completion ☐ Operation Permit

does not in any way guarantee that the system will operate properly or relieve any person now or hereafter owning, controlling, or using such system from any liability resulting from the failure of the system to operate properly. This document is issued subject to those restrictions and conditions shown on the permit(s) and the provisions of ~~10 NCAC 10A~~ .1900 in addition to those listed below under "COMMENTS." This document shall be null and void if any information contained in the application is untrue or if any additions are made to the property which would increase the requirements for said system.

COMMENTS: 2nd "T" Installed 2 trenches off New D-Box. 1 trench 3'x102' 1 trench 3'x28 - This Line discontinued because of huge boulder: Original System 1977

P. Walker for S. Daniel 4/26/94

Judy J. Klein R.S.
Environmentalist

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

#5

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT

Approval

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603


2400

FILE: 12819 DATE: 3/5/94

TC: 113-183-09 ☐ L

SERIAL Nº 15956

Permission is hereby given to _____ Install or Construct, ✓ _____ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 3/5/94. All work shall be completed on or before 5/5/94 15 18 after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank _____ gallons

Liquid Capacity of Dosing Tank _____ gallons

Tank Construction _____

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 130' feet

Number of Lines 2

Depth of Stone 12 inches

Distance from House 15' feet

Distance from Property Line 10 feet

Distance from Well >100' feet

NAME OF OWNER Austin Brown

LOCATION OF PROPERTY 3805 Norwich Rd

Comments: Rem 4" pvc from tank Set new D-Box And
Rem 2 Trenches 3' x 65' x 12" Stone
Additional drainfield is to allow for addition of bedroom

J. Walker for S. Daniel 4/7/94 Judy J. Kiser R.S.

Division or Section Head Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

* Installation written to another contractor today (different contractor from last installer)

INSTALLATION, CONSTRUCTION, ALTERATION, AND/OR REPAIR PERMIT


HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 12819 DATE: 2/14/91

TC: 113-183.09 ☐ L

SERIAL Nº 14924

Permission is hereby given to ____ Install or Construct, ✓ Alter or Repair the individual septic tank wastewater treatment system with subsurface, soil absorption, effluent discharge as specified herein at the described location. This permit is granted based upon the information supplied in the application dated 2/11/91. All work shall be completed on or before 3/14/91, after which date this permit shall be null and void. The system shall meet all of the construction requirements of 10 NCAC 10A .1900 which are in effect on the date of the granting of this permit. A Certificate of Completion or an Operation Permit must be obtained from the Mecklenburg County Health Department before any system can be covered up or placed into service. The issuance of this permit does not in any way guarantee that the system anticipated to be constructed will operate properly, or relieve any person now or hereafter owning, controlling or using such system from any liability resulting from the failure of the system to operate properly.



PLOT OF SYSTEM

Liquid Capacity of Septic Tank ~1500 gallons

Liquid Capacity of Dosing Tank ____ gallons

Tank Construction Pcc

Absorption and/or Nitrification Lines:

Trench Width 3 feet

Total Line Length 140 feet

Number of Lines 2

Depth of Stone 12 inches

Distance from House 15 feet

Distance from Property Line 10 feet

Distance from Well > 50' feet

NAME OF OWNER Brown Thurston Noah

LOCATION OF PROPERTY 3805 Marwick Rd

Comments: INSTALL New Septic Tank & Tie into existing D-Box...
INSTALL D-Box and 2 Trenches 3' x 70' 12" Stone
140' drainfield

Division or Section Head

Environmentalist

* If this permit is for the installation or construction of a new system, it must be signed by the division or a section head of the Mecklenburg County Health Department in order to be valid. Only the signature of the Environmentalist is required where an existing system is being altered or repaired.

WHITE - HEALTH DEPARTMENT'S COPY • CANARY - ENVIRONMENTALIST'S COPY • PINK - OWNER OR AGENT'S COPY

APPLICATION FOR AN IMPROVEMENT PERMIT

DLW

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

Mecklenburg County services are available without regard to ethnic origin, sex, or disability.

(OFFICE USE ONLY)
FILE: 12819
TC: 113-183-09
SERIAL: № 21647
☐ L ☑ CRT

JOB LOCATION

① ADDRESS: 3805 (STREET NO.) MARwick Rd (STREET) ② FILE: 12819
③ JURISDICTION: ④ TAX PARCEL NO.:
⑤ SUBDIVISION: ⑥ LOT: 16 ⑦ BLOCK:

OWNER

⑧ NAME: Thurston (FIRST) NOAH (MIDDLE) BROWN (LAST)
⑨ MAILING ADDRESS: 3805 MARwick Rd
⑩ CITY: Charlotte ⑪ STATE: N.C. ⑫ ZIP: 28208
⑬ PHONE: (WORK) 399-3782 ⑭ (HOME) 399-3782

REQUEST

This request is for a(n):

⑮ ☐ New permit
⑯ ☑ Repair or alteration permit
⑰ ☐ Authorization for mobile home exchange
⑱ ☑ Other (specify) USE Existing System Log CABIN

DESIGN CRITERIA

System will serve:

⑲ ☑ Residence ⑳ ☐ Mobile home
㉑ ☐ Business or place of public assembly
㉒ Number of bedrooms? 3
㉕ Type?
㉓ Maximum occupancy? 3
㉖ Maximum number of employees?
㉔ Basement? ☐ no yes
㉗ Maximum number of seats?

WATER SUPPLY

㉘ Water supply from (present or proposed):

A ☑ Individual well
B ☐ Municipal system
C ☐ Community well
D ☐ Community system

㉙ The undersigned, owner of the property described above as the "JOB LOCATION" has read the foregoing application, acknowledges that the contents of same are true, and authorizes agents of the MECKLENBURG COUNTY HEALTH DEPARTMENT to enter onto the property for the purpose of processing this request.

Signed: Thurston Noah Brown
Date: 2/11/91

IMPROVEMENT PERMIT

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. This approval is granted in accordance with the provisions of Laws And Rules For Sanitary Sewage Collection, Treatment And Disposal in effect at the time of issuance of the permit and is subject to the following provisions:

... No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair permit is issued by this Department.

... This permit is not transferable, and shall become null and void ● months from the date of issuance. May use existing System - Mobile Home to be moved before final occupancy is released

Environmentalist RS 4/15/91 Date

Director or Authorized Section Head RS 4/15/91 Date

*This permit must be signed by the Director of Mecklenburg County Health Department or an authorized section head in order to be valid.

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date: 2-12-91

Name/Company: Thurston Noah Brown

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: App Insp. (Log cabin - well, septic sys)
3805 Marwick Rd.
TP: 113-183-09
File: 12819

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
FEB 12 1991

Fee: $ 25.00 Cash #25.00

NOTICE:

A processing fee of $15.00 will be charged for all returned checks in accordance with N.C. General Statute 25-3-512.

Completed by

Collected by

MECKLENBURG COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION

CHARGE SLIP

Date: 02-14-91

Name/Company: Thurston Brown

Sanitation _____

Vector Control _____

O.P.W.D. ✓

Service: Land Disposal
Solid Waste Permit
Application
Ck # 12819

MECKLENBURG COUNTY
HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
PAID
FEB 14 1991

Fee: $ 100.00 Ck # 1100 $100.00

NOTICE:

A processing ~~fee~~ of $15.00 will be charged for all returned checks in accordance with N.C. General Statute 25-3-512.

Completed by

Collected by


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 12819

TC: 113-221-40

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 12819

TC: 113-221-10

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy


PROPOSED PLOT PLAN

HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH DIVISION
1200 BLYTHE BOULEVARD
CHARLOTTE, NC 28203
PHONE (704) 376-4603

FILE: 12819

TC: 113-221-10

Draw in and name all roads adjoining the property. Draw in and accurately dimension the lot concerned. Accurately indicate property boundaries, proposed and/or existing structures and driveways, underground utilities, and wells and springs within 100 feet of the proposed building or drainfield.



APPROVAL DATE _____

White - Health Department's Copy Canary - Environmentalist's Copy Pink - Owner's Copy